

STRASBORG-ENTZHEIM, France

WMO: 071900

Lat: 48.5494N

Lon: 7.6403E

Elev: 154

StdP: 99.49

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.0	-5.5	-11.0	1.5	-7.0	-8.5	1.9	-3.9	11.9	9.9	10.4	8.7	2.3	350	0.498

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	32.0	21.3	29.9	20.3	28.1	19.6	22.1	29.8	21.2	28.1	20.4	26.7	2.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.6	25.2	18.8	13.9	24.2	18.0	13.2	23.3	65.3	30.1	62.0	28.2	59.1	26.8	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.2	7.9	6.8	-11.0	35.0	3.2	1.8	-13.3	36.3	-15.2	37.3	-17.0	38.3	-19.4	39.7
			-11.4	24.0	3.2	0.8	-13.7	24.5	-15.6	25.0	-17.4	25.5	-19.7	26.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	2.3	3.6	7.2	11.2	15.2	18.6	20.2	19.9	15.8	11.5	6.3	3.2
	DBStd	7.41	4.54	4.12	3.79	3.77	3.57	3.57	3.24	3.27	3.05	3.62	3.69	4.28
	HDD10.0	917	241	181	101	31	3	0	0	0	1	27	119	213
	HDD18.3	2791	498	412	344	216	109	40	18	21	87	214	361	469
	CDD10.0	1387	2	2	14	66	165	259	317	306	175	72	9	2
	CDD18.3	219	0	0	0	1	13	49	76	68	12	1	0	0
	CDH23.3	2254	0	0	0	32	162	497	783	653	119	8	0	0
	CDH26.7	732	0	0	0	2	34	156	283	233	23	1	0	0
Wind	WSAvg	2.9	3.2	3.3	3.4	3.1	2.9	2.8	2.7	2.4	2.5	2.5	2.6	3.1
Precipitation	PrecAvg	625	35	34	37	44	76	72	66	66	55	52	48	42
	PrecMax	812	105	80	115	141	203	183	202	134	124	132	105	123
	PrecMin	399	3	5	4	11	19	14	19	6	12	2	3	4
	PrecStd	102	20	18	22	28	37	34	33	30	29	30	25	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	15.9	21.2	26.6	30.1	33.7	34.6	35.0	29.6	24.5	17.5	13.9
		MCWB	11.1	10.3	12.1	15.5	19.1	21.9	21.5	22.0	19.5	17.3	13.4	10.8
	2%	DB	12.0	13.3	18.4	23.8	27.2	30.6	32.0	31.4	26.6	21.2	14.9	12.2
		MCWB	9.5	9.4	11.2	14.3	17.6	20.6	21.4	21.3	18.8	16.0	11.8	10.0
	5%	DB	10.3	11.5	15.8	21.1	25.0	28.3	29.8	29.1	24.3	19.0	13.2	10.7
		MCWB	8.2	8.3	10.4	13.1	16.5	19.9	20.2	20.3	17.7	14.9	11.0	8.8
	10%	DB	8.6	9.8	13.6	18.7	22.8	26.2	27.7	27.0	22.2	17.0	11.7	9.2
		MCWB	6.8	7.2	9.5	12.1	15.7	18.8	19.6	19.5	16.4	13.9	9.9	7.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	11.0	13.5	16.6	20.5	23.2	23.2	23.1	20.7	17.9	13.9	11.5
		MCDB	13.5	14.6	18.7	24.7	27.7	31.0	31.4	31.2	26.7	22.6	16.5	13.1
	2%	WB	9.7	9.7	12.0	14.9	18.8	21.6	22.1	21.8	19.5	16.6	12.4	10.2
		MCDB	11.7	12.9	16.3	21.5	25.2	28.2	30.1	29.6	25.3	20.3	14.5	11.9
	5%	WB	8.3	8.6	10.9	13.7	17.4	20.5	21.1	20.9	18.3	15.5	11.2	8.9
		MCDB	10.2	11.2	14.9	19.8	23.1	26.9	28.2	27.7	23.2	18.4	13.0	10.5
	10%	WB	6.9	7.3	9.8	12.6	16.3	19.5	20.2	20.0	17.2	14.4	10.0	7.8
		MCDB	8.3	9.5	13.4	17.8	21.3	25.3	26.3	26.0	21.1	16.6	11.5	9.2
Mean Daily Temperature Range	5% DB	MDBR	5.2	7.1	9.3	10.9	10.8	11.4	11.7	11.6	10.8	9.0	6.0	5.0
		MCDBR	7.2	10.5	14.1	15.7	15.1	14.8	15.8	15.7	14.4	12.0	8.4	6.9
		MCWBR	5.5	7.1	8.0	7.6	6.9	6.6	6.7	6.6	7.2	7.2	5.9	5.2
	5% WB	MCDBR	6.8	9.7	11.6	14.0	12.9	13.6	14.0	14.1	12.9	11.1	7.9	6.5
		MCWBR	5.4	6.7	7.0	7.1	6.3	6.6	6.3	6.4	6.7	7.0	5.8	5.0
Clear-Sky Solar Irradiance	taub	0.317	0.340	0.370	0.404	0.414	0.420	0.416	0.412	0.387	0.366	0.336	0.313	
	taud	2.449	2.385	2.319	2.248	2.260	2.278	2.276	2.308	2.353	2.405	2.443	2.441	
	Ebn at Noon	750	809	839	844	849	844	841	827	811	766	716	702	
	Edh at Noon	65	85	107	127	130	129	127	118	102	83	65	58	
All-Sky Solar Radiation	RadAvg	0.93	1.68	2.90	4.28	5.07	5.82	5.42	4.71	3.58	2.14	1.07	0.74	
	RadStd	0.14	0.29	0.45	0.59	0.56	0.48	0.53	0.48	0.37	0.18	0.11	0.13	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (82 neighbors)	N/A	N/A	N/A	N/A	+0.33	+0.28	N/A	N/A	N/A	N/A

Nomenclature: See separate page