

BELLE ILE-LE TALUT, France

WMO: 072070

Lat: 47.2944N

Lon: 3.2183W

Elev: 141

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.1	34.6	23.1	17.5	35.0	26.7	20.8	36.8	41.1	50.5	37.3	49.9	14.8	70	0.661

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	78.3	66.3	74.8	65.0	72.0	64.1	68.5	74.8	66.8	72.1	65.5	70.1	10.3	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	97.4	70.7	64.8	92.4	68.9	63.7	88.9	67.8	32.8	74.9	31.4	72.5	30.4	69.9	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.8	31.4	27.7	DB	28.6	84.1	4.1	3.5	25.7	86.6	23.2	88.6	20.9	90.6	17.9	93.1	(4)
(5)			WB	26.5	70.8	3.9	2.2	23.7	72.4	21.4	73.7	19.3	75.0	16.5	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.4	46.7	46.4	49.1	51.9	56.8	61.8	65.0	65.1	62.4	58.3	52.5	48.3
	DBStd	8.10	5.63	4.83	3.89	4.01	4.17	4.27	4.01	3.50	3.54	3.95	4.73	5.96
	HDD50	455	124	112	60	24	1	0	0	0	0	3	30	101
	HDD65	3634	567	522	494	393	256	116	49	40	94	210	376	517
	CDD50	2427	22	10	31	81	214	355	464	467	371	259	104	49
	CDD65	129	0	0	0	0	3	20	48	42	15	1	0	0
	CDH74	382	0	0	0	0	8	73	164	112	25	0	0	0
	CDH80	58	0	0	0	0	0	9	26	20	3	0	0	0
Wind	WSAvg	14.0	16.2	14.8	14.4	13.9	12.9	11.7	12.1	11.6	12.4	14.1	16.1	17.4
Precipitation	PrecAvg	27.9	3.4	2.5	1.9	2.0	1.8	1.4	1.6	1.5	2.1	3.0	3.3	3.3
	PrecMax	35.6	7.4	5.2	6.3	4.6	4.1	2.7	3.2	3.9	6.4	5.8	7.5	5.9
	PrecMin	18.6	0.5	0.5	0.1	0.5	0.4	0.2	0.3	0.1	0.1	0.7	0.7	0.7
	PrecStd	3.7	1.9	1.4	1.3	1.2	0.8	0.8	0.8	1.0	1.5	1.3	1.6	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.3	55.2	63.2	67.4	75.0	81.0	83.3	82.9	77.3	68.3	62.5	58.5
		MCWB	53.7	51.3	53.7	57.4	62.9	67.5	67.2	68.4	64.7	62.8	58.9	55.4
	2%	DB	55.1	53.9	57.8	63.3	70.4	75.7	78.6	76.7	72.8	65.9	61.0	57.3
		MCWB	53.1	51.2	51.2	55.2	61.5	64.8	66.1	66.9	63.2	61.8	58.1	54.8
	5%	DB	54.2	53.0	55.1	60.3	66.2	71.9	74.6	72.9	70.1	64.5	59.8	56.4
		MCWB	52.1	50.7	50.7	53.9	59.5	63.1	65.6	65.6	62.7	61.2	57.1	54.1
	10%	DB	53.3	52.1	53.7	57.6	63.1	68.7	71.4	70.3	67.8	63.4	58.7	55.5
		MCWB	51.2	50.1	50.6	52.7	58.0	62.0	64.4	64.6	62.2	60.3	56.1	53.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.8	53.0	54.8	59.3	65.1	69.4	70.4	71.2	67.8	64.4	60.5	56.6
		MCDB	55.3	53.6	59.9	65.2	72.4	76.4	77.1	78.4	73.6	66.3	61.5	57.3
	2%	WB	53.7	52.1	53.1	56.6	62.4	66.3	68.3	68.5	65.7	63.1	58.9	55.7
		MCDB	54.7	52.9	55.2	61.2	68.1	73.0	75.1	74.1	69.6	64.8	60.2	56.7
	5%	WB	52.7	51.5	52.2	54.9	60.5	64.5	66.6	66.8	64.5	62.1	57.7	54.8
		MCDB	53.8	52.4	53.9	58.6	65.3	70.1	72.3	71.1	67.9	63.8	59.4	56.0
	10%	WB	51.7	50.7	51.5	53.6	58.6	62.8	65.2	65.5	63.3	61.1	56.5	53.9
		MCDB	53.0	51.9	53.1	56.5	62.2	67.5	70.1	69.2	66.6	62.8	58.6	55.3
Mean Daily Temperature Range	5% DB	MDBR	5.8	6.6	7.8	9.0	9.0	9.7	9.6	9.6	9.7	6.9	6.3	5.9
		MCDBR	4.7	5.7	10.0	13.3	14.3	15.7	16.1	14.0	12.9	7.3	5.3	4.6
		MCWBR	5.2	5.6	6.5	7.9	8.1	8.3	8.1	7.1	6.6	5.3	5.6	5.1
	5% WB	MCDBR	4.5	5.1	7.2	10.0	12.2	13.0	12.8	11.2	9.2	5.8	4.9	4.3
		MCWBR	5.3	5.7	5.5	6.8	7.7	7.8	7.5	6.7	6.3	5.1	5.9	5.1
Clear-Sky Solar Irradiance	taub	0.337	0.348	0.374	0.387	0.392	0.391	0.387	0.377	0.364	0.364	0.342	0.330	
	taud	2.433	2.420	2.366	2.349	2.382	2.413	2.425	2.469	2.484	2.471	2.450	2.412	
	Ebn at Noon	235	258	267	275	277	277	277	275	269	249	230	221	
	Edh at Noon	22	27	33	36	37	36	35	32	29	25	21	20	
All-Sky Solar Radiation	RadAvg	345	646	1039	1551	1835	2007	1923	1686	1340	764	437	302	
	RadStd	32	63	105	147	120	172	81	110	89	62	38	33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page