

POINTE DE CHEMOULIN, France

WMO: 072160

Lat: 47.2340N

Lon: 2.2989W

Elev: 66

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 01-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 2	(b) 29.4	(c) 31.9	(d) 23.2	(e) 17.5	(f) 33.2	(g) 26.3	(h) 20.3	(i) 35.2	(j) 56.5	(k) 49.3	(l) 50.4	(m) 49.6	(n) 10.6	(o) 40	(p) 0.644

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.4	(c) 82.8	(d) 68.3	(e) 78.8	(f) 66.8	(g) 75.5	(h) 64.9	(i) 69.8	(j) 78.8	(k) 68.1	(l) 75.8	(m) 66.7	(n) 73.1	(o) 8.9	(p) 70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.9	99.2	73.1	65.5	94.4	71.4	64.3	90.4	70.1	33.8	78.3	32.4	76.2	31.3	73.5	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 43.5	(b) 36.6	(c) 31.1	(e) 25.7	(f) 90.0	(g) 3.0	(h) 4.0	(i) 23.6	(j) 92.9	(k) 21.8	(l) 95.2	(m) 20.1	(n) 97.4	(o) 18.0	(p) 100.3		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.7	45.0	45.1	49.1	53.8	58.4	64.1	66.7	66.1	64.0	58.8	51.2	45.7
	DBStd	9.41	5.51	5.22	5.07	4.86	4.53	4.78	4.41	3.75	4.13	4.64	5.18	5.84
	HDD50	602	163	143	75	15	0	0	0	0	5	47	154	
	HDD65	3626	620	557	494	338	214	74	27	27	66	195	415	599
	CDD50	2684	8	6	46	128	260	422	518	498	419	278	82	19
	CDD65	235	0	0	0	1	8	46	81	61	35	3	0	0
	CDH74	1038	0	0	0	15	54	220	406	220	118	5	0	0
	CDH80	243	0	0	0	5	6	46	116	54	15	1	0	0
(14) Wind	WSAvg	13.5	14.4	14.1	13.0	12.9	14.1	12.8	13.1	12.4	11.5	14.1	13.7	15.9
(15) Precipitation	PrecAvg	26.9	3.0	2.4	1.9	2.0	1.9	1.3	1.5	1.4	2.1	3.1	3.3	3.1
	PrecMax	35.7	6.1	5.1	5.0	5.1	3.8	2.6	3.1	3.8	5.4	6.7	6.9	5.9
	PrecMin	18.1	0.4	0.3	0.2	0.5	0.3	0.2	0.1	0.0	0.1	0.8	0.8	0.1
	PrecStd	4.2	1.5	1.3	1.2	1.1	0.9	0.7	0.7	1.0	1.4	1.5	1.7	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	57.3	70.3	73.4	80.1	85.5	88.1	87.9	82.0	72.1	63.1	57.7
		MCWB	53.1	50.5	60.0	60.9	65.9	69.9	67.7	72.3	68.4	64.3	59.1	55.3
	2%	DB	53.7	53.8	62.9	68.1	73.8	79.7	83.3	80.5	77.1	68.2	61.2	55.7
		MCWB	52.2	50.1	54.4	57.9	63.6	67.4	67.2	68.3	64.2	61.8	57.1	53.5
	5%	DB	52.5	52.4	58.5	64.6	69.4	75.7	78.4	75.7	74.2	66.0	59.6	54.4
		MCWB	51.2	49.9	51.3	56.6	61.2	65.3	66.1	65.8	62.7	61.4	55.9	52.3
	10%	DB	51.6	51.2	55.5	61.5	65.6	72.4	74.1	72.5	71.1	64.5	58.2	53.2
		MCWB	50.3	49.3	50.8	55.2	59.0	64.3	65.3	65.0	62.1	60.9	54.9	51.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.2	52.8	57.8	62.0	67.1	71.1	70.2	73.9	69.2	64.7	60.3	55.9
		MCDB	54.7	54.6	64.1	68.1	77.5	81.6	81.6	85.9	77.9	68.2	62.2	56.9
	2%	WB	53.1	51.6	54.3	59.6	64.4	69.2	68.4	70.5	66.8	63.3	58.1	54.0
		MCDB	53.8	52.6	58.3	64.5	72.6	77.6	77.9	78.6	72.5	66.0	60.1	54.9
	5%	WB	51.7	50.9	52.9	57.4	62.3	67.2	67.3	68.1	65.5	62.4	56.5	52.7
		MCDB	52.2	52.0	55.3	62.0	68.5	74.2	75.0	73.8	69.9	64.4	58.4	53.8
	10%	WB	50.7	50.0	51.9	55.6	60.2	65.4	66.1	66.3	64.2	61.5	54.9	51.5
		MCDB	51.4	51.2	53.6	60.2	64.7	71.2	72.2	71.6	68.6	63.5	56.9	52.8
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	8.7	10.8	12.2	11.8	12.9	11.4	11.6	13.9	9.1	8.9	7.9
		MCDBR	5.9	9.2	17.1	18.9	19.5	20.7	21.4	18.6	19.3	11.2	9.3	6.4
	5% WB	MCWBR	5.1	7.0	10.6	10.7	11.0	10.5	10.0	9.9	10.0	7.7	7.5	5.9
		MCWBR	4.6	6.3	10.8	14.9	16.5	17.6	15.5	16.2	13.3	8.7	6.8	5.4
(40) Clear-Sky Solar Irradiance	taub		0.334	0.348	0.376	0.391	0.396	0.399	0.394	0.383	0.367	0.365	0.341	0.328
	taud		2.430	2.405	2.334	2.300	2.334	2.358	2.374	2.422	2.446	2.444	2.442	2.410
	Ebn at Noon		236	258	267	273	276	275	274	273	268	248	231	222
	Edh at Noon		22	27	34	38	39	38	37	34	30	26	22	20
(44) All-Sky Solar Radiation	RadAvg		347	645	1033	1535	1814	1990	1907	1676	1331	763	437	304
	RadStd		32	64	107	148	123	171	85	116	90	62	39	34

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page