

ORLEANS BRICY AB, France

WMO: 072490

Lat: 47.9908N

Lon: 1.7783E

Elev: 126

StdP: 99.83

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.9	(c) -3.8	(d) -8.9	(e) 1.8	(f) -4.5	(g) -6.5	(h) 2.2	(i) -2.6	(j) 13.2	(k) 10.7	(l) 12.0	(m) 9.9	(n) 3.1	(o) 50	(p) 0.563

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	31.3	20.2	29.2	19.4	27.3	18.7	21.3	28.8	20.4	27.1	19.5	25.5	3.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.0	23.7	18.0	13.2	22.9	17.2	12.4	21.9	62.4	28.9	58.9	27.2	55.9	25.5	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.9	9.6	8.5	-8.9	34.8	3.2	2.3	-11.2	36.4	-13.1	37.8	-14.9	39.0	-17.3	40.7		
			-9.1	23.3	3.2	1.3	-11.4	24.3	-13.3	25.0	-15.0	25.7	-17.3	26.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	4.1	4.9	7.5	10.3	13.9	17.2	19.4	19.0	15.7	12.3	7.5	4.7	(6)	(7)
	DBStd	6.48	4.14	4.03	3.50	3.40	3.33	3.39	3.09	3.10	2.93	3.55	3.76	3.99	(7)	(8)
	HDD10.0	742	186	146	93	36	6	1	0	0	1	18	91	167	(8)	(9)
	HDD18.3	2671	442	377	336	241	143	60	24	27	88	187	324	422	(9)	(10)
	CDD10.0	1261	2	2	16	46	125	217	291	280	172	90	17	4	(10)	(11)
	CDD18.3	148	0	0	0	0	5	27	57	49	10	1	0	0	(11)	(12)
	CDH23.3	1704	0	0	0	13	67	317	645	533	118	12	0	0	(12)	(13)
	CDH26.7	547	0	0	0	1	7	99	223	190	26	1	0	0	(13)	(14)
(14) Wind	WSAvg	4.1	4.6	4.6	4.6	4.1	3.9	3.7	3.7	3.5	3.7	3.9	4.1	4.6	(14)	(15)
(15) Precipitation	PrecAvg	640	56	48	50	47	65	48	53	44	52	60	61	54	(15)	(16)
	PrecMax	874	110	104	110	121	148	103	119	111	144	181	137	111	(16)	(17)
	PrecMin	413	10	7	3	9	9	1	11	4	8	8	16	2	(17)	(18)
	PrecStd	124	28	26	25	26	35	24	24	27	35	43	29	29	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	16.2	20.7	25.0	27.6	32.7	34.4	34.1	29.5	24.9	17.6	13.9	(19)	(20)
		MCWB	11.6	10.5	12.7	15.9	19.1	22.0	20.7	20.5	18.3	17.2	14.5	12.4	(20)	(21)
	2%	DB	12.1	13.1	17.7	22.3	25.2	29.4	31.3	31.1	26.7	21.8	15.5	12.7	(21)	(22)
		MCWB	10.7	9.7	11.7	14.6	17.4	20.0	20.1	19.9	17.6	16.5	13.5	11.2	(22)	(23)
	5%	DB	11.0	11.5	15.3	19.4	23.1	26.9	29.2	28.8	24.2	19.4	14.1	11.7	(23)	(24)
		MCWB	9.7	9.4	10.8	13.1	16.5	19.2	19.2	19.3	16.9	15.5	12.4	10.4	(24)	(25)
	10%	DB	9.7	10.4	13.4	16.9	20.9	24.6	27.0	26.3	22.0	17.6	12.7	10.6	(25)	(26)
		MCWB	8.6	8.7	10.1	11.8	15.5	18.0	18.7	18.2	15.9	14.6	11.4	9.5	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	11.7	13.8	17.2	20.3	22.9	22.3	22.1	20.2	18.4	15.2	12.7	(27)	(28)
		MCDB	12.8	13.8	18.1	23.6	25.9	29.9	30.7	30.2	25.4	22.3	16.6	13.5	(28)	(29)
	2%	WB	11.0	10.6	12.6	15.1	18.4	21.1	21.1	20.9	18.7	17.1	13.8	11.6	(29)	(30)
		MCDB	11.8	12.3	16.0	20.7	23.8	27.3	29.3	28.6	24.0	20.2	15.1	12.4	(30)	(31)
	5%	WB	9.9	9.7	11.5	13.6	17.1	19.9	20.2	19.9	17.7	16.1	12.6	10.6	(31)	(32)
		MCDB	10.9	11.3	14.4	18.3	21.8	25.5	27.4	26.7	23.0	18.8	13.9	11.5	(32)	(33)
	10%	WB	8.7	8.7	10.5	12.3	15.8	18.6	19.2	18.9	16.7	15.1	11.5	9.5	(33)	(34)
		MCDB	9.6	10.3	13.1	16.2	20.0	23.7	25.4	24.8	20.8	17.3	12.6	10.5	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	7.0	9.0	10.6	10.6	11.2	12.0	11.8	10.8	8.5	6.2	5.4	(35)	(36)
		MCDBR	5.7	8.8	12.4	14.7	13.9	15.3	16.2	15.9	14.7	11.0	7.0	5.9	(36)	(37)
	5% WB	MCWBR	4.8	6.1	7.4	7.9	7.4	7.2	6.4	6.4	7.0	6.3	5.1	4.9	(37)	(38)
		MCDWR	5.4	7.7	10.2	12.9	12.6	13.7	14.1	13.9	11.9	9.5	6.5	5.3	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.323	0.342	0.371	0.399	0.403	0.412	0.408	0.397	0.368	0.361	0.334	0.319	(39)	(40)
		taud	2.438	2.386	2.302	2.226	2.255	2.269	2.272	2.323	2.389	2.416	2.442	2.412	(40)	(41)
	Ebn at Noon		749	811	840	850	860	853	850	843	835	778	725	700	(41)	(42)
		Edh at Noon	67	86	109	130	131	130	128	117	99	83	66	61	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		0.98	1.79	2.98	4.41	5.19	5.83	5.58	4.88	3.78	2.25	1.19	0.84	(43)	(44)
	RadStd		0.10	0.25	0.37	0.52	0.48	0.56	0.40	0.46	0.29	0.19	0.12	0.12	(44)	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page