

AVORD AB, France

WMO: 072570

Lat: 47.0522N

Lon: 2.6422E

Elev: 581

StdP: 14.39

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.7	25.1	16.2	12.7	25.0	20.4	15.6	27.9	28.3	49.2	25.4	48.2	7.3	40	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	91.0	68.8	86.3	67.7	82.7	66.1	70.5	85.2	69.0	82.8	67.5	80.1	8.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	98.4	74.9	64.5	92.9	72.9	63.0	87.9	71.8	34.7	85.8	33.4	82.9	32.2	80.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.6	19.5	17.1	17.6	96.5	4.8	4.2	14.1	99.5	11.3	102.0	8.6	104.3	5.2	107.4		
			16.9	73.7	4.7	1.6	13.5	74.9	10.7	75.8	8.0	76.8	4.6	78.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.3	39.4	40.4	46.3	51.3	58.0	65.0	68.2	67.8	61.6	55.1	45.5	40.4
	DBStd	12.33	7.36	7.13	6.52	6.04	6.20	6.25	5.88	6.25	5.67	6.91	7.08	7.39
	HDD50	1324	334	273	150	54	6	0	0	0	1	32	169	305
	HDD65	4640	795	689	580	411	230	75	32	37	132	310	586	763
	CDD50	2541	5	4	35	94	255	451	564	551	350	192	33	7
	CDD65	381	0	0	0	1	13	76	131	124	31	5	0	0
	CDH74	4108	0	0	0	27	176	823	1383	1337	326	36	0	0
	CDH80	1475	0	0	0	1	24	281	527	561	79	2	0	0
Wind	WSAvg	7.9	8.5	8.9	9.0	8.3	7.6	7.4	7.7	7.0	7.1	7.1	7.8	8.5
Precipitation	PrecAvg	32.5	2.6	2.3	2.2	2.7	3.0	2.4	2.8	2.7	2.5	3.1	3.1	3.0
	PrecMax	41.5	6.1	4.4	6.0	8.2	7.1	4.6	7.1	6.4	6.5	5.6	6.6	6.3
	PrecMin	24.1	0.3	0.2	0.4	0.4	0.6	0.3	0.6	0.3	0.8	0.9	1.2	0.8
	PrecStd	4.5	1.3	1.2	1.4	1.7	1.3	1.1	1.5	1.4	1.4	1.2	1.3	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.8	62.7	70.2	77.4	82.8	93.5	95.1	99.1	87.4	78.8	65.8	58.7
		MCWB	51.6	51.1	54.6	60.9	66.4	70.3	69.4	69.5	65.3	63.6	57.7	52.6
	2%	DB	54.4	57.0	65.5	72.0	78.8	86.9	89.8	91.4	82.0	73.3	61.0	55.6
		MCWB	51.2	49.7	52.7	57.8	63.4	68.6	69.0	68.6	64.8	62.1	55.4	51.9
	5%	DB	52.1	53.4	61.1	67.8	75.1	82.5	85.8	86.1	77.4	68.6	58.5	53.5
		MCWB	49.2	48.0	51.3	56.1	62.5	66.9	67.7	67.3	63.0	60.5	54.5	50.5
	10%	DB	49.9	50.5	57.4	63.4	71.2	78.5	82.1	81.1	73.5	65.3	55.5	51.2
		MCWB	47.6	46.9	49.8	53.6	60.5	65.2	66.0	65.5	61.6	58.7	52.2	48.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.2	53.0	56.8	62.2	68.2	73.3	71.8	72.3	69.2	65.3	59.4	54.8
		MCDB	55.2	59.0	64.7	74.8	79.6	87.0	88.2	87.5	79.5	74.1	62.4	56.7
	2%	WB	52.0	50.8	54.5	59.1	65.6	70.3	70.0	70.0	66.8	63.1	56.7	52.6
		MCDB	54.2	54.7	62.0	70.4	76.6	83.2	85.8	85.2	77.1	70.2	60.3	55.0
	5%	WB	49.8	49.2	52.7	56.7	63.2	68.2	68.5	68.4	64.8	61.3	54.5	50.8
		MCDB	51.7	52.4	59.3	65.4	72.4	79.6	82.9	83.2	74.5	67.6	57.9	53.1
	10%	WB	47.6	47.4	50.9	54.5	61.0	66.3	66.9	66.8	63.0	59.5	52.5	48.8
		MCDB	49.5	50.5	56.5	61.9	69.5	76.3	79.5	79.3	71.4	64.6	55.5	50.8
Mean Daily Temperature Range	5% DB	MDBR	10.3	13.5	16.9	18.6	18.8	19.8	20.5	20.8	19.7	16.1	12.0	10.7
		MCDBR	11.5	18.1	23.8	26.4	25.2	27.0	27.4	29.2	26.5	20.4	15.1	12.7
		MCWBR	9.0	12.1	13.6	14.1	12.6	11.3	10.5	10.9	11.8	11.2	10.1	9.8
	5% WB	MCDBR	10.4	15.4	19.7	24.1	22.2	24.0	24.6	24.5	21.3	18.4	13.8	11.4
		MCWBR	9.1	11.2	12.2	13.6	11.9	11.0	9.9	10.0	10.8	10.8	9.8	9.4
Clear-Sky Solar Irradiance	taub	0.315	0.335	0.363	0.396	0.399	0.410	0.404	0.397	0.365	0.358	0.329	0.312	
	taud	2.455	2.399	2.327	2.234	2.274	2.282	2.294	2.330	2.399	2.424	2.455	2.444	
	Ebn at Noon	245	263	271	272	275	272	271	269	268	251	237	231	
	Edh at Noon	21	28	34	41	41	41	40	37	31	27	21	19	
All-Sky Solar Radiation	RadAvg	334	593	994	1395	1639	1885	1820	1592	1229	757	404	282	
	RadStd	45	90	120	171	158	175	135	142	95	57	44	49	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page