

NEVERS-FOURCHAMBAULT AP, France

WMO: 072600

Lat: 46.9983N

Lon: 3.1128E

Elev: 581

StdP: 14.39

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.3	23.0	14.5	11.7	21.4	18.6	14.3	25.4	22.1	48.4	19.6	47.5	2.5	20	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.4	89.4	69.4	85.5	68.4	82.1	67.0	71.4	84.9	69.7	82.9	68.1	79.8	7.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	100.8	77.3	65.3	95.5	75.2	63.9	90.7	73.3	35.5	85.0	34.0	83.0	32.7	80.0	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	15.7	13.8	13.5	94.8	4.8	4.1	10.1	97.8	7.3	100.2	4.6	102.5	1.1	105.5		
(5)			12.9	74.3	4.7	1.4	9.5	75.3	6.8	76.1	4.1	76.9	0.7	77.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	38.8	39.8	45.4	50.1	56.9	63.8	66.9	66.2	59.3	53.8	44.7	39.8		
	DBStd	12.05	7.64	7.24	6.41	6.01	6.11	6.18	5.68	5.98	5.60	7.11	7.18	7.74		
	HDD50	1450	351	290	170	71	11	0	0	0	3	45	186	323		
	HDD65	4954	812	706	609	446	261	94	45	55	186	351	608	781		
	CDD50	2251	4	4	26	75	223	415	524	503	281	162	27	7		
	CDD65	284	0	0	0	0	9	59	104	93	15	4	0	0		
	CDH74	3663	0	0	0	27	177	789	1244	1165	235	26	0	0		
	CDH80	1231	0	0	0	1	26	257	436	461	48	2	0	0		
(14) Wind	WSAvg	5.9	6.6	6.7	6.7	6.3	5.8	5.6	5.5	4.9	4.7	5.3	5.9	6.5		
(15) Precipitation	PrecAvg	31.4	2.4	2.2	2.0	2.8	3.0	2.5	2.5	2.6	2.6	3.0	3.1	2.8		
	PrecMax	39.4	5.4	4.3	4.7	8.1	6.1	5.6	5.4	6.3	6.7	4.9	6.2	5.9		
	PrecMin	22.9	0.4	0.3	0.4	0.1	0.5	0.5	0.4	0.7	0.9	1.1	1.1	0.6		
	PrecStd	3.9	1.2	1.1	1.3	1.7	1.3	1.1	1.2	1.4	1.3	1.2	1.2	1.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.8	62.1	70.8	77.5	83.4	92.6	93.6	96.9	85.3	77.4	65.6	59.0		
		MCWB	51.6	51.0	54.9	60.8	67.0	71.2	69.3	70.3	66.3	63.2	57.6	52.7		
	2%	DB	54.4	57.2	65.9	72.4	78.8	86.2	88.6	89.6	80.4	72.8	60.8	55.6		
		MCWB	50.8	49.4	53.3	58.0	63.9	69.1	69.4	69.3	65.4	62.6	55.3	51.9		
	5%	DB	52.3	53.5	61.4	68.0	74.9	82.2	84.8	84.9	76.2	68.4	58.1	53.1		
		MCWB	49.0	48.1	51.5	55.5	62.5	67.4	68.1	68.3	63.6	60.4	54.1	50.2		
	10%	DB	49.7	50.8	57.5	63.6	70.9	78.2	81.2	80.5	72.2	64.9	55.4	51.0		
		MCWB	47.0	46.8	49.9	53.5	60.2	65.5	66.7	66.9	61.9	58.8	52.2	48.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.6	52.9	57.0	62.4	68.7	73.5	73.0	73.0	69.8	65.5	59.2	54.6		
		MCDB	55.2	58.3	66.5	75.1	80.2	87.9	87.0	87.1	80.1	73.7	63.1	57.0		
	2%	WB	51.4	50.7	54.5	59.4	65.8	70.7	70.9	71.1	66.9	63.1	56.5	52.3		
		MCDB	54.0	55.0	62.4	70.1	76.4	83.2	84.8	85.0	76.4	70.2	59.8	54.9		
	5%	WB	49.2	49.0	52.7	56.7	63.4	68.5	69.3	69.3	64.8	61.3	54.5	50.5		
		MCDB	51.8	52.7	59.8	65.3	72.8	79.9	82.5	82.8	74.0	67.2	57.7	52.9		
	10%	WB	47.1	47.2	50.8	54.4	61.0	66.5	67.5	67.5	63.0	59.3	52.4	48.4		
		MCDB	49.5	50.8	56.6	61.8	69.2	76.3	79.0	78.6	70.4	64.2	55.3	50.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.5	15.1	19.8	21.6	21.4	22.0	22.4	23.2	22.2	18.4	13.6	11.6		
		MCDBR	13.3	20.7	28.7	31.1	29.2	30.0	29.9	32.0	30.1	22.9	16.5	13.3		
		MCWBR	10.2	14.4	17.4	17.8	16.3	14.5	13.2	14.0	16.1	13.9	11.7	10.3		
	5% WB	MCDBR	12.0	17.6	23.6	27.6	26.4	26.8	26.6	28.1	25.4	20.6	15.1	12.1		
		MCWBR	9.9	13.0	15.1	16.3	15.3	13.5	12.3	13.2	14.4	13.1	11.2	9.9		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.335	0.363	0.396	0.400	0.410	0.405	0.398	0.367	0.358	0.328	0.311		
	taud		2.455	2.400	2.329	2.236	2.272	2.283	2.295	2.329	2.393	2.420	2.455	2.447		
	Ebn at Noon		246	263	272	272	274	272	271	268	267	251	237	232		
	Edh at Noon		21	28	34	41	41	41	40	37	32	27	21	19		
(44) All-Sky Solar Radiation	RadAvg		336	596	996	1395	1639	1886	1823	1595	1231	759	407	284		
	RadStd		45	90	120	171	158	175	135	142	94	57	44	49		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.60	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page