

AUXERRE PERRIGNY, France

WMO: 072660

Lat: 47.8249N

Lon: 3.5499E

Elev: 502

StdP: 14.43

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	25.0	15.0	12.0	23.9	19.4	14.9	27.9	21.8	48.8	19.7	48.4	4.2	20	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	90.8	68.7	86.5	67.7	82.8	66.4	70.8	85.6	69.2	83.1	67.6	79.9	5.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	98.1	75.6	64.7	93.1	73.4	63.3	88.7	71.9	34.9	86.3	33.5	83.4	32.2	80.3	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.4	14.8	12.9	16.6	97.6	4.6	4.1	13.3	100.6	10.6	103.0	8.0	105.3	4.6	108.3		
(5)			16.0	74.2	4.7	1.9	12.6	75.5	9.9	76.6	7.3	77.7	3.9	79.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.2	39.0	40.6	46.4	51.5	58.0	64.6	68.4	67.8	60.9	54.6	45.2	39.9		
	DBStd	12.39	7.54	7.22	6.50	6.54	6.44	6.46	5.91	6.26	5.66	6.80	6.90	7.30		
	HDD50	1351	345	267	148	58	9	0	0	0	1	34	171	318		
	HDD65	4705	807	683	577	407	233	85	31	37	148	327	593	777		
	CDD50	2501	3	4	36	102	256	438	571	553	328	176	28	6		
	CDD65	380	0	0	0	1	15	73	137	125	25	4	0	0		
	CDH74	4003	0	0	1	43	188	782	1411	1289	262	27	0	0		
	CDH80	1454	0	0	0	3	31	271	548	536	64	1	0	0		
(14) Wind	WSAvg	5.6	7.0	7.0	6.7	5.9	5.0	4.6	4.7	4.5	4.5	5.0	5.9	6.9		
(15) Precipitation	PrecAvg	25.7	2.1	1.9	1.9	1.7	2.8	2.5	1.9	2.1	2.2	2.4	2.1	2.2		
	PrecMax	34.4	4.4	4.6	4.9	3.9	6.1	5.8	4.4	5.3	8.0	6.2	3.7	4.3		
	PrecMin	15.8	0.6	0.4	0.4	0.3	0.7	0.3	0.5	0.2	0.2	0.1	0.8	0.2		
	PrecStd	4.9	1.1	1.1	1.0	0.9	1.5	1.4	1.1	1.3	1.6	1.6	0.8	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.9	61.6	70.6	79.0	83.7	93.2	96.0	99.3	86.5	77.7	65.1	58.1		
		MCWB	51.7	50.8	54.7	60.4	66.4	69.5	69.6	68.9	65.4	63.4	57.0	52.6		
	2%	DB	53.6	56.6	65.5	73.6	79.3	86.9	90.3	91.1	81.0	72.4	60.8	54.9		
		MCWB	50.3	48.7	52.7	58.1	63.9	68.7	68.6	68.5	64.8	62.3	55.5	51.5		
	5%	DB	51.4	53.1	61.1	68.5	75.2	82.5	86.1	86.0	76.3	68.2	57.6	52.6		
		MCWB	48.4	47.9	51.3	55.5	62.0	66.9	67.5	67.5	63.2	60.3	53.6	49.9		
	10%	DB	49.1	50.5	57.2	63.8	71.0	78.0	82.1	81.3	72.1	64.5	54.9	50.4		
		MCWB	46.5	46.6	49.6	53.2	60.0	65.1	66.2	65.9	61.4	58.4	51.9	48.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.2	52.6	56.7	62.3	68.8	73.0	72.3	72.5	68.9	65.2	58.8	54.3		
		MCDB	55.0	57.6	65.9	75.4	81.0	86.7	87.4	87.6	81.0	73.3	62.4	56.5		
	2%	WB	50.9	50.4	54.1	59.1	65.5	70.1	70.5	70.3	66.3	63.0	56.1	52.1		
		MCDB	53.0	54.3	61.8	71.1	75.9	83.0	85.9	85.8	76.4	70.2	59.7	54.3		
	5%	WB	48.8	48.7	52.4	56.5	63.1	68.1	68.8	68.7	64.5	61.1	54.0	50.2		
		MCDB	51.1	52.3	59.1	66.1	72.7	80.2	82.8	82.8	74.0	66.8	57.1	52.4		
	10%	WB	46.7	46.9	50.6	54.2	60.9	66.1	67.2	67.0	62.6	59.3	52.1	48.1		
		MCDB	48.8	50.2	56.2	61.9	69.4	76.1	79.3	78.8	70.2	63.9	54.8	50.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	12.2	16.1	18.4	18.8	19.7	20.4	20.5	18.8	15.6	10.8	9.3		
		MCDBR	11.3	17.3	23.9	26.6	25.8	27.8	28.5	29.3	26.2	21.1	14.8	11.3		
		MCWBR	8.6	11.3	13.2	13.2	12.5	11.8	10.5	10.5	12.0	11.8	9.9	8.8		
	5% WB	MCDBR	10.2	14.7	19.5	23.7	23.1	24.7	25.0	24.5	22.3	18.6	13.2	10.5		
		MCWBR	8.4	10.5	11.6	12.3	12.0	11.3	10.0	9.9	10.8	11.1	9.4	8.7		
(40) Clear-Sky Solar Irradiance	taub		0.317	0.338	0.366	0.399	0.404	0.414	0.410	0.401	0.371	0.360	0.330	0.314		
	taud		2.444	2.390	2.316	2.227	2.258	2.267	2.275	2.318	2.383	2.409	2.444	2.422		
	Ebn at Noon		241	260	269	270	272	270	269	266	264	247	233	225		
	Edh at Noon		21	27	34	41	42	41	41	37	32	27	21	19		
(44) All-Sky Solar Radiation	RadAvg		306	565	960	1393	1641	1861	1778	1553	1197	725	376	258		
	RadStd		42	85	117	167	164	172	139	147	102	56	39	45		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page