

AUXERRE PERRIGNY, France

WMO: 072660

Lat: 47.8249N

Lon: 3.5499E

Elev: 153

StdP: 99.50

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.9	-3.9	-9.5	1.7	-4.5	-7.0	2.1	-2.3	9.8	9.4	8.8	9.1	1.9	20	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	32.6	20.4	30.3	19.8	28.2	19.1	21.5	29.8	20.6	28.4	19.8	26.6	2.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.0	24.2	18.1	13.3	23.0	17.4	12.7	22.2	63.2	30.2	60.0	28.5	57.1	26.9	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.6	5.7	-8.6	36.5	2.6	2.3	-10.4	38.1	-11.9	39.4	-13.4	40.7	-15.2	42.4		
			-8.9	23.4	2.6	1.0	-10.8	24.2	-12.3	24.8	-13.7	25.4	-15.6	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.8	3.9	4.8	8.0	10.8	14.4	18.1	20.2	19.9	16.1	12.5	7.4	4.4
	DBStd	6.88	4.19	4.01	3.61	3.63	3.58	3.59	3.28	3.48	3.14	3.78	3.83	4.06
	HDD10.0	751	192	148	82	32	5	0	0	0	1	19	95	177
	HDD18.3	2614	448	379	321	226	129	47	17	21	82	182	329	432
	CDD10.0	1389	2	2	20	57	142	243	317	307	182	98	16	3
	CDD18.3	211	0	0	0	1	8	41	76	69	14	2	0	0
	CDH23.3	2224	0	0	1	24	104	434	784	716	146	15	0	0
	CDH26.7	808	0	0	0	2	17	151	304	298	36	1	0	0
Wind	WSAvg	2.5	3.1	3.1	3.0	2.6	2.2	2.1	2.1	2.0	2.0	2.2	2.6	3.1
Precipitation	PrecAvg	654	53	49	48	42	72	63	48	54	57	60	54	56
	PrecMax	874	113	117	124	100	156	147	113	135	202	158	93	109
	PrecMin	401	16	9	9	8	18	8	12	4	6	2	20	5
	PrecStd	125	27	29	26	24	37	35	28	34	41	40	21	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.3	16.5	21.4	26.1	28.7	34.0	35.6	37.4	30.3	25.4	18.4	14.5
		MCWB	10.9	10.4	12.6	15.8	19.1	20.8	20.9	20.5	18.5	17.4	13.9	11.5
	2%	DB	12.0	13.7	18.6	23.1	26.3	30.5	32.4	32.9	27.2	22.5	16.0	12.7
		MCWB	10.2	9.3	11.5	14.5	17.7	20.4	20.3	20.3	18.2	16.8	13.1	10.8
	5%	DB	10.8	11.7	16.2	20.3	24.0	28.0	30.1	30.0	24.6	20.1	14.2	11.5
		MCWB	9.1	8.8	10.7	13.1	16.6	19.4	19.7	19.7	17.3	15.7	12.0	9.9
	10%	DB	9.5	10.3	14.0	17.7	21.7	25.6	27.8	27.4	22.3	18.1	12.7	10.2
		MCWB	8.1	8.1	9.8	11.8	15.6	18.4	19.0	18.9	16.3	14.7	11.0	8.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	11.5	13.7	16.8	20.5	22.8	22.4	22.5	20.5	18.4	14.9	12.4
		MCDB	12.8	14.2	18.8	24.1	27.2	30.4	30.8	30.9	27.2	22.9	16.9	13.6
	2%	WB	10.5	10.2	12.3	15.1	18.6	21.1	21.4	21.3	19.1	17.2	13.4	11.1
		MCDB	11.7	12.4	16.5	21.7	24.4	28.3	30.0	29.9	24.7	21.2	15.4	12.4
	5%	WB	9.3	9.3	11.3	13.6	17.3	20.0	20.5	20.4	18.0	16.2	12.2	10.1
		MCDB	10.6	11.3	15.1	19.0	22.6	26.8	28.2	28.2	23.3	19.4	14.0	11.3
	10%	WB	8.2	8.3	10.3	12.3	16.0	19.0	19.5	19.4	17.0	15.1	11.2	8.9
		MCDB	9.3	10.1	13.5	16.6	20.8	24.5	26.3	26.0	21.2	17.7	12.7	10.1
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.8	9.0	10.2	10.4	10.9	11.3	11.4	10.4	8.6	6.0	5.2
		MCDBR	6.3	9.6	13.3	14.8	14.3	15.4	15.8	16.3	14.6	11.7	8.2	6.3
		MCWBR	4.8	6.3	7.4	7.3	6.9	6.6	5.8	5.8	6.7	6.6	5.5	4.9
	5% WB	MCDBR	5.7	8.2	10.8	13.1	12.8	13.7	13.9	13.6	12.4	10.4	7.3	5.8
		MCWBR	4.7	5.8	6.4	6.8	6.7	6.3	5.5	5.5	6.0	6.2	5.2	4.9
Clear-Sky Solar Irradiance	taub	0.317	0.338	0.366	0.399	0.404	0.414	0.410	0.401	0.371	0.360	0.330	0.314	
	taud	2.444	2.390	2.316	2.227	2.258	2.267	2.275	2.318	2.383	2.409	2.444	2.422	
	Ebn at Noon	760	819	847	851	859	851	848	840	833	779	733	710	
	Edh at Noon	66	86	108	130	131	130	128	117	100	84	66	60	
All-Sky Solar Radiation	RadAvg	0.97	1.78	3.02	4.39	5.17	5.87	5.61	4.90	3.77	2.29	1.19	0.81	
	RadStd	0.13	0.27	0.37	0.53	0.52	0.54	0.44	0.46	0.32	0.18	0.12	0.14	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page