

BOURGOGNE AP, France

WMO: 072800

Lat: 47.2678N

Lon: 5.0883E

Elev: 726

StdP: 14.31

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.5	23.2	13.5	11.2	22.7	17.6	13.7	26.5	26.6	45.9	23.4	44.0	6.3	10	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	89.5	69.0	85.9	67.9	82.7	66.7	70.9	84.9	69.3	82.5	67.9	79.8	8.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	99.9	75.8	64.9	94.6	73.8	63.6	90.4	72.7	35.1	85.2	33.8	82.6	32.6	79.8	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	18.5	16.3	13.5	94.4	5.5	3.8	9.6	97.1	6.4	99.4	3.3	101.5	-0.7	104.3
			12.9	73.9	5.4	1.5	9.0	75.0	5.8	75.8	2.8	76.6	-1.2	77.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	36.6	38.7	45.3	50.9	57.8	65.0	68.7	67.8	60.9	53.3	43.4	37.7
	DBStd	13.07	7.28	6.80	6.38	6.13	6.05	6.58	6.09	6.17	5.65	6.27	6.58	7.36
	HDD50	1612	417	318	170	63	8	0	0	0	1	40	213	382
	HDD65	5044	881	736	610	424	234	82	32	40	147	364	648	846
	CDD50	2434	2	2	25	89	249	450	580	551	328	141	15	2
	CDD65	390	0	0	0	0	11	81	147	125	25	1	0	0
	CDH74	4016	0	0	0	19	148	863	1503	1236	236	11	0	0
	CDH80	1346	0	0	0	0	16	270	551	465	44	0	0	0
Wind	WSAvg	7.4	7.8	8.4	8.5	8.0	7.1	7.0	7.1	6.5	7.0	6.6	7.0	7.6
Precipitation	PrecAvg	29.5	2.3	2.0	2.0	2.1	3.1	2.6	2.4	2.6	2.5	2.6	2.8	2.4
	PrecMax	42.5	5.0	4.6	6.5	5.9	7.7	6.9	5.4	5.5	10.4	7.0	10.2	6.7
	PrecMin	18.7	0.6	0.2	0.2	0.1	0.2	0.0	0.2	0.4	0.4	0.2	0.2	0.0
	PrecStd	5.4	1.1	1.1	1.3	1.5	1.5	1.5	1.2	1.3	1.9	1.5	1.7	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	59.3	68.4	76.7	82.3	92.3	94.4	96.6	84.7	75.4	63.4	56.4
		MCWB	51.6	49.6	54.0	60.9	66.7	69.8	69.1	69.4	66.3	62.7	56.3	51.4
	2%	DB	52.1	55.1	64.6	71.8	78.0	86.5	89.6	88.9	80.5	70.6	59.0	53.0
		MCWB	48.8	48.3	52.3	57.4	63.7	68.5	68.7	68.7	65.0	61.6	54.1	50.1
	5%	DB	49.7	52.0	60.5	67.8	74.7	82.7	86.0	85.1	76.2	66.8	55.9	50.7
		MCWB	47.0	46.9	50.9	55.2	61.9	67.2	67.8	67.6	63.5	59.8	52.8	48.4
	10%	DB	47.1	49.2	56.6	63.6	71.0	79.1	82.5	81.0	72.3	63.4	53.2	48.3
		MCWB	44.9	45.4	48.9	53.3	59.9	65.3	66.3	66.2	61.6	58.0	50.5	46.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.5	51.1	56.1	62.4	68.6	72.8	72.3	72.5	68.9	65.1	57.5	52.6
		MCDB	54.5	56.3	65.2	74.7	79.5	86.5	86.9	86.9	80.0	71.5	61.1	54.7
	2%	WB	49.5	49.3	53.6	58.7	65.7	70.5	70.5	70.4	66.6	62.7	55.0	50.6
		MCDB	51.5	53.8	61.7	69.4	75.9	83.2	85.4	84.5	77.2	68.6	57.9	52.6
	5%	WB	47.1	47.5	51.7	56.4	63.1	68.4	69.0	68.9	64.7	60.6	53.1	48.7
		MCDB	49.2	51.3	58.8	65.7	71.9	80.0	82.9	81.7	74.2	65.7	55.8	50.6
	10%	WB	45.0	45.6	49.8	54.1	60.9	66.5	67.4	67.3	62.7	58.6	50.7	46.5
		MCDB	46.9	48.9	55.8	61.9	68.6	77.0	79.7	78.5	70.2	62.7	52.8	47.9
Mean Daily Temperature Range	5% DB	MDBR	10.0	13.4	17.4	19.0	19.3	20.7	21.1	20.7	18.7	16.1	11.6	9.8
		MCDBR	12.3	18.9	24.7	26.8	25.7	26.4	27.0	27.6	25.0	21.5	15.5	12.4
		MCWBR	9.8	12.9	14.6	14.6	13.5	11.8	10.8	11.1	12.0	13.1	11.4	9.9
	5% WB	MCDBR	11.7	16.6	21.9	24.2	23.3	24.8	24.5	24.6	22.2	19.7	14.3	11.8
		MCWBR	9.8	12.0	13.6	13.9	13.3	11.9	10.5	11.2	11.5	12.8	11.0	9.7
Clear-Sky Solar Irradiance	taub	0.311	0.331	0.358	0.391	0.398	0.406	0.402	0.396	0.373	0.359	0.328	0.308	
	taud	2.460	2.409	2.347	2.259	2.287	2.297	2.306	2.339	2.384	2.418	2.458	2.456	
	Ebn at Noon	246	264	273	273	275	272	272	269	265	249	237	233	
	Edh at Noon	21	27	33	40	40	40	39	36	32	27	21	19	
All-Sky Solar Radiation	RadAvg	331	592	995	1400	1637	1904	1818	1574	1217	745	392	270	
	RadStd	43	96	134	193	177	178	156	137	100	58	38	46	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (47 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page