

ILE D'YEU, France

WMO: 073000

Lat: 46.6936N

Lon: 2.3303W

Elev: 105

StdP: 14.64

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.1	(c) 32.7	(d) 21.4	(e) 16.1	(f) 32.5	(g) 25.4	(h) 19.5	(i) 35.4	(j) 40.1	(k) 52.0	(l) 35.3	(m) 51.8	(n) 12.5	(o) 40	(p) 0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.1	(c) 81.6	(d) 67.4	(e) 78.0	(f) 66.1	(g) 75.0	(h) 65.2	(i) 69.7	(j) 77.7	(k) 68.1	(l) 74.9	(m) 66.7	(n) 72.5	(o) 9.0	(p) 60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.2	100.3	72.2	65.7	95.2	70.5	64.5	91.3	69.5	33.7	77.7	32.4	75.2	31.3	72.5	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 31.1	(b) 26.6	(c) 23.2	(e) 26.6	(f) 88.4	(g) 4.2	(h) 3.6	(i) 23.6	(j) 91.0	(k) 21.1	(l) 93.1	(m) 18.7	(n) 95.1	(o) 15.6	(p) 97.7		
(a) 31.1	(b) 26.6	(c) 23.2	(e) 24.6	(f) 72.7	(g) 4.2	(h) 2.5	(i) 21.6	(j) 74.5	(k) 19.1	(l) 76.0	(m) 16.7	(n) 77.4	(o) 13.7	(p) 79.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.8	45.9	46.1	49.3	52.7	58.0	63.4	66.6	66.6	63.2	58.4	51.9	47.4
	DBStd	8.96	5.99	5.07	4.10	4.28	4.51	4.52	4.33	3.85	3.94	4.47	5.33	6.41
	HDD50	513	145	119	60	19	1	0	0	0	0	4	41	124
	HDD65	3562	592	529	488	369	225	83	30	23	80	205	392	546
	CDD50	2645	18	10	37	99	248	403	514	514	396	265	99	42
	CDD65	220	0	0	0	0	7	35	79	72	26	1	0	0
	CDH74	879	0	0	0	0	33	174	339	259	73	1	0	0
	CDH80	183	0	0	0	0	3	36	71	61	12	0	0	0
(14) Wind	WSAvg	12.1	13.9	13.3	12.4	12.1	11.3	10.8	10.6	10.5	10.8	11.9	13.7	14.2
(15) Precipitation	PrecAvg	30.4	3.4	2.6	2.1	2.2	2.0	1.5	1.5	1.7	2.4	3.7	3.9	3.4
	PrecMax	40.7	7.1	5.6	5.2	6.6	4.3	3.7	3.0	4.0	7.0	7.4	11.0	5.9
	PrecMin	19.8	0.4	0.5	0.2	0.4	0.5	0.1	0.3	0.2	0.0	0.8	1.0	0.6
	PrecStd	4.6	1.8	1.4	1.3	1.3	0.9	0.9	0.7	1.2	1.7	1.5	2.2	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.2	56.6	65.4	70.4	78.0	85.0	86.8	86.5	81.0	71.1	63.6	59.0
		MCWB	53.7	51.9	54.4	58.9	64.3	68.9	68.5	70.2	66.6	63.6	59.9	55.8
	2%	DB	55.2	54.4	59.6	65.9	72.9	78.7	81.4	80.1	75.5	67.7	61.7	57.4
		MCWB	53.0	51.2	52.4	56.7	62.1	66.4	67.2	67.6	64.7	62.6	58.6	55.1
	5%	DB	54.1	53.2	56.6	62.5	68.3	74.7	77.9	76.3	72.5	65.9	60.3	56.3
		MCWB	52.0	50.6	51.5	55.2	60.1	64.5	66.1	66.5	63.9	61.7	57.7	54.2
	10%	DB	53.1	52.2	54.6	59.4	65.3	71.2	74.1	73.2	69.9	64.3	59.1	55.3
		MCWB	51.0	50.1	50.7	53.8	58.9	63.2	65.4	65.6	63.0	60.7	56.7	53.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.9	53.4	55.6	60.4	66.4	70.8	71.0	73.2	69.2	65.4	61.2	57.1
		MCDB	55.4	54.9	62.4	67.6	75.5	80.4	80.8	80.6	76.4	68.4	62.1	57.9
	2%	WB	53.7	52.2	53.8	57.9	63.1	68.1	68.9	70.0	67.0	63.9	59.5	56.0
		MCDB	54.6	53.4	57.4	63.4	69.8	76.4	77.3	76.8	72.1	66.4	60.7	56.9
	5%	WB	52.5	51.5	52.7	56.1	61.2	65.7	67.5	68.2	65.6	62.7	58.4	54.8
		MCDB	53.7	52.6	55.4	60.8	67.0	72.1	74.9	73.7	69.9	64.9	59.9	55.9
	10%	WB	51.4	50.7	51.7	54.5	59.6	64.0	66.3	66.7	64.2	61.5	57.0	53.7
		MCDB	52.7	52.0	53.7	58.6	64.3	69.7	72.7	71.3	68.3	63.6	58.9	55.1
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	8.3	9.9	11.2	11.1	11.7	12.1	12.1	11.9	9.1	7.6	7.4
		MCDBR	6.2	8.4	12.4	15.1	16.6	17.9	18.4	17.2	15.8	10.3	7.5	6.1
	5% WB	MCWBR	5.5	6.7	7.6	8.3	8.7	8.5	7.7	7.7	7.7	6.8	6.3	5.7
		MCWBR	5.7	7.0	10.1	12.9	13.9	15.4	14.8	13.6	12.7	8.6	6.5	5.6
(40) Clear-Sky Solar Irradiance	taub	taub	0.335	0.348	0.375	0.391	0.395	0.400	0.394	0.384	0.368	0.368	0.343	0.329
		taud	2.450	2.424	2.364	2.331	2.371	2.386	2.405	2.445	2.470	2.460	2.455	2.430
	Ebn at Noon	Ebn at Noon	239	260	268	274	277	275	275	273	268	249	233	226
		Edh at Noon	22	27	33	37	37	37	36	33	30	26	22	20
(44) All-Sky Solar Radiation	RadAvg	RadAvg	364	666	1075	1592	1874	2041	1966	1740	1379	800	453	319
	RadStd	RadStd	32	67	112	141	130	162	82	121	87	63	43	36

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page