

ILE D'YEU, France

WMO: 073000

Lat: 46.6936N

Lon: 2.3303W

Elev: 32

StdP: 100.94

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	0.4	-5.9	2.3	0.3	-3.7	2.8	1.9	17.9	11.1	15.8	11.0	5.6	40	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	27.5	19.7	25.6	19.0	23.9	18.5	20.9	25.4	20.0	23.8	19.3	22.5	4.0	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.3	22.3	18.7	13.6	21.4	18.1	13.0	20.9	60.5	25.4	57.4	24.0	55.0	22.5	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.9	11.9	10.4	-3.0	31.3	2.4	2.0	-4.7	32.8	-6.1	34.0	-7.4	35.1	-9.1	36.5		
			-4.1	22.6	2.3	1.4	-5.8	23.6	-7.2	24.4	-8.5	25.2	-10.2	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	7.7	7.8	9.6	11.5	14.4	17.5	19.2	17.3	14.7	11.1	8.5	
	DBStd	4.98	3.33	2.82	2.28	2.38	2.51	2.51	2.41	2.14	2.19	2.48	3.56	
	HDD10.0	285	81	66	33	11	1	0	0	0	0	23	69	
	HDD18.3	1979	329	294	271	205	125	46	17	13	44	218	303	
	CDD10.0	1469	10	6	21	55	138	224	286	220	147	55	23	
	CDD18.3	122	0	0	0	0	4	19	44	40	14	0	0	
	CDH23.3	488	0	0	0	0	18	97	188	144	41	0	0	
	CDH26.7	102	0	0	0	0	2	20	39	34	7	0	0	
Wind	WSAvg	5.4	6.2	5.9	5.5	5.4	5.1	4.8	4.7	4.7	4.8	5.3	6.1	6.3
Precipitation	PrecAvg	772	87	65	53	56	52	38	37	43	62	93	98	86
	PrecMax	1034	181	141	131	168	110	95	77	102	178	188	280	149
	PrecMin	502	10	12	5	9	12	2	8	5	1	20	26	16
	PrecStd	118	45	36	33	34	24	22	17	30	44	39	57	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	13.7	18.6	21.3	25.5	29.4	30.4	30.3	27.2	21.7	17.6	15.0
		MCWB	12.1	11.1	12.4	14.9	17.9	20.5	20.3	21.2	19.2	17.5	15.5	13.2
	2%	DB	12.9	12.5	15.4	18.9	22.7	25.9	27.4	26.7	24.1	19.9	16.5	14.1
		MCWB	11.7	10.6	11.3	13.7	16.7	19.1	19.5	19.8	18.1	17.0	14.8	12.8
	5%	DB	12.3	11.8	13.7	16.9	20.2	23.7	25.5	24.6	22.5	18.8	15.7	13.5
		MCWB	11.1	10.3	10.8	12.9	15.6	18.1	19.0	19.1	17.7	16.5	14.3	12.3
	10%	DB	11.7	11.2	12.6	15.2	18.5	21.8	23.4	22.9	21.1	17.9	15.0	13.0
		MCWB	10.6	10.1	10.4	12.1	15.0	17.4	18.6	18.6	17.2	15.9	13.7	11.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	11.9	13.1	15.8	19.1	21.5	21.7	22.9	20.7	18.6	16.2	14.0
		MCDB	13.0	12.7	16.9	19.8	24.2	26.9	27.1	27.0	24.7	20.2	16.7	14.4
	2%	WB	12.0	11.2	12.1	14.4	17.3	20.0	20.5	21.1	19.5	17.7	15.3	13.3
		MCDB	12.6	11.9	14.1	17.5	21.0	24.7	25.2	24.9	22.3	19.1	16.0	13.8
	5%	WB	11.4	10.8	11.5	13.4	16.2	18.7	19.7	20.1	18.6	17.1	14.7	12.7
		MCDB	12.0	11.4	13.0	16.0	19.4	22.3	23.8	23.2	21.0	18.3	15.5	13.3
	10%	WB	10.8	10.4	10.9	12.5	15.3	17.8	19.1	19.3	17.9	16.4	13.9	12.0
		MCDB	11.5	11.1	12.1	14.8	18.0	20.9	22.6	21.8	20.1	17.6	15.0	12.8
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.6	5.5	6.2	6.2	6.5	6.7	6.7	6.6	5.1	4.2	4.1
		MCDBR	3.4	4.7	6.9	8.4	9.2	9.9	10.2	9.6	8.8	5.7	4.2	3.4
		MCWBR	3.1	3.7	4.2	4.6	4.8	4.7	4.3	4.3	4.3	3.8	3.5	3.2
	5% WB	MCDBR	3.2	3.9	5.6	7.2	7.7	8.5	8.2	7.6	7.0	4.8	3.6	3.1
		MCWBR	3.2	3.5	3.8	4.3	4.5	4.5	4.1	4.2	4.2	3.6	3.6	3.2
Clear-Sky Solar Irradiance	taub	0.335	0.348	0.375	0.391	0.395	0.400	0.394	0.384	0.368	0.368	0.343	0.329	
	taud	2.450	2.424	2.364	2.331	2.371	2.386	2.405	2.445	2.470	2.460	2.455	2.430	
	Ebn at Noon	752	819	846	865	872	866	867	862	846	785	733	711	
	Edh at Noon	69	86	105	118	117	116	113	104	93	82	68	63	
All-Sky Solar Radiation	RadAvg	1.15	2.10	3.39	5.02	5.91	6.43	6.20	5.49	4.35	2.52	1.43	1.00	
	RadStd	0.10	0.21	0.35	0.45	0.41	0.51	0.26	0.38	0.28	0.20	0.14	0.11	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page