

POINTE DE CHASSIRON, France

WMO: 073140

Lat: 46.0469N

Lon: 1.4117W

Elev: 22

StdP: 101.06

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.7	-5.4	2.4	0.2	-3.4	2.8	1.7	17.4	11.2	15.8	10.6	6.2	50	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.4	26.2	20.7	24.6	20.2	23.2	19.5	21.7	24.8	20.8	23.5	20.1	22.5	3.4	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.3	23.2	19.8	14.5	22.4	19.1	13.9	21.8	63.3	25.0	60.2	23.7	57.5	22.6	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
14.4	12.6	11.3	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-2.3	31.1	2.2	2.3	-3.9	32.7	-5.2	34.1	-6.5	35.3	-8.1	37.0
			-3.4	23.2	2.2	1.2	-5.0	24.1	-6.3	24.8	-7.6	25.5	-9.2	26.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	7.6	7.8	10.0	12.0	15.0	18.0	19.7	20.0	18.1	15.4	11.4	8.6
	DBStd	5.13	3.27	2.98	2.40	2.25	2.21	2.30	2.04	1.97	2.02	2.48	2.82	3.43
	HDD10.0	272	84	67	29	7	0	0	0	0	0	1	18	66
	HDD18.3	1856	333	294	258	189	107	32	8	4	27	93	208	302
	CDD10.0	1613	9	7	28	67	155	241	300	309	243	170	61	23
	CDD18.3	156	0	0	0	0	3	23	50	56	21	3	0	0
	CDH23.3	303	0	0	0	1	6	63	92	106	33	3	0	0
	CDH26.7	44	0	0	0	0	1	13	13	14	3	0	0	0
Wind	WSAvg	5.6	6.3	6.3	5.8	5.6	5.3	4.9	4.9	4.8	5.0	5.4	6.6	6.4
Precipitation	PrecAvg	701	70	55	47	58	46	35	40	44	55	80	93	78
	PrecMax	1017	160	118	155	221	81	74	114	117	192	161	249	141
	PrecMin	519	9	3	6	16	16	5	5	7	0	7	20	16
	PrecStd	130	38	30	34	41	17	18	21	31	45	40	48	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	14.2	18.1	20.4	23.9	28.4	28.5	28.5	26.5	23.1	18.2	15.1
		MCWB	11.9	10.9	13.5	15.6	18.4	21.0	21.5	21.9	20.3	18.3	15.7	13.3
	2%	DB	12.8	12.7	15.7	18.1	21.8	24.9	25.6	25.8	23.9	20.8	16.8	14.1
		MCWB	11.3	10.7	12.1	14.0	17.3	19.8	20.4	21.2	19.3	17.6	14.8	12.4
	5%	DB	12.2	11.9	14.1	16.6	19.8	22.9	23.9	24.2	22.4	19.6	15.9	13.5
		MCWB	10.8	10.4	11.4	13.4	16.3	18.7	20.0	20.6	18.6	17.2	14.2	12.0
	10%	DB	11.6	11.2	13.0	15.3	18.3	21.3	22.6	22.8	21.2	18.6	15.1	12.9
		MCWB	10.4	10.0	10.9	12.7	15.5	18.2	19.4	19.8	18.0	16.6	13.4	11.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.5	12.0	13.8	16.2	19.2	22.1	22.4	23.8	21.3	19.2	16.2	13.8
		MCDB	13.1	13.1	17.2	19.2	22.9	27.1	26.4	26.2	24.5	21.3	17.5	14.5
	2%	WB	11.7	11.2	12.7	14.8	17.7	20.5	21.2	22.0	20.1	18.3	15.4	12.9
		MCDB	12.4	12.1	14.7	17.2	20.7	23.9	24.2	24.7	22.7	20.0	16.5	13.6
	5%	WB	11.2	10.7	12.0	13.8	16.7	19.4	20.5	21.1	19.4	17.6	14.5	12.4
		MCDB	11.9	11.5	13.4	16.0	19.2	22.0	23.1	23.4	21.6	19.1	15.7	13.2
	10%	WB	10.6	10.3	11.3	13.0	15.8	18.5	19.7	20.2	18.6	16.9	13.7	11.8
		MCDB	11.4	11.2	12.7	14.9	18.0	20.9	22.1	22.4	20.7	18.4	15.0	12.8
Mean Daily Temperature Range	5% DB	MDBR	3.7	3.8	4.5	4.6	4.5	4.7	4.3	4.4	4.8	4.4	3.9	3.8
		MCDBR	3.4	4.3	6.5	7.0	7.4	7.9	7.1	7.1	7.0	5.9	4.4	3.6
		MCWBR	3.1	3.4	4.3	4.6	4.5	4.4	4.0	4.1	4.2	3.9	3.6	3.3
	5% WB	MCDBR	3.1	3.6	5.3	6.2	6.4	7.0	6.0	5.8	6.0	5.1	4.0	3.3
		MCWBR	3.1	3.3	3.8	4.2	4.2	4.1	3.7	3.8	4.0	3.8	3.7	3.2
Clear-Sky Solar Irradiance	taub	0.331	0.345	0.373	0.393	0.398	0.408	0.400	0.391	0.370	0.369	0.343	0.327	
	taud	2.470	2.428	2.358	2.310	2.351	2.352	2.375	2.416	2.451	2.456	2.460	2.452	
	Ebn at Noon	767	828	851	864	871	860	862	857	846	789	742	726	
	Edh at Noon	69	86	106	121	120	121	117	108	96	83	69	63	
All-Sky Solar Radiation	RadAvg	1.22	2.18	3.37	4.76	5.57	6.23	6.03	5.34	4.24	2.56	1.47	1.08	
	RadStd	0.12	0.22	0.38	0.45	0.43	0.47	0.29	0.37	0.28	0.22	0.16	0.13	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page