

GUERET HP, France

WMO: 073600

Lat: 46.161N

Lon: 1.869E

Elev: 1808

StdP: 13.76

Time Zone: 1.00 (EUC)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.7	22.6	12.5	11.1	26.2	16.9	13.8	28.8	32.4	44.4	30.5	44.2	4.7	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	86.3	67.4	82.5	66.2	79.1	65.0	69.6	81.9	67.9	79.6	66.3	77.1	5.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	100.7	75.5	63.9	95.0	73.4	62.3	89.8	71.2	34.7	81.9	33.2	79.6	31.9	77.4	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.5	21.6	19.0	DB	16.4	92.9	3.7	3.4	13.7	95.4	11.6	97.4	9.5	99.3	6.8	101.8	(4)
(5)			WB	15.5	73.0	3.5	1.6	13.0	74.2	10.9	75.1	9.0	76.0	6.4	77.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	38.5	39.8	45.8	50.1	56.8	62.8	65.8	66.1	59.7	54.5	44.4	38.9	(6)
(7)		DBStd	12.45	7.62	8.57	8.04	7.59	7.10	7.38	6.67	7.04	6.51	7.36	7.26	8.04	(7)
(8)		HDD50	1528	358	297	179	90	18	0	0	0	4	40	194	348	(8)
(9)		HDD65	5055	821	706	595	449	268	130	72	68	187	333	617	809	(9)
(10)		CDD50	2260	2	12	49	93	230	384	490	499	293	178	26	4	(10)
(11)		CDD65	312	0	0	0	2	15	63	97	102	27	6	0	0	(11)
(12)		CDH74	2256	0	0	1	15	93	450	701	833	147	16	0	0	(12)
(13)		CDH80	639	0	0	0	1	8	109	192	303	25	1	0	0	(13)
(14)	Wind	WSAvg	8.3	10.5	9.7	8.2	8.8	7.0	6.6	6.0	6.1	7.1	8.3	9.6	11.4	(14)
(15)	Precipitation	PrecAvg	41.2	3.3	3.1	2.9	3.6	3.9	3.1	3.1	3.2	3.7	3.9	4.0		(15)
(16)		PrecMax	49.6	8.6	7.2	8.7	9.1	6.1	6.9	8.0	7.2	7.8	6.9	8.6	8.2	(16)
(17)		PrecMin	29.4	0.9	0.6	0.3	0.8	1.2	1.0	0.9	0.9	1.3	1.5	1.3	1.1	(17)
(18)		PrecStd	5.3	1.8	1.8	2.2	2.2	1.4	1.5	1.5	1.5	1.8	1.5	1.7	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.3	65.1	71.3	75.7	80.9	87.9	90.4	96.7	83.5	75.9	65.0	57.0	(19)
(20)			MCWB	45.7	49.5	53.6	57.9	63.2	68.9	68.2	67.6	65.1	62.5	55.1	49.5	(20)
(21)		2%	DB	52.1	58.4	66.0	71.1	76.7	83.0	85.2	87.5	78.2	71.2	60.0	53.3	(21)
(22)			MCWB	46.5	46.7	51.6	55.5	61.3	66.9	67.8	67.1	63.7	60.1	52.4	48.1	(22)
(23)		5%	DB	50.1	53.9	61.5	66.9	72.8	79.2	81.4	82.3	74.0	67.5	56.7	50.9	(23)
(24)			MCWB	46.2	45.1	49.9	54.0	59.6	65.6	66.4	65.8	62.4	58.6	51.3	47.2	(24)
(25)		10%	DB	47.9	50.3	57.2	62.5	68.7	75.5	77.8	78.1	69.9	64.3	53.9	48.8	(25)
(26)			MCWB	44.5	44.4	47.8	52.0	57.9	63.6	64.9	64.9	60.5	57.2	50.1	46.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	51.0	54.9	59.7	66.4	71.2	71.5	71.6	68.9	63.9	56.4	51.7	(27)
(28)			MCD B	52.4	58.4	66.9	72.6	77.1	82.7	83.3	84.8	79.5	71.7	61.5	54.6	(28)
(29)		2%	WB	48.6	48.9	52.8	57.1	63.2	68.6	69.4	69.2	65.9	61.7	54.1	49.7	(29)
(30)			MCD B	50.4	54.8	62.8	68.7	72.9	79.9	81.7	82.0	74.1	68.2	58.1	51.8	(30)
(31)		5%	WB	46.8	47.1	50.9	54.7	60.7	66.5	67.6	67.3	63.3	60.0	52.3	48.1	(31)
(32)			MCD B	49.0	51.7	58.9	64.3	70.4	77.0	78.9	79.8	71.4	65.8	55.6	49.9	(32)
(33)		10%	WB	45.0	45.5	49.0	52.7	58.5	64.6	65.8	65.6	61.2	58.2	50.6	46.6	(33)
(34)			MCD B	47.1	49.3	55.8	61.0	67.2	73.8	76.2	76.6	69.0	63.5	53.5	48.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	10.6	13.5	15.0	15.0	15.8	15.9	15.7	14.6	12.0	8.9	7.7	(35)
(36)			MCDBR	10.6	16.6	19.7	20.6	20.2	20.2	20.8	21.4	19.7	16.1	12.6	9.7	(36)
(37)			MCWBR	7.3	9.3	10.5	10.5	10.9	10.6	9.7	9.6	10.1	9.1	7.8	6.9	(37)
(38)		5% WB	MCD BR	8.1	13.2	16.8	18.8	18.1	18.6	18.8	19.2	17.7	14.1	11.0	8.6	(38)
(39)			MCWBR	6.8	8.4	9.6	9.8	10.3	9.8	9.6	9.5	9.8	8.6	7.5	7.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.312	0.341	0.373	0.375	0.386	0.379	0.374	0.343	0.338	0.310	0.293	(40)	
(41)		taud	2.501	2.453	2.388	2.297	2.335	2.334	2.351	2.377	2.441	2.469	2.500	2.498	(41)	
(42)		Ebn at Noon	259	275	281	280	283	279	279	277	277	261	250	246	(42)	
(43)		Edh at Noon	21	26	32	39	39	39	38	36	30	26	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	375	647	1026	1406	1645	1900	1858	1636	1280	796	443	327	(44)	
(45)		RadStd	45	88	126	178	151	178	132	138	84	64	52	52	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page