

GUERET HP, France

WMO: 073600

Lat: 46.161N

Lon: 1.869E

Elev: 551

StdP: 94.88

Time Zone: 1.00 (EUC)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.9	-5.2	-10.8	1.6	-3.2	-8.4	2.0	-1.8	14.5	6.9	13.6	6.8	2.1	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	30.1	19.7	28.1	19.0	26.2	18.3	20.9	27.7	19.9	26.4	19.1	25.1	2.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	14.4	24.1	17.7	13.6	23.0	16.8	12.8	21.8	62.9	27.7	59.4	26.4	56.4	25.2	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.7	8.5	-8.7	33.8	2.0	1.9	-10.1	35.2	-11.3	36.3	-12.5	37.4	-14.0	38.8		
(5)			-9.2	22.8	1.9	0.9	-10.6	23.4	-11.7	23.9	-12.8	24.4	-14.2	25.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	3.6	4.3	7.7	10.1	13.8	17.1	18.8	18.9	15.4	12.5	6.9	3.8	(6)
(7)		DBStd	6.92	4.23	4.76	4.47	4.22	3.94	4.10	3.71	3.91	3.61	4.09	4.04	4.47	(7)
(8)		HDD10.0	849	199	165	99	50	10	0	0	0	2	22	108	193	(8)
(9)		HDD18.3	2808	456	392	331	249	149	72	40	38	104	185	343	449	(9)
(10)		CDD10.0	1256	1	7	27	52	128	213	272	277	163	99	14	2	(10)
(11)		CDD18.3	173	0	0	0	1	8	35	54	57	15	3	0	0	(11)
(12)		CDH23.3	1253	0	0	1	8	52	250	389	463	82	9	0	0	(12)
(13)		CDH26.7	355	0	0	0	1	4	61	107	168	14	1	0	0	(13)
(14)	Wind	WSAvg	3.7	4.7	4.4	3.6	3.9	3.1	2.9	2.7	2.7	3.2	3.7	4.3	5.1	(14)
(15)	Precipitation	PrecAvg	1046	85	80	74	92	100	79	79	78	81	95	100	102	(15)
(16)		PrecMax	1260	218	184	221	232	154	176	204	182	197	174	218	208	(16)
(17)		PrecMin	747	24	16	8	20	30	25	24	22	32	39	32	29	(17)
(18)		PrecStd	135	46	45	55	56	36	37	38	37	45	37	44	46	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	18.4	21.8	24.3	27.2	31.1	32.4	35.9	28.6	24.4	18.3	13.9	(19)
(20)			MCWB	7.6	9.7	12.0	14.4	17.3	20.5	20.1	19.8	18.4	17.0	12.8	9.7	(20)
(21)		2%	DB	11.2	14.7	18.9	21.7	24.8	28.4	29.6	30.8	25.7	21.8	15.6	11.8	(21)
(22)			MCWB	8.0	8.2	10.9	13.1	16.3	19.4	19.9	19.5	17.6	15.6	11.4	8.9	(22)
(23)		5%	DB	10.1	12.2	16.4	19.4	22.7	26.2	27.4	27.9	23.3	19.7	13.7	10.5	(23)
(24)			MCWB	7.9	7.3	9.9	12.2	15.3	18.7	19.1	18.8	16.9	14.8	10.7	8.4	(24)
(25)		10%	DB	8.8	10.2	14.0	16.9	20.4	24.2	25.4	25.6	21.1	17.9	12.2	9.3	(25)
(26)			MCWB	6.9	6.9	8.8	11.1	14.4	17.6	18.3	18.3	15.8	14.0	10.0	7.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	10.5	12.7	15.4	19.1	21.8	21.9	22.0	20.5	17.7	13.5	10.9	(27)
(28)			MCD B	11.3	14.7	19.4	22.6	25.0	28.2	28.5	29.3	26.4	22.0	16.4	12.5	(28)
(29)		2%	WB	9.2	9.4	11.5	13.9	17.3	20.3	20.8	20.7	18.8	16.5	12.3	9.8	(29)
(30)			MCD B	10.2	12.7	17.1	20.4	22.7	26.6	27.6	27.8	23.4	20.1	14.5	11.0	(30)
(31)		5%	WB	8.2	8.4	10.5	12.6	16.0	19.2	19.8	19.6	17.4	15.6	11.3	9.0	(31)
(32)			MCD B	9.4	10.9	14.9	18.0	21.3	25.0	26.0	26.6	21.9	18.8	13.1	10.0	(32)
(33)		10%	WB	7.2	7.5	9.4	11.5	14.7	18.1	18.8	18.7	16.2	14.6	10.3	8.1	(33)
(34)			MCD B	8.4	9.6	13.2	16.1	19.5	23.2	24.5	24.8	20.5	17.5	11.9	9.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	5.9	7.5	8.3	8.8	8.9	8.7	8.1	6.7	5.0	4.3	(35)	
(36)			MCD BR	5.9	9.2	10.9	11.5	11.2	11.6	11.9	11.0	8.9	7.0	5.4	(36)	
(37)			MCWBR	4.1	5.2	5.8	5.8	6.0	5.9	5.4	5.3	5.6	5.1	4.3	3.9	(37)
(38)		5% WB	MCD BR	4.5	7.3	9.3	10.4	10.1	10.4	10.5	10.7	9.8	7.9	6.1	4.8	(38)
(39)			MCWBR	3.8	4.7	5.3	5.4	5.7	5.5	5.4	5.3	5.4	4.8	4.1	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.295	0.312	0.341	0.373	0.375	0.386	0.379	0.374	0.343	0.338	0.310	0.293	(40)	
(41)		taud	2.501	2.453	2.388	2.297	2.335	2.334	2.351	2.377	2.441	2.469	2.500	2.498	(41)	
(42)		Ebn at Noon	817	867	886	883	891	879	881	873	873	824	787	776	(42)	
(43)		Edh at Noon	65	83	102	122	122	123	119	112	96	81	65	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.18	2.04	3.23	4.43	5.18	5.99	5.86	5.16	4.04	2.51	1.40	1.03	(44)	
(45)		RadStd	0.14	0.28	0.40	0.56	0.48	0.56	0.42	0.43	0.27	0.20	0.16	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page