

MACON-CHARNAY AP, France

WMO: 073850

Lat: 46.2967N

Lon: 4.7986E

Elev: 728

StdP: 14.31

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.7	25.0	15.2	12.2	24.6	19.3	14.9	28.0	22.8	42.1	20.0	38.2	5.6	320	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	90.5	69.2	86.8	68.3	83.5	67.2	71.2	85.4	69.7	83.0	68.3	80.5	7.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	100.3	76.6	65.2	95.6	75.2	63.9	91.3	73.8	35.4	85.9	34.1	83.2	32.9	80.7	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	15.9	13.5	16.7	95.2	5.4	3.9	12.8	98.0	9.6	100.3	6.6	102.5	2.7	105.3
			15.9	74.0	5.2	1.8	12.1	75.3	9.1	76.3	6.2	77.3	2.4	78.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.0	38.0	40.3	46.9	52.8	60.0	67.1	70.6	69.5	62.2	55.1	45.2	39.1	(6)
(7)		DBStd	13.19	7.23	6.87	6.44	6.23	6.12	6.30	5.80	5.74	5.52	6.58	6.82	7.42	(7)
(8)		HDD50	1375	374	276	135	41	3	0	0	0	0	29	174	343	(8)
(9)		HDD65	4545	837	692	560	366	179	50	15	19	118	311	594	804	(9)
(10)		CDD50	2822	2	3	40	125	312	513	637	604	367	186	29	4	(10)
(11)		CDD65	519	0	0	0	1	23	113	187	158	34	3	0	0	(11)
(12)		CDH74	4605	0	0	0	26	224	1001	1670	1386	279	19	0	0	(12)
(13)		CDH80	1557	0	0	0	1	36	324	617	530	49	0	0	0	(13)
(14)	Wind	WSAvg	5.9	5.8	6.5	6.9	6.8	6.2	6.0	5.7	5.2	5.3	5.1	5.6	5.7	(14)
(15)	Precipitation	PrecAvg	34.4	2.5	2.2	2.0	2.8	3.1	2.7	3.0	3.0	2.7	3.7	4.1	2.8	(15)
(16)		PrecMax	40.3	5.3	4.2	5.6	6.9	5.6	5.7	5.4	7.9	8.0	7.7	10.4	4.9	(16)
(17)		PrecMin	24.5	0.7	0.2	0.4	0.6	0.6	0.5	0.7	0.6	0.3	0.7	1.7	0.7	(17)
(18)		PrecStd	4.3	1.1	1.1	1.1	1.6	1.2	1.3	1.2	1.5	1.9	1.5	2.1	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.2	60.2	69.5	77.7	84.5	93.5	95.2	97.0	85.5	76.7	65.5	58.9	(19)
(20)			MCWB	51.2	50.2	54.7	60.6	65.1	69.6	68.9	69.8	66.4	63.0	56.9	52.2	(20)
(21)		2%	DB	53.2	56.3	65.4	72.7	79.6	87.5	90.4	90.0	80.8	72.5	61.4	54.6	(21)
(22)			MCWB	48.7	48.5	52.8	57.4	63.0	68.7	69.1	69.2	65.3	61.5	54.7	50.0	(22)
(23)		5%	DB	50.5	53.3	61.5	68.7	76.0	83.7	86.7	85.9	77.1	68.8	58.1	51.8	(23)
(24)			MCWB	47.0	47.2	51.5	55.5	61.7	67.2	68.4	68.3	64.1	60.3	53.3	48.5	(24)
(25)		10%	DB	48.1	50.3	57.9	64.9	72.4	80.0	83.1	81.8	73.3	65.2	55.0	49.3	(25)
(26)			MCWB	45.4	45.6	49.6	53.7	60.1	65.7	67.2	67.1	62.2	58.5	51.5	46.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.1	51.4	56.4	62.0	67.9	72.9	72.8	73.1	69.5	65.1	58.1	52.9	(27)
(28)			MCD B	55.8	57.7	65.9	75.0	80.2	87.6	88.0	88.0	80.2	72.5	63.4	56.9	(28)
(29)		2%	WB	49.1	49.5	53.9	59.0	65.2	70.4	71.0	70.9	67.0	63.0	55.8	50.7	(29)
(30)			MCD B	52.3	55.0	62.5	69.7	76.3	83.4	85.8	85.3	77.7	69.9	60.0	54.1	(30)
(31)		5%	WB	47.4	47.6	52.2	56.7	62.9	68.6	69.5	69.3	65.1	61.1	53.8	48.8	(31)
(32)			MCD B	50.2	52.4	60.0	66.4	72.8	80.7	83.4	82.1	74.3	67.0	57.5	51.4	(32)
(33)		10%	WB	45.4	45.9	50.4	54.6	61.1	66.8	68.0	67.9	63.3	59.2	51.8	46.9	(33)
(34)			MCD B	47.9	49.7	57.0	63.1	70.1	77.7	80.5	79.5	71.3	64.3	55.0	49.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.5	12.4	16.3	17.7	17.7	18.8	19.1	19.5	18.3	15.2	11.1	9.2	(35)
(36)			MCDBR	12.7	18.1	23.0	24.7	24.1	25.2	25.2	27.3	24.3	20.5	15.1	12.8	(36)
(37)			MCWBR	9.2	11.7	12.8	12.4	11.0	10.4	9.6	10.6	11.3	11.2	9.8	9.4	(37)
(38)		5% WB	MCD BR	12.1	16.1	20.4	22.1	21.3	22.5	22.3	23.2	21.1	18.5	13.7	11.6	(38)
(39)			MCWBR	9.0	10.9	11.9	11.5	10.7	10.0	9.2	10.0	10.4	10.6	9.3	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.331	0.359	0.394	0.399	0.404	0.401	0.395	0.374	0.361	0.329	0.308	(40)	
(41)		taud	2.464	2.408	2.346	2.250	2.288	2.309	2.315	2.341	2.380	2.415	2.460	2.468	(41)	
(42)		Ebn at Noon	250	267	274	273	275	274	273	270	266	252	240	238	(42)	
(43)		Edh at Noon	22	28	34	41	41	40	39	37	32	27	22	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	371	637	1047	1424	1663	1969	1899	1644	1263	784	423	306	(44)	
(45)		RadStd	45	97	136	194	168	171	163	129	98	69	42	49	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page