

LES SAUVAGES, France

WMO: 074770

Lat: 45.9353N

Lon: 4.3842E

Elev: 2362

StdP: 13.48

Time Zone: 1.00 (EUC)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.1	21.9	11.9	11.0	19.8	17.7	14.6	24.2	27.9	47.2	24.7	46.1	5.7	340	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	89.6	67.7	85.0	66.4	81.0	65.1	69.7	84.3	68.1	80.9	66.5	78.3	8.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.4	102.4	74.2	63.8	96.8	72.8	62.5	92.2	71.8	35.1	85.2	33.7	80.8	32.4	78.6	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.0	18.6	16.1	DB	16.8	96.7	5.3	4.4	12.9	99.8	9.8	102.4	6.8	104.9	2.9	108.1
			WB	15.0	73.1	5.7	1.9	10.8	74.5	7.5	75.6	4.3	76.7	0.1	78.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	39.0	37.4	45.1	49.6	55.1	63.3	67.4	66.3	60.1	53.5	44.2	40.1
	DBStd	12.59	7.06	8.67	6.19	6.92	7.08	6.75	6.87	6.70	6.34	7.58	8.23	7.78
	HDD50	1572	346	354	172	89	31	2	0	0	4	52	207	315
	HDD65	5128	806	773	617	462	315	108	54	64	172	360	625	772
	CDD50	2248	5	2	21	77	189	400	540	507	306	161	32	8
	CDD65	326	0	0	0	0	8	56	128	106	24	4	0	0
	CDH74	3183	0	0	0	11	88	637	1211	1010	204	22	0	0
	CDH80	1145	0	0	0	0	13	253	447	390	41	1	0	0
(14) Wind	WSAvg	6.7	7.5	7.6	7.5	7.2	7.3	6.2	6.0	5.3	5.6	6.0	6.9	7.0
(15) Precipitation	PrecAvg	32.9	2.1	1.9	1.7	2.6	3.3	3.1	3.1	3.0	3.0	3.4	3.6	2.2
	PrecMax	43.8	4.1	3.4	4.9	6.5	5.8	6.1	6.0	7.1	7.1	6.5	9.1	5.9
	PrecMin	25.0	0.5	0.4	0.3	0.4	0.8	1.0	1.0	0.9	0.9	0.6	0.9	0.6
	PrecStd	4.6	1.0	0.9	1.0	1.4	1.3	1.2	1.3	1.3	1.5	1.5	1.8	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.4	62.3	67.7	75.3	81.1	95.5	96.5	93.4	85.0	77.1	65.1	59.4
		MCWB	51.1	49.3	52.4	59.1	63.9	71.0	67.5	68.4	65.1	61.2	55.8	51.2
	2%	DB	54.5	56.2	64.1	69.6	76.0	86.5	88.9	89.0	79.4	71.9	61.3	56.7
		MCWB	48.6	47.4	51.8	55.8	62.0	66.5	67.8	67.8	63.7	60.3	53.8	50.1
	5%	DB	51.6	52.5	60.1	65.6	71.8	80.3	84.4	84.3	75.3	68.0	58.1	54.1
		MCWB	46.5	45.6	50.2	54.1	59.3	63.6	66.0	66.9	62.9	59.2	52.2	48.9
	10%	DB	49.0	48.6	56.4	61.2	68.0	75.5	80.7	79.2	71.3	64.7	55.4	51.2
		MCWB	44.8	43.8	48.4	51.9	57.5	62.8	65.5	65.4	61.3	57.5	50.9	46.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	50.9	54.5	61.0	66.6	72.1	71.4	72.3	68.1	63.6	57.2	52.9
		MCDB	57.7	58.7	64.7	72.3	76.9	90.6	88.4	86.8	76.3	72.1	62.4	57.3
	2%	WB	49.3	48.2	52.3	57.4	63.4	67.6	69.5	69.7	65.6	61.6	54.9	51.0
		MCDB	53.7	54.8	61.5	67.3	73.4	80.7	84.4	83.9	75.0	69.3	60.0	55.4
	5%	WB	46.9	46.2	50.7	54.7	60.7	65.6	68.1	68.0	64.0	59.9	53.1	49.1
		MCDB	51.1	51.3	59.0	64.3	69.5	77.8	81.2	80.8	72.8	66.9	57.3	53.2
	10%	WB	45.0	44.2	48.9	52.4	58.2	63.8	66.5	66.3	62.4	58.1	51.0	47.2
		MCDB	48.3	48.6	55.7	60.5	65.5	73.8	78.5	77.4	70.4	64.0	55.0	50.8
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	13.5	17.4	17.3	17.6	18.8	19.2	19.6	17.8	14.8	11.4	11.6
		MCDBR	14.2	21.8	25.3	24.3	25.5	29.2	26.2	28.2	24.5	19.7	15.8	14.4
		MCWBR	10.1	14.2	15.2	13.7	13.2	12.4	10.5	10.8	11.6	10.8	10.5	9.9
	5% WB	MCDBR	13.8	19.4	22.2	23.2	21.8	24.2	23.5	23.8	20.4	18.0	14.9	13.3
		MCWBR	10.1	13.2	13.9	13.5	12.0	11.3	10.4	10.4	10.5	10.4	10.3	9.5
(40) Clear-Sky Solar Irradiance	taub		0.286	0.303	0.328	0.360	0.365	0.370	0.367	0.362	0.342	0.330	0.302	0.283
	taud		2.511	2.467	2.420	2.332	2.364	2.378	2.381	2.405	2.440	2.480	2.516	2.516
	Ebn at Noon		264	279	286	285	286	284	283	281	278	265	255	252
	Edh at Noon		21	26	31	37	37	37	37	35	30	25	20	18
(44) All-Sky Solar Radiation	RadAvg		388	655	1064	1426	1666	1976	1926	1668	1278	798	439	324
	RadStd		47	95	133	187	162	164	163	128	98	75	48	53

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page