

LES SAUVAGES, France

WMO: 074770

Lat: 45.9353N

Lon: 4.3842E

Elev: 720

StdP: 92.97

Time Zone: 1.00 (EUC)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.7	-5.6	-11.1	1.6	-6.8	-8.0	2.1	-4.3	12.5	8.4	11.1	7.8	2.5	340	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	32.0	19.9	29.5	19.1	27.2	18.4	21.0	29.1	20.1	27.1	19.2	25.7	3.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	14.6	23.4	17.7	13.8	22.7	16.9	13.2	22.1	63.8	29.6	60.5	27.1	57.5	25.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.3	7.2	-8.4	35.9	3.0	2.4	-10.6	37.7	-12.3	39.1	-14.0	40.5	-16.2	42.3		
(5)			-9.5	22.8	3.2	1.1	-11.8	23.6	-13.6	24.2	-15.4	24.8	-17.7	25.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	3.9	3.0	7.3	9.8	12.8	17.4	19.7	19.1	15.6	12.0	6.8	4.5
	DBStd	7.00	3.92	4.82	3.44	3.84	3.93	3.75	3.82	3.72	3.52	4.21	4.57	4.32
	HDD10.0	873	192	197	96	49	17	1	0	0	2	29	115	175
	HDD18.3	2849	448	429	343	257	175	60	30	36	96	200	347	429
	CDD10.0	1249	3	1	12	43	105	222	300	282	170	89	18	4
	CDD18.3	181	0	0	0	0	4	31	71	59	13	2	0	0
	CDH23.3	1768	0	0	0	6	49	354	673	561	113	12	0	0
	CDH26.7	636	0	0	0	0	7	141	248	217	23	1	0	0
Wind	WSAvg	3.0	3.3	3.4	3.4	3.2	3.2	2.8	2.7	2.4	2.5	2.7	3.1	3.1
Precipitation	PrecAvg	835	54	48	44	65	84	78	78	76	77	86	91	55
	PrecMax	1113	105	87	125	166	148	156	153	181	181	166	231	151
	PrecMin	636	13	11	8	9	20	26	26	24	22	15	23	15
	PrecStd	117	25	22	26	36	32	31	33	34	38	37	45	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.7	16.8	19.8	24.1	27.3	35.3	35.9	34.1	29.4	25.0	18.4	15.2
		MCWB	10.6	9.6	11.3	15.1	17.7	21.7	19.7	20.2	18.4	16.2	13.2	10.7
	2%	DB	12.5	13.4	17.8	20.9	24.5	30.3	31.6	31.7	26.4	22.2	16.3	13.7
		MCWB	9.2	8.5	11.0	13.2	16.7	19.2	19.9	19.9	17.6	15.7	12.1	10.1
	5%	DB	10.9	11.4	15.6	18.7	22.1	26.8	29.1	29.0	24.1	20.0	14.5	12.3
		MCWB	8.1	7.6	10.1	12.3	15.2	17.5	18.9	19.4	17.2	15.1	11.2	9.4
	10%	DB	9.4	9.2	13.5	16.2	20.0	24.2	27.1	26.2	21.8	18.2	13.0	10.7
		MCWB	7.1	6.6	9.1	11.0	14.2	17.1	18.6	18.6	16.3	14.2	10.5	8.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	10.5	12.5	16.1	19.2	22.3	21.9	22.4	20.0	17.6	14.0	11.6
		MCDB	14.3	14.8	18.2	22.4	24.9	32.6	31.3	30.4	24.6	22.3	16.9	14.0
	2%	WB	9.6	9.0	11.3	14.1	17.4	19.8	20.8	21.0	18.7	16.5	12.7	10.5
		MCDB	12.0	12.6	16.4	19.6	23.0	27.1	29.1	28.9	23.9	20.7	15.5	13.0
	5%	WB	8.3	7.9	10.4	12.6	15.9	18.7	20.1	20.0	17.8	15.5	11.7	9.5
		MCDB	10.6	10.7	15.0	17.9	20.9	25.4	27.3	27.1	22.6	19.4	14.1	11.8
	10%	WB	7.2	6.8	9.4	11.3	14.6	17.6	19.2	19.0	16.9	14.5	10.6	8.4
		MCDB	9.1	9.2	13.2	15.8	18.6	23.2	25.8	25.2	21.3	17.8	12.8	10.4
Mean Daily Temperature Range	5% DB	MDBR	6.0	7.5	9.7	9.6	9.8	10.4	10.7	10.9	9.9	8.2	6.3	6.5
		MCDBR	7.9	12.1	14.1	13.5	14.2	16.2	14.5	15.7	13.6	10.9	8.8	8.0
		MCWBR	5.6	7.9	8.4	7.6	7.3	6.9	5.8	6.0	6.4	6.0	5.8	5.5
	5% WB	MCDBR	7.7	10.8	12.4	12.9	12.1	13.4	13.1	13.2	11.4	10.0	8.3	7.4
		MCWBR	5.6	7.3	7.7	7.5	6.7	6.3	5.8	5.8	5.8	5.8	5.7	5.3
Clear-Sky Solar Irradiance	taub	0.286	0.303	0.328	0.360	0.365	0.370	0.367	0.362	0.342	0.330	0.302	0.283	
	taud	2.511	2.467	2.420	2.332	2.364	2.378	2.381	2.405	2.440	2.480	2.516	2.516	
	Ebn at Noon	833	881	903	897	902	896	893	886	875	835	803	796	
	Edh at Noon	65	82	99	118	118	118	116	109	96	80	64	58	
All-Sky Solar Radiation	RadAvg	1.22	2.06	3.35	4.50	5.25	6.23	6.07	5.26	4.03	2.52	1.38	1.02	
	RadStd	0.15	0.30	0.42	0.59	0.51	0.52	0.51	0.41	0.31	0.23	0.15	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page