

LYON ST EXUPERY AP, France

WMO: 074810

Lat: 45.7264N

Lon: 5.0778E

Elev: 250

StdP: 98.36

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.8	-4.0	-9.2	1.8	-3.6	-7.0	2.1	-2.1	12.5	9.5	11.2	7.9	2.7	340	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	33.0	20.0	31.1	19.6	29.3	19.2	21.4	29.6	20.6	28.4	19.9	27.3	4.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	14.1	23.9	18.1	13.4	23.1	17.3	12.8	22.6	63.0	29.8	60.2	28.5	57.8	27.4	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	9.3	8.0	-8.0	35.5	2.4	2.0	-9.7	36.9	-11.0	38.1	-12.4	39.3	-14.1	40.8
			-8.4	22.7	2.4	0.8	-10.1	23.3	-11.5	23.8	-12.8	24.2	-14.5	24.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.7	3.8	4.9	8.7	12.0	16.1	20.0	22.0	21.7	17.4	13.7	7.8	4.4
	DBStd	7.55	4.26	4.18	3.76	3.63	3.63	3.82	3.47	3.58	3.45	3.93	4.26	4.38
	HDD10.0	717	194	147	70	21	2	0	0	0	0	13	92	178
	HDD18.3	2401	450	376	299	192	89	26	7	8	57	150	317	431
	CDD10.0	1720	3	3	29	80	190	298	373	362	224	127	25	5
	CDD18.3	364	0	0	0	2	19	74	122	112	30	5	0	0
	CDH23.3	3187	0	0	0	18	147	669	1125	1001	213	14	0	0
	CDH26.7	1127	0	0	0	1	24	226	428	403	45	0	0	0
Wind	WSAvg	3.3	3.3	3.5	3.6	3.6	3.4	3.3	3.1	2.9	3.0	3.2	3.3	3.3
Precipitation	PrecAvg	918	60	50	55	79	88	73	72	69	97	109	104	63
	PrecMax	1229	134	122	162	187	187	157	174	166	291	264	303	134
	PrecMin	698	18	5	8	12	18	26	27	23	22	20	35	7
	PrecStd	144	30	30	35	44	41	33	38	33	65	49	61	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	16.5	21.3	25.8	29.2	34.1	35.1	36.2	30.2	25.1	19.6	15.6
		MCWB	10.7	9.6	12.1	15.3	17.9	20.6	20.0	20.3	18.6	16.8	13.6	11.5
	2%	DB	12.7	14.4	18.9	22.8	26.9	31.3	32.9	33.1	28.0	23.1	17.3	13.8
		MCWB	9.4	9.3	11.1	13.7	16.5	19.8	20.1	19.9	18.3	16.3	12.8	10.5
	5%	DB	11.3	12.6	16.9	20.7	24.9	29.3	31.0	31.0	25.9	21.3	15.7	12.4
		MCWB	8.5	8.5	10.6	12.8	16.0	19.2	19.8	19.4	17.4	15.7	12.0	9.6
	10%	DB	9.9	11.1	15.0	18.6	22.9	27.3	29.0	28.8	23.9	19.6	14.0	10.9
		MCWB	7.6	7.7	9.9	11.9	15.3	18.5	19.2	19.2	16.9	15.1	11.2	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	10.8	13.2	16.0	19.2	22.5	22.2	22.1	20.6	18.1	14.6	12.0
		MCDB	13.8	14.2	18.8	23.9	26.4	30.1	30.5	30.9	27.0	22.6	17.9	14.5
	2%	WB	9.7	9.8	12.0	14.5	17.8	21.1	21.2	21.1	19.2	17.2	13.3	10.9
		MCDB	12.2	13.4	16.9	21.1	24.7	28.8	29.6	29.4	25.3	21.5	16.4	13.5
	5%	WB	8.8	8.9	11.1	13.4	16.8	20.0	20.5	20.4	18.4	16.3	12.3	9.9
		MCDB	11.0	12.2	15.8	19.3	22.8	27.4	28.5	28.2	24.0	20.1	15.2	12.0
	10%	WB	7.7	7.9	10.2	12.4	15.8	19.1	19.7	19.7	17.5	15.5	11.4	8.7
		MCDB	9.7	10.9	14.5	17.6	21.3	25.8	27.2	26.9	22.6	18.9	13.9	10.5
Mean Daily Temperature Range	5% DB	MDBR	5.4	6.9	8.8	9.3	9.4	10.0	10.4	10.4	9.5	7.9	6.2	5.3
		MCDBR	7.1	10.0	11.8	12.4	12.2	12.6	12.8	13.5	12.3	10.0	8.4	7.1
		MCWBR	4.7	6.0	6.0	5.8	5.2	4.8	4.4	4.4	4.8	4.7	5.1	4.7
	5% WB	MCDBR	6.7	8.9	10.4	11.2	10.7	11.7	11.5	11.7	10.4	8.8	7.6	6.5
		MCWBR	4.7	5.6	5.6	5.6	5.0	4.7	4.3	4.4	4.6	4.4	4.9	4.7
Clear-Sky Solar Irradiance	taub	0.309	0.329	0.359	0.395	0.401	0.402	0.399	0.392	0.376	0.361	0.329	0.306	
	taud	2.476	2.414	2.353	2.259	2.290	2.322	2.328	2.355	2.384	2.425	2.472	2.482	
	Ebn at Noon	801	848	867	863	868	866	863	856	839	797	766	762	
	Edh at Noon	68	87	106	128	128	125	122	115	102	86	68	61	
All-Sky Solar Radiation	RadAvg	1.25	2.10	3.40	4.52	5.28	6.29	6.16	5.32	4.06	2.54	1.41	1.05	
	RadStd	0.15	0.30	0.42	0.58	0.50	0.50	0.52	0.40	0.32	0.25	0.16	0.17	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page