

GRENOBLE SAINT GEOIRS AP, France

WMO: 074860

Lat: 45.3639N

Lon: 5.3133E

Elev: 1302

StdP: 14.02

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	22.9	13.9	11.7	20.8	18.0	14.3	25.1	23.7	37.1	21.1	37.9	6.3	0	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	89.7	68.4	86.3	67.7	83.3	66.8	70.4	84.8	69.0	83.0	67.7	80.8	8.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	98.8	76.4	64.1	94.0	74.8	62.8	89.8	73.4	35.0	85.0	33.8	83.2	32.7	81.1	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.7	18.0	15.5	DB	12.8	93.9	6.5	3.8	8.1	96.6	4.3	98.8	0.7	100.9	-4.1	103.6
			WB	12.1	73.2	6.4	1.8	7.5	74.5	3.7	75.6	0.1	76.6	-4.6	77.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	36.8	38.6	45.1	50.5	57.6	64.7	68.6	68.1	60.8	54.3	44.1	38.2	(6)
	DBStd	13.05	6.92	7.40	6.47	6.04	6.27	6.39	6.02	6.14	5.83	6.68	7.32	7.14	(7)
	HDD50	1595	410	321	175	67	10	0	0	0	2	37	203	370	(8)
	HDD65	5005	874	740	617	435	237	84	34	39	150	334	629	832	(9)
	CDD50	2455	1	1	23	81	247	442	578	560	326	169	25	2	(10)
	CDD65	390	0	0	0	0	9	75	147	133	25	1	0	0	(11)
	CDH74	4494	0	0	0	15	160	899	1678	1451	280	11	0	0	(12)
	CDH80	1482	0	0	0	0	16	265	597	554	50	0	0	0	(13)
(14) Wind	WSAvg	6.9	7.6	7.5	7.3	7.2	6.6	6.5	6.3	6.2	6.2	6.4	7.1	7.5	(14)
(15) Precipitation	PrecAvg	39.0	2.8	2.8	3.5	3.0	4.1	3.4	2.7	3.1	3.6	3.7	3.1	3.1	(15)
	PrecMax	50.5	4.4	5.9	6.7	7.3	10.1	7.5	6.7	6.2	9.2	10.6	6.9	8.7	(16)
	PrecMin	28.0	0.2	0.6	0.5	0.6	0.9	0.9	0.2	0.6	0.1	0.2	0.3	0.5	(17)
	PrecStd	5.9	1.1	1.3	1.7	1.6	2.0	1.6	1.6	1.3	2.6	2.5	1.7	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.8	61.1	68.4	76.3	82.1	91.3	93.2	96.1	84.7	75.5	66.2	58.1	(19)
		MCWB	50.1	49.2	53.9	59.6	64.6	70.0	68.6	68.4	65.9	62.4	54.5	50.7	(20)
	2%	DB	52.4	56.8	64.3	71.1	78.3	86.3	89.5	90.1	81.0	72.0	62.3	54.2	(21)
		MCWB	47.0	47.9	52.4	57.2	62.3	68.4	68.5	68.0	65.1	61.1	54.0	48.9	(22)
	5%	DB	49.6	53.2	60.7	67.4	74.9	82.9	86.3	86.2	77.2	68.6	58.6	51.5	(23)
		MCWB	45.5	46.3	50.7	55.1	61.2	66.9	67.7	67.4	63.1	59.8	52.6	47.4	(24)
	10%	DB	46.8	49.9	57.2	63.6	71.4	79.4	83.0	82.3	73.5	65.2	55.2	48.4	(25)
		MCWB	43.8	44.6	48.7	53.1	59.5	65.2	66.7	66.8	61.9	58.2	50.9	45.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.6	50.8	55.6	60.4	67.0	72.5	71.9	71.9	68.8	64.3	57.4	52.0	(27)
		MCDB	55.4	57.6	65.8	73.2	79.2	86.3	86.8	86.3	80.0	72.2	63.3	56.4	(28)
	2%	WB	47.9	48.9	53.1	58.0	64.0	69.8	70.2	70.0	66.3	62.4	54.8	49.5	(29)
		MCDB	51.6	55.2	61.6	69.4	75.6	83.4	85.3	84.6	77.1	69.5	59.8	53.3	(30)
	5%	WB	46.0	46.9	51.3	55.9	62.0	67.9	68.8	68.6	64.6	60.6	53.1	47.6	(31)
		MCDB	49.0	52.3	59.3	65.7	72.6	80.6	83.2	82.5	74.5	66.9	58.0	50.9	(32)
	10%	WB	43.9	44.9	49.5	53.8	60.2	66.1	67.5	67.2	63.0	58.8	51.1	45.5	(33)
		MCDB	46.6	49.4	56.0	62.2	69.6	77.8	80.9	80.1	71.5	64.4	55.1	48.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	14.5	18.5	20.1	20.4	22.2	23.3	22.5	20.1	17.3	13.7	12.2	(35)
		MCDBR	16.0	21.4	25.3	27.9	26.9	28.2	28.9	29.6	26.9	21.6	18.6	16.3	(36)
		MCWBR	11.4	14.0	15.0	15.7	13.7	12.9	11.5	11.4	12.7	11.8	11.8	11.7	(37)
	5% WB	MCDBR	14.7	19.7	22.6	25.1	24.2	26.5	25.9	25.5	23.3	19.6	17.3	14.6	(38)
		MCWBR	11.0	13.3	13.8	14.6	13.0	12.9	11.3	11.1	11.8	11.4	11.7	11.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.302	0.323	0.357	0.393	0.400	0.399	0.395	0.388	0.374	0.358	0.325	0.300	(40)
	taud		2.478	2.412	2.351	2.256	2.285	2.322	2.332	2.359	2.385	2.430	2.475	2.485	(41)
	Ebn at Noon		258	272	277	274	276	276	275	273	267	255	246	246	(42)
	Edh at Noon		22	28	34	41	41	40	39	36	33	27	22	20	(43)
(44) All-Sky Solar Radiation	RadAvg		421	694	1105	1451	1698	2024	2004	1729	1316	827	469	356	(44)
	RadStd		49	93	129	175	156	149	162	119	101	85	56	57	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page