

GRENOBLE SAINT GEOIRS AP, France

WMO: 074860

Lat: 45.3639N

Lon: 5.3133E

Elev: 397

StdP: 96.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.1	-5.1	-10.1	1.7	-6.2	-7.8	2.0	-3.9	10.6	2.8	9.4	3.3	2.8	0	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	32.1	20.2	30.2	19.8	28.5	19.3	21.3	29.3	20.6	28.3	19.8	27.1	3.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	14.1	24.7	17.8	13.4	23.8	17.1	12.8	23.0	63.6	29.5	60.9	28.5	58.2	27.3	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.0	6.9	-10.6	34.4	3.6	2.1	-13.3	35.9	-15.4	37.1	-17.4	38.3	-20.0	39.8		
(5)			-11.1	22.9	3.6	1.0	-13.6	23.6	-15.7	24.2	-17.7	24.8	-20.3	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	2.7	3.7	7.3	10.3	14.2	18.2	20.4	20.0	16.0	12.4	6.7	3.4	(6)
(7)		DBStd	7.25	3.84	4.11	3.59	3.36	3.48	3.55	3.34	3.41	3.24	3.71	4.07	3.96	(7)
(8)		HDD10.0	886	228	178	97	37	6	0	0	0	1	21	113	206	(8)
(9)		HDD18.3	2781	486	411	343	242	132	47	19	22	83	186	349	462	(9)
(10)		CDD10.0	1364	1	1	13	45	137	246	321	311	181	94	14	1	(10)
(11)		CDD18.3	217	0	0	0	0	5	42	82	74	14	1	0	0	(11)
(12)		CDH23.3	2497	0	0	0	8	89	499	932	806	156	6	0	0	(12)
(13)		CDH26.7	823	0	0	0	0	9	147	332	308	28	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.4	3.4	3.3	3.2	2.9	2.9	2.8	2.8	2.9	3.2	3.4	(14)	
(15)	Precipitation	PrecAvg	991	71	72	89	77	104	87	69	79	92	93	80	79	(15)
(16)		PrecMax	1283	113	150	170	185	256	190	171	157	233	268	176	222	(16)
(17)		PrecMin	712	5	16	12	16	22	22	6	16	2	4	8	12	(17)
(18)		PrecStd	149	29	34	43	41	52	40	41	34	65	64	44	52	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	16.2	20.2	24.6	27.9	33.0	34.0	35.6	29.3	24.2	19.0	14.5	(19)
(20)			MCWB	10.0	9.6	12.1	15.3	18.1	21.1	20.4	20.2	18.8	16.9	12.5	10.4	(20)
(21)		2%	DB	11.3	13.8	18.0	21.7	25.7	30.1	31.9	32.3	27.2	22.2	16.8	12.3	(21)
(22)			MCWB	8.3	8.8	11.3	14.0	16.9	20.2	20.3	20.0	18.4	16.1	12.2	9.4	(22)
(23)		5%	DB	9.8	11.8	15.9	19.7	23.9	28.3	30.2	30.1	25.1	20.3	14.8	10.8	(23)
(24)			MCWB	7.5	8.0	10.4	12.8	16.2	19.4	19.8	19.7	17.3	15.4	11.5	8.5	(24)
(25)		10%	DB	8.2	9.9	14.0	17.6	21.9	26.4	28.3	27.9	23.0	18.4	12.9	9.1	(25)
(26)			MCWB	6.5	7.0	9.3	11.7	15.3	18.4	19.3	19.3	16.6	14.6	10.5	7.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	10.5	13.1	15.8	19.5	22.5	22.1	22.2	20.5	18.0	14.1	11.1	(27)
(28)			MCDWB	13.0	14.2	18.8	22.9	26.2	30.1	30.5	30.2	26.7	22.3	17.4	13.6	(28)
(29)		2%	WB	8.9	9.4	11.7	14.4	17.8	21.0	21.2	21.1	19.0	16.9	12.7	9.7	(29)
(30)			MCDWB	10.9	12.9	16.4	20.8	24.2	28.5	29.6	29.2	25.1	20.8	15.4	11.8	(30)
(31)		5%	WB	7.8	8.3	10.7	13.3	16.7	19.9	20.5	20.3	18.1	15.9	11.7	8.7	(31)
(32)			MCDWB	9.5	11.3	15.2	18.7	22.5	27.0	28.5	28.1	23.6	19.4	14.4	10.5	(32)
(33)		10%	WB	6.6	7.2	9.7	12.1	15.7	18.9	19.7	19.6	17.2	14.9	10.6	7.5	(33)
(34)			MCDWB	8.1	9.7	13.3	16.8	20.9	25.4	27.2	26.7	21.9	18.0	12.8	9.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.7	8.1	10.3	11.1	11.3	12.3	12.9	12.5	11.1	9.6	7.6	6.8	(35)
(36)			MCDBR	8.9	11.9	14.0	15.5	14.9	15.6	16.0	16.5	14.9	12.0	10.3	9.0	(36)
(37)			MCWBR	6.3	7.8	8.3	8.7	7.6	7.2	6.4	6.3	7.0	6.6	6.6	6.5	(37)
(38)		5% WB	MCDWB	8.2	10.9	12.6	14.0	13.5	14.7	14.4	14.2	12.9	10.9	9.6	8.1	(38)
(39)			MCWBR	6.1	7.4	7.7	8.1	7.2	7.2	6.3	6.2	6.6	6.3	6.5	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.302	0.323	0.357	0.393	0.400	0.399	0.395	0.388	0.374	0.358	0.325	0.300	(40)	
(41)		taud	2.478	2.412	2.351	2.256	2.285	2.322	2.332	2.359	2.385	2.430	2.475	2.485	(41)	
(42)		Ebn at Noon	814	857	872	865	869	869	868	861	843	805	775	776	(42)	
(43)		Edh at Noon	68	88	107	128	129	125	122	114	103	86	69	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.33	2.19	3.48	4.57	5.35	6.38	6.32	5.45	4.15	2.61	1.48	1.12	(44)	
(45)		RadStd	0.15	0.29	0.41	0.55	0.49	0.47	0.51	0.38	0.32	0.27	0.18	0.18	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (45 neighbors)		(m)								
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page