

ANNECY MONT BLANC AP, France

WMO: 074900

Lat: 45.9298N

Lon: 6.1047E

Elev: 1521

StdP: 13.91

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	22.7	12.1	10.8	23.4	16.2	13.2	26.0	16.7	36.5	14.0	36.6	4.3	30	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	89.2	69.0	85.7	67.9	82.5	66.8	70.6	85.0	69.1	82.6	67.6	80.2	6.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	99.9	77.7	64.2	95.2	75.4	62.8	90.4	73.8	35.3	86.0	34.0	83.0	32.8	80.3	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.1	13.2	11.3	DB	15.0	94.1	5.0	3.4	11.4	96.5	8.4	98.5	5.6	100.5	1.9	103.0	
			WB	13.8	73.8	4.9	2.3	10.2	75.5	7.4	76.8	4.6	78.1	1.1	79.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	35.6	37.0	44.5	51.8	57.1	64.7	68.3	67.5	60.4	53.0	43.4	36.8
	DBStd	13.17	5.89	6.95	6.12	5.96	6.47	6.58	6.51	6.21	5.55	6.24	6.14	6.09
	HDD50	1720	447	363	187	50	10	0	0	0	1	44	209	409
	HDD65	5204	912	783	635	396	256	85	42	46	156	371	648	874
	CDD50	2366	0	0	18	105	231	441	567	542	314	137	11	0
	CDD65	374	0	0	0	0	12	76	144	123	19	0	0	0
	CDH74	4028	0	0	0	24	150	848	1578	1237	185	6	0	0
	CDH80	1271	0	0	0	1	21	247	560	414	28	0	0	0
(14) Wind	WSAvg	4.2	3.5	4.3	4.8	5.0	5.0	4.8	4.7	4.4	4.1	3.7	3.4	3.3
(15) Precipitation	PrecAvg	44.8	4.0	3.1	3.3	3.3	4.2	3.3	3.7	4.3	3.1	4.1	4.3	4.0
	PrecMax	57.1	7.9	7.4	8.9	7.9	7.2	6.5	9.7	7.8	7.6	8.9	11.3	9.2
	PrecMin	34.8	1.0	0.0	0.6	0.5	1.7	1.3	1.3	1.1	0.7	0.6	0.3	0.0
	PrecStd	7.1	1.9	2.1	2.0	2.1	1.9	1.7	2.2	1.8	1.9	2.4	3.0	2.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	60.0	68.3	77.2	82.5	90.9	93.5	92.7	83.9	74.7	64.3	55.8
		MCWB	46.6	47.8	52.2	58.6	66.3	72.9	69.6	69.7	65.4	60.9	53.7	48.6
	2%	DB	50.2	55.5	64.6	72.5	78.4	86.0	89.6	88.2	78.9	71.2	59.2	51.7
		MCWB	45.0	46.0	50.8	56.6	62.4	69.3	68.6	68.5	64.5	59.9	52.0	46.3
	5%	DB	46.7	51.5	60.7	69.3	74.1	82.5	85.9	84.6	75.3	67.3	55.7	48.4
		MCWB	43.5	44.5	49.4	54.9	60.1	67.1	67.4	67.8	62.7	58.8	50.7	44.9
	10%	DB	44.4	47.9	56.8	65.5	70.2	79.0	82.6	80.9	72.0	63.4	52.8	45.8
		MCWB	41.6	42.8	47.5	53.4	58.5	64.9	66.6	66.7	61.7	56.8	49.0	43.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	49.2	53.8	60.1	66.4	74.7	72.0	72.0	67.5	63.0	55.7	49.9
		MCDB	52.5	56.2	64.3	74.4	80.3	88.8	88.1	86.4	77.0	70.9	62.5	54.6
	2%	WB	45.9	47.3	51.8	57.6	63.9	70.2	70.3	70.1	65.7	61.1	53.3	47.5
		MCDB	48.8	53.9	62.5	70.1	75.5	83.8	85.1	84.3	76.1	68.2	57.9	50.3
	5%	WB	43.8	45.0	50.0	55.7	61.6	68.1	68.8	68.6	64.2	59.4	51.3	45.3
		MCDB	46.4	50.7	59.5	67.3	71.7	80.5	82.7	81.9	74.0	65.4	55.0	48.1
	10%	WB	41.6	42.6	48.0	53.7	59.4	66.1	67.4	67.2	62.5	57.7	49.3	42.9
		MCDB	43.8	47.3	55.6	64.1	68.1	77.2	80.5	79.3	70.5	62.9	52.5	45.1
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	15.0	18.2	20.2	20.1	22.1	23.2	22.3	19.8	17.5	13.8	12.8
		MCDBR	16.0	23.3	26.7	27.4	25.9	27.0	28.8	28.2	25.0	23.8	19.2	17.9
		MCWBR	11.4	15.3	15.2	14.3	12.8	12.9	11.5	11.9	12.2	13.8	13.0	12.8
	5% WB	MCDBR	14.5	21.2	24.3	25.5	23.4	25.5	25.4	25.1	22.3	20.6	17.8	15.9
		MCWBR	10.7	14.4	14.1	13.7	12.4	13.1	11.6	11.9	11.6	12.4	12.4	11.7
(40) Clear-Sky Solar Irradiance	taub		0.285	0.308	0.346	0.382	0.392	0.393	0.389	0.380	0.363	0.345	0.313	0.285
	taud		2.445	2.396	2.358	2.295	2.315	2.350	2.355	2.388	2.422	2.467	2.498	2.468
	Ebn at Noon		262	276	279	278	278	277	277	275	270	259	249	250
	Edh at Noon		22	28	33	39	40	38	38	35	31	26	21	19
(44) All-Sky Solar Radiation	RadAvg		447	719	1092	1409	1625	1934	1923	1670	1293	825	471	371
	RadStd		52	98	141	183	146	161	156	126	103	87	62	55

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)	N/A	N/A	N/A	N/A	+0.59	+0.41	N/A	N/A	N/A	N/A

Nomenclature: See separate page