

LEGE CAP FERRET, France

WMO: 075000

Lat: 44.6453N

Lon: 1.2488W

Elev: 33

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.3	32.1	20.5	15.4	33.1	24.3	18.5	35.1	42.2	52.2	38.2	52.0	8.5	40	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.0	87.6	69.9	83.2	68.6	79.8	68.1	72.5	82.5	70.8	79.9	69.5	77.5	8.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	107.6	76.8	67.8	102.4	74.9	66.6	97.9	73.8	36.1	82.7	34.7	80.0	33.5	77.9	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
34.3	29.2	24.9	27.1	97.3	2.8	3.7	25.1	100.0	23.4	102.2	21.9	104.3	19.9	107.0
			24.9	75.2	3.4	1.6	22.4	76.4	20.5	77.4	18.6	78.3	16.1	79.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.3	46.4	46.9	51.5	55.6	61.4	67.5	70.4	70.7	67.0	61.2	52.8	47.9
	DBStd	10.30	6.35	6.15	5.14	4.58	4.81	4.93	4.39	4.08	4.46	5.30	5.76	6.60
	HDD50	464	142	115	42	5	0	0	0	0	0	3	39	118
	HDD65	3008	576	507	418	285	132	25	4	2	26	135	367	531
	CDD50	3509	31	28	89	173	354	524	634	641	510	351	122	52
	CDD65	579	0	0	0	3	21	99	173	178	87	18	0	0
	CDH74	2834	0	0	1	29	143	532	884	822	385	38	0	0
	CDH80	766	0	0	0	5	36	183	247	210	83	2	0	0
Wind	WSAvg	11.1	12.1	12.0	12.0	11.4	11.0	10.4	10.5	9.5	9.6	10.0	12.3	12.4
Precipitation	PrecAvg	33.9	3.5	2.7	2.2	2.7	2.3	2.4	1.7	2.2	2.9	3.2	4.7	3.5
	PrecMax	42.4	8.1	5.6	5.6	7.1	5.0	7.2	3.4	6.9	6.4	5.8	10.5	7.4
	PrecMin	23.7	0.4	0.3	0.5	0.6	0.6	0.3	0.2	0.4	0.2	0.6	1.5	0.4
	PrecStd	4.8	2.2	1.5	1.4	1.7	1.2	1.5	0.7	1.5	1.6	1.6	2.4	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.3	64.0	71.1	78.6	84.6	93.1	93.8	92.4	87.1	78.1	68.9	61.3
		MCWB	54.7	54.1	56.2	60.9	66.1	73.0	71.0	71.4	68.8	65.9	60.4	55.2
	2%	DB	57.4	59.1	66.1	70.6	77.8	85.3	86.2	86.1	82.0	74.2	64.6	58.8
		MCWB	53.8	52.2	55.0	57.6	63.5	68.1	71.0	69.8	67.5	64.6	58.8	54.5
	5%	DB	56.0	56.5	62.4	66.4	72.8	79.5	81.7	80.9	78.2	70.9	62.3	57.5
		MCWB	53.1	51.6	53.4	57.0	61.9	66.9	69.8	69.4	67.1	63.5	57.8	54.0
	10%	DB	54.7	54.7	59.0	63.3	69.5	75.5	78.4	78.1	75.1	68.5	60.4	56.3
		MCWB	52.0	51.0	52.5	55.5	61.0	66.0	68.4	68.4	66.1	62.3	56.7	53.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.0	55.3	58.2	61.8	67.9	73.4	74.6	74.9	72.0	67.8	62.9	56.7
		MCDB	57.5	59.5	66.8	72.8	80.2	88.3	84.8	83.7	81.6	74.3	65.5	58.6
	2%	WB	54.7	53.8	56.2	59.7	65.2	70.1	72.4	72.4	70.0	65.9	60.2	55.7
		MCDB	56.4	56.8	62.7	67.8	74.5	80.3	82.2	81.5	78.0	71.3	63.0	57.7
	5%	WB	53.7	52.8	54.9	57.9	63.5	68.5	70.7	70.7	68.4	64.6	58.6	54.7
		MCDB	55.5	55.5	60.0	64.7	70.9	76.6	79.7	79.1	75.5	69.5	61.7	56.9
	10%	WB	52.4	51.7	53.6	56.4	61.9	66.9	69.2	69.2	66.9	63.2	56.9	53.5
		MCDB	54.4	54.3	57.9	62.1	68.2	74.0	77.4	76.6	73.4	67.7	60.2	56.0
Mean Daily Temperature Range	5% DB	MDBR	9.3	11.6	12.8	12.9	12.9	13.6	13.4	14.0	14.5	12.5	10.1	9.6
		MCDBR	9.0	14.2	19.1	19.2	20.0	22.3	20.0	19.6	19.6	15.7	11.8	9.1
		MCWBR	7.1	9.2	10.2	9.6	9.3	9.5	8.5	9.0	9.5	8.7	7.8	7.1
	5% WB	MCDBR	7.7	12.0	14.6	16.0	16.6	18.0	16.8	16.3	16.1	13.3	10.3	8.2
		MCWBR	6.8	8.7	8.7	8.8	8.3	8.5	8.0	8.3	8.9	8.1	7.8	7.1
Clear-Sky Solar Irradiance	taub	0.330	0.343	0.372	0.390	0.395	0.408	0.399	0.397	0.374	0.369	0.344	0.327	
	taud	2.504	2.457	2.387	2.352	2.386	2.381	2.403	2.423	2.468	2.477	2.485	2.494	
	Ebn at Noon	250	267	273	277	278	274	275	272	270	254	241	238	
	Edh at Noon	22	27	33	37	37	37	36	34	30	27	22	20	
All-Sky Solar Radiation	RadAvg	422	731	1129	1533	1812	2005	1964	1741	1387	872	507	387	
	RadStd	39	83	137	145	138	131	120	94	83	71	64	48	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page