

LEGE CAP FERRET, France

WMO: 075000

Lat: 44.6453N

Lon: 1.2488W

Elev: 10

StdP: 101.20

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.5	0.0	-6.4	2.2	0.6	-4.3	2.6	1.7	18.9	11.2	17.1	11.1	3.8	40	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	30.9	21.0	28.4	20.4	26.6	20.1	22.5	28.0	21.6	26.6	20.8	25.3	4.0	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	15.4	24.9	19.9	14.6	23.9	19.2	14.0	23.2	66.0	28.2	62.7	26.7	60.1	25.5	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	13.1	11.1	-2.7	36.3	1.5	2.1	-3.8	37.8	-4.8	39.0	-5.6	40.2	-6.7	41.7
			-4.0	24.0	1.9	0.9	-5.3	24.7	-6.4	25.2	-7.4	25.7	-8.8	26.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.6	8.0	8.3	10.8	13.1	16.3	19.7	21.4	21.5	19.5	16.2	11.5	8.8
	DBStd	5.72	3.53	3.42	2.86	2.54	2.67	2.74	2.44	2.27	2.48	2.95	3.20	3.66
	HDD10.0	258	79	64	23	3	0	0	0	0	0	2	22	66
	HDD18.3	1671	320	282	232	158	73	14	2	1	14	75	204	295
	CDD10.0	1949	17	16	49	96	197	291	352	356	283	195	68	29
	CDD18.3	322	0	0	0	2	12	55	96	99	48	10	0	0
	CDH23.3	1574	0	0	1	16	79	296	491	457	214	21	0	0
	CDH26.7	426	0	0	0	3	20	102	137	117	46	1	0	0
Wind	WSAvg	5.0	5.4	5.4	5.3	5.1	4.9	4.6	4.7	4.3	4.3	4.5	5.5	5.5
Precipitation	PrecAvg	862	90	69	57	69	59	60	42	55	73	81	119	89
	PrecMax	1078	207	141	141	180	127	182	87	174	163	148	266	188
	PrecMin	601	11	7	13	16	16	8	4	11	5	16	37	9
	PrecStd	121	55	37	36	44	30	39	19	37	40	41	61	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	17.8	21.7	25.9	29.2	33.9	34.3	33.5	30.6	25.6	20.5	16.3
		MCWB	12.6	12.3	13.4	16.0	19.0	22.8	21.6	21.9	20.4	18.8	15.8	12.9
	2%	DB	14.1	15.1	18.9	21.5	25.4	29.6	30.1	30.1	27.8	23.4	18.1	14.9
		MCWB	12.1	11.2	12.8	14.2	17.5	20.1	21.7	21.0	19.7	18.1	14.9	12.5
	5%	DB	13.3	13.6	16.9	19.1	22.7	26.4	27.6	27.1	25.7	21.6	16.8	14.2
		MCWB	11.7	10.9	11.9	13.9	16.6	19.4	21.0	20.8	19.5	17.5	14.3	12.2
	10%	DB	12.6	12.6	15.0	17.4	20.8	24.1	25.8	25.6	24.0	20.3	15.8	13.5
		MCWB	11.1	10.5	11.4	13.0	16.1	18.9	20.2	20.2	18.9	16.8	13.7	11.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.3	13.0	14.5	16.5	19.9	23.0	23.7	23.8	22.2	19.9	17.2	13.7
		MCDB	14.2	15.3	19.3	22.6	26.8	31.3	29.3	28.7	27.6	23.5	18.6	14.8
	2%	WB	12.6	12.1	13.5	15.4	18.5	21.2	22.4	22.4	21.1	18.8	15.6	13.2
		MCDB	13.5	13.8	17.1	19.9	23.6	26.9	27.9	27.5	25.5	21.9	17.2	14.3
	5%	WB	12.1	11.5	12.7	14.4	17.5	20.3	21.5	21.5	20.2	18.1	14.8	12.6
		MCDB	13.0	13.1	15.5	18.2	21.6	24.8	26.5	26.2	24.2	20.8	16.5	13.8
	10%	WB	11.3	10.9	12.0	13.6	16.6	19.4	20.7	20.7	19.4	17.3	13.8	12.0
		MCDB	12.5	12.4	14.4	16.7	20.1	23.3	25.2	24.8	23.0	19.9	15.7	13.3
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.4	7.1	7.1	7.2	7.6	7.4	7.8	8.1	6.9	5.6	5.3
		MCDBR	5.0	7.9	10.6	10.7	11.1	12.4	11.1	10.9	10.9	8.7	6.6	5.0
		MCWBR	4.0	5.1	5.6	5.3	5.2	5.3	4.7	5.0	5.3	4.8	4.4	4.0
	5% WB	MCDBR	4.3	6.7	8.1	8.9	9.2	10.0	9.3	9.1	8.9	7.4	5.7	4.6
MCWBR		3.8	4.8	4.8	4.9	4.6	4.7	4.4	4.6	4.9	4.5	4.3	4.0	
Clear-Sky Solar Irradiance	taub	0.330	0.343	0.372	0.390	0.395	0.408	0.399	0.397	0.374	0.369	0.344	0.327	
	taud	2.504	2.457	2.387	2.352	2.386	2.381	2.403	2.423	2.468	2.477	2.485	2.494	
	Ebn at Noon	789	843	860	873	876	863	866	856	850	801	760	751	
	Edh at Noon	69	86	104	117	117	118	114	108	96	84	70	64	
All-Sky Solar Radiation	RadAvg	1.33	2.30	3.56	4.83	5.71	6.32	6.19	5.49	4.37	2.75	1.60	1.22	
	RadStd	0.12	0.26	0.43	0.46	0.43	0.41	0.38	0.30	0.26	0.23	0.20	0.15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page