

CAZAUX AB, France

WMO: 075020

Lat: 44.5347N

Lon: 1.1319W

Elev: 26

StdP: 101.02

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.5	-2.0	-6.9	2.1	-0.3	-4.9	2.5	0.6	11.2	10.2	10.0	10.6	1.7	0	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	32.5	21.1	30.2	20.3	28.3	19.5	22.6	29.2	21.6	27.7	20.7	26.0	3.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.7	15.4	24.7	19.8	14.5	23.6	19.0	13.8	23.0	66.5	29.1	62.9	27.8	59.8	26.0	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	7.9	6.9	-6.3	36.4	1.6	2.0	-7.4	37.9	-8.4	39.0	-9.3	40.1	-10.4	41.5		
(5)			-6.7	24.1	1.5	1.0	-7.8	24.8	-8.7	25.4	-9.5	25.9	-10.7	26.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.5	6.9	7.4	10.0	12.1	15.4	18.6	20.6	20.5	17.8	14.8	10.1	7.6	(6)
(7)		DBStd	5.92	3.73	3.46	2.99	2.98	3.15	3.23	2.96	2.97	2.99	3.48	3.47	3.84	(7)
(8)		HDD10.0	378	106	82	38	12	1	0	0	0	0	6	42	92	(8)
(9)		HDD18.3	2003	354	305	259	188	101	34	11	44	115	248	333		(9)
(10)		CDD10.0	1666	10	11	37	75	169	258	328	327	235	156	43	17	(10)
(11)		CDD18.3	249	0	0	0	1	11	43	80	79	29	7	0	0	(11)
(12)		CDH23.3	2354	0	1	3	37	147	443	705	664	303	49	1	0	(12)
(13)		CDH26.7	819	0	0	0	7	37	169	264	245	92	6	0	0	(13)
(14)	Wind	WSAvg	3.1	3.1	3.2	3.5	3.4	3.3	3.2	3.1	2.9	2.7	2.7	3.0	3.0	(14)
(15)	Precipitation	PrecAvg	862	90	69	57	69	59	60	42	55	73	81	119	89	(15)
(16)		PrecMax	1078	207	141	141	180	127	182	87	174	163	148	266	188	(16)
(17)		PrecMin	601	11	7	13	16	16	8	4	11	5	16	37	9	(17)
(18)		PrecStd	121	55	37	36	44	30	39	19	37	40	41	61	45	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	19.8	23.2	27.6	30.3	34.8	35.5	35.5	32.1	27.4	20.9	16.9	(19)
MCWB			12.6	12.4	13.4	16.2	19.0	21.9	21.7	21.5	20.2	18.6	15.5	12.8	(20)	
2%		DB	14.5	16.7	20.4	23.4	27.2	30.9	32.0	32.1	29.2	24.5	18.3	15.2	(21)	
		MCWB	12.0	11.3	12.7	14.3	17.8	20.0	21.3	21.3	19.4	18.1	14.7	12.4	(22)	
5%		DB	13.4	14.4	18.2	20.8	24.6	28.2	29.7	29.2	26.9	22.6	16.6	14.1	(23)	
		MCWB	11.5	10.8	11.9	13.7	16.8	19.3	20.4	20.6	18.5	17.4	14.1	12.2	(24)	
10%		DB	12.5	12.9	15.8	18.2	22.1	25.4	27.2	26.8	24.5	20.6	15.4	13.2	(25)	
		MCWB	10.9	10.5	11.1	12.6	15.9	18.5	19.7	19.8	18.0	16.6	13.3	11.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	13.5	14.7	17.0	20.5	22.7	23.6	24.1	22.2	20.1	16.9	14.1	(27)
MCDWB			14.8	17.3	20.3	23.8	28.0	31.5	30.8	30.2	28.7	24.0	19.1	14.9	(28)	
2%		WB	12.7	12.4	13.7	15.4	18.8	21.4	22.3	22.8	20.7	19.0	15.4	13.3	(29)	
		MCDWB	13.9	14.7	18.6	21.5	24.8	28.5	29.3	28.6	25.9	23.0	17.4	14.4	(30)	
5%		WB	12.0	11.7	12.7	14.4	17.7	20.2	21.4	21.7	19.7	18.1	14.5	12.6	(31)	
		MCDWB	13.1	13.6	16.3	19.3	22.7	26.0	27.5	26.8	24.6	21.2	16.3	13.9	(32)	
10%		WB	11.0	10.9	11.9	13.4	16.5	19.2	20.5	20.7	18.7	17.2	13.6	11.8	(33)	
		MCDWB	12.3	12.8	14.7	17.1	21.0	24.1	25.7	25.3	23.2	20.0	15.3	13.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.8	9.4	10.3	10.4	10.1	10.7	10.7	11.2	11.8	10.4	8.5	7.9	(35)
MCDBR			8.7	12.8	15.5	15.7	15.7	16.7	15.8	15.8	16.4	13.0	10.0	8.7	(36)	
MCWBR			6.4	8.2	8.7	7.9	7.5	7.1	6.4	6.6	7.6	7.2	6.7	6.3	(37)	
5% WB		MCDWR	7.4	10.2	12.0	13.0	13.2	13.7	13.1	12.7	13.1	10.7	8.9	7.3	(38)	
		MCWBR	5.9	7.2	7.2	7.1	6.8	6.6	6.0	6.1	7.0	6.3	6.4	5.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.330	0.343	0.373	0.392	0.398	0.411	0.402	0.399	0.375	0.369	0.344	0.327	(40)
taud		2.499	2.450	2.377	2.336	2.370	2.365	2.388	2.407	2.455	2.471	2.480	2.492	(41)		
Ebn at Noon		790	843	859	870	873	860	864	854	848	801	761	753	(42)		
Edh at Noon		70	87	106	119	119	120	116	110	97	84	71	64	(43)		
(44)	All-Sky Solar Radiation	RadAvg		1.34	2.31	3.56	4.80	5.67	6.30	6.18	5.48	4.37	2.76	1.61	1.23	(44)
(45)		RadStd		0.12	0.27	0.43	0.47	0.43	0.42	0.40	0.30	0.26	0.23	0.20	0.15	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page