

BISCAROSSE PARENTIS, France

WMO: 075030

Lat: 44.4317N

Lon: 1.2475W

Elev: 128

StdP: 14.63

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 28.2	(c) 31.1	(d) 19.3	(e) 14.6	(f) 32.8	(g) 23.6	(h) 17.9	(i) 35.9	(j) 41.6	(k) 51.0	(l) 38.0	(m) 50.2	(n) 6.1	(o) 90	(p) 0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.7	(c) 88.2	(d) 69.0	(e) 83.7	(f) 67.8	(g) 79.9	(h) 67.5	(i) 72.4	(j) 81.5	(k) 70.8	(l) 79.1	(m) 69.4	(n) 76.9	(o) 8.6	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.6	109.3	76.1	68.1	103.7	74.3	66.7	98.7	73.2	36.1	81.5	34.6	79.1	33.5	76.8	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 34.4	(b) 29.3	(c) 24.9	(e) 25.2	(f) 98.1	(g) 3.6	(h) 3.0	(i) 22.6	(j) 100.3	(k) 20.5	(l) 102.1	(m) 18.5	(n) 103.8	(o) 15.9	(p) 106.0		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			23.7	74.5	3.7	2.3	21.1	76.1	19.0	77.5	16.9	78.7	14.2	80.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.1	46.3	47.0	51.7	55.4	60.8	66.9	69.8	70.1	66.7	61.0	52.6	48.0
	DBStd	10.23	6.48	6.50	5.42	4.81	5.04	5.21	4.64	4.30	4.70	5.57	5.89	6.97
	HDD50	472	143	118	43	6	0	0	0	0	0	3	41	118
	HDD65	3057	579	504	413	291	150	34	7	3	32	145	373	526
	CDD50	3427	29	34	95	169	335	506	615	623	502	343	119	57
	CDD65	536	0	0	0	4	20	90	157	161	83	20	1	0
	CDH74	2786	0	0	3	41	173	537	780	755	425	70	2	0
	CDH80	826	0	0	0	7	46	200	236	223	109	5	0	0
Wind	WSAvg	10.4	11.0	10.7	11.2	11.2	10.6	9.9	10.1	9.0	9.1	9.2	11.1	11.2
Precipitation	PrecAvg	35.9	3.8	2.8	2.5	3.0	2.5	2.5	1.8	2.4	2.6	3.5	5.2	3.3
	PrecMax	43.3	8.8	5.7	5.6	7.3	5.6	6.5	3.7	6.9	5.1	6.5	11.6	7.6
	PrecMin	27.2	0.7	0.5	0.6	0.8	0.8	0.4	0.2	0.5	0.3	0.8	1.6	0.4
	PrecStd	4.7	2.2	1.5	1.5	1.8	1.3	1.5	0.9	1.6	1.1	1.9	2.6	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.4	66.8	73.0	79.7	85.8	93.5	94.2	93.7	88.2	80.1	70.2	63.9
		MCWB	53.4	53.9	56.9	60.1	64.7	70.9	70.1	70.3	68.1	65.2	60.0	54.1
	2%	DB	58.3	61.4	68.0	72.1	78.6	85.6	86.3	87.0	83.1	75.7	65.6	60.2
		MCWB	53.0	52.3	54.9	57.7	63.1	68.0	70.2	68.8	67.0	64.1	58.5	54.1
	5%	DB	56.2	57.6	63.8	67.5	73.0	79.6	81.1	81.2	78.7	72.1	62.6	58.1
		MCWB	52.8	51.1	53.4	56.2	61.1	66.1	69.4	68.9	66.3	63.2	57.5	53.7
	10%	DB	54.7	55.1	60.0	63.7	69.1	75.1	77.6	77.6	75.2	69.0	60.5	56.6
		MCWB	51.9	50.8	52.5	55.5	60.4	66.0	68.3	68.2	65.9	61.9	56.4	53.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.0	55.9	58.6	61.9	67.5	72.9	74.6	74.7	72.4	67.6	62.8	57.2
		MCDB	58.0	62.2	68.4	72.2	81.0	86.4	84.0	83.1	81.2	75.5	65.7	59.2
	2%	WB	54.8	54.0	56.5	59.5	64.7	70.0	72.2	72.3	70.0	65.8	60.1	55.8
		MCDB	56.7	57.9	64.0	68.0	73.9	80.1	81.2	80.6	77.2	72.3	63.7	58.0
	5%	WB	53.7	52.8	54.9	57.8	63.0	68.3	70.6	70.5	68.3	64.3	58.5	54.9
		MCDB	55.7	56.0	60.5	65.1	70.1	76.3	79.0	77.9	75.7	69.7	61.9	57.3
	10%	WB	52.1	51.7	53.5	56.3	61.5	66.8	69.1	69.2	66.7	62.9	56.8	53.7
		MCDB	54.5	54.6	58.1	62.3	67.5	73.4	76.7	75.9	73.2	68.2	60.2	56.5
Mean Daily Temperature Range	5% DB	MDBR	10.7	12.5	13.3	13.1	12.8	13.3	12.9	13.7	14.8	13.4	11.2	11.0
		MCDBR	11.7	16.3	20.5	20.1	21.7	22.7	19.9	20.9	21.1	17.7	13.7	11.4
		MCWBR	8.6	9.6	10.4	10.0	9.9	9.6	9.0	9.6	9.7	9.3	8.7	8.1
	5% WB	MCDBR	9.4	12.9	15.6	16.2	16.6	17.4	16.7	15.4	16.2	14.5	12.2	9.1
MCWBR		8.0	8.8	8.9	9.0	8.6	8.5	8.2	8.4	9.0	8.6	8.6	7.6	
Clear-Sky Solar Irradiance	taub	0.330	0.343	0.373	0.391	0.397	0.410	0.401	0.399	0.376	0.369	0.344	0.326	
	taud	2.502	2.453	2.383	2.344	2.376	2.372	2.394	2.413	2.459	2.476	2.483	2.495	
	Ebn at Noon	251	268	273	277	277	273	274	271	269	255	242	239	
	Edh at Noon	22	27	33	37	37	38	36	35	31	27	23	20	
All-Sky Solar Radiation	RadAvg	428	734	1134	1527	1809	2001	1963	1741	1389	878	513	393	
	RadStd	40	85	139	147	139	130	124	93	82	71	65	49	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page