

BISCAROSSE PARENTIS, France

WMO: 075030

Lat: 44.4317N

Lon: 1.2475W

Elev: 39

StdP: 100.86

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.1	(c) -0.5	(d) -7.0	(e) 2.1	(f) 0.4	(g) -4.7	(h) 2.6	(i) 2.2	(j) 18.6	(k) 10.5	(l) 17.0	(m) 10.1	(n) 2.7	(o) 90	(p) 0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.6	(c) 31.2	(d) 20.6	(e) 28.7	(f) 19.9	(g) 26.6	(h) 19.7	(i) 22.4	(j) 27.5	(k) 21.5	(l) 26.2	(m) 20.8	(n) 24.9	(o) 3.8	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	15.6	24.5	20.0	14.8	23.5	19.3	14.1	22.9	66.0	27.5	62.7	26.2	60.0	24.9	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
15.4	13.1	11.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-3.8	36.7	2.0	1.7	-5.2	37.9	-6.4	38.9	-7.5	39.9	-8.9	41.1
			-4.6	23.6	2.0	1.3	-6.1	24.5	-7.2	25.3	-8.4	26.0	-9.9	26.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.5	8.0	8.3	10.9	13.0	16.0	19.4	21.0	21.2	19.3	16.1	11.4	8.9
	DBStd	5.68	3.60	3.61	3.01	2.67	2.80	2.89	2.58	2.39	2.61	3.10	3.27	3.87
	HDD10.0	262	79	66	24	3	0	0	0	0	0	2	23	66
	HDD18.3	1698	322	280	229	162	83	19	4	2	18	81	207	292
	CDD10.0	1904	16	19	53	94	186	281	342	346	279	191	66	32
	CDD18.3	298	0	0	0	2	11	50	87	89	46	11	1	0
	CDH23.3	1548	0	0	2	23	96	298	433	419	236	39	1	0
	CDH26.7	459	0	0	0	4	26	111	131	124	61	3	0	0
Wind	WSAvg	4.6	4.9	4.8	5.0	5.0	4.7	4.4	4.5	4.0	4.1	4.1	5.0	5.0
Precipitation	PrecAvg	913	96	72	63	75	64	63	46	62	65	89	133	84
	PrecMax	1100	223	146	143	186	141	164	94	176	129	165	295	192
	PrecMin	691	18	12	14	21	21	9	6	12	7	21	41	10
	PrecStd	120	57	38	39	45	33	39	23	40	29	48	66	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	19.4	22.8	26.5	29.9	34.2	34.5	34.3	31.2	26.7	21.2	17.7
		MCWB	11.9	12.1	13.8	15.6	18.2	21.6	21.2	21.3	20.0	18.4	15.6	12.3
	2%	DB	14.6	16.3	20.0	22.3	25.9	29.8	30.2	30.6	28.4	24.3	18.7	15.7
		MCWB	11.7	11.3	12.7	14.3	17.3	20.0	21.2	20.4	19.5	17.8	14.7	12.3
	5%	DB	13.4	14.2	17.7	19.7	22.8	26.4	27.3	27.3	25.9	22.3	17.0	14.5
		MCWB	11.5	10.6	11.9	13.5	16.2	19.0	20.8	20.5	19.1	17.3	14.2	12.1
	10%	DB	12.6	12.8	15.6	17.6	20.6	23.9	25.3	25.4	24.0	20.5	15.9	13.7
		MCWB	11.0	10.4	11.4	13.1	15.8	18.9	20.2	20.1	18.8	16.6	13.6	11.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.3	13.3	14.8	16.6	19.7	22.7	23.7	23.7	22.4	19.8	17.1	14.0
		MCDB	14.4	16.8	20.2	22.3	27.2	30.2	28.9	28.4	27.3	24.1	18.7	15.1
	2%	WB	12.6	12.2	13.6	15.3	18.1	21.1	22.3	22.4	21.1	18.8	15.6	13.2
		MCDB	13.7	14.4	17.8	20.0	23.3	26.7	27.3	27.0	25.1	22.4	17.6	14.4
	5%	WB	12.1	11.6	12.7	14.3	17.2	20.2	21.5	21.4	20.2	18.0	14.7	12.7
		MCDB	13.2	13.4	15.8	18.4	21.2	24.6	26.1	25.5	24.3	20.9	16.6	14.1
	10%	WB	11.2	10.9	12.0	13.5	16.4	19.3	20.6	20.7	19.3	17.2	13.8	12.0
		MCDB	12.5	12.6	14.5	16.8	19.7	23.0	24.8	24.4	22.9	20.1	15.7	13.6
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.9	7.4	7.3	7.1	7.4	7.2	7.6	8.2	7.5	6.2	6.1
		MCDBR	6.5	9.0	11.4	11.2	12.0	12.6	11.1	11.6	11.7	9.9	7.6	6.4
		MCWBR	4.8	5.3	5.8	5.6	5.5	5.3	5.0	5.3	5.4	5.2	4.8	4.5
	5% WB	MCDBR	5.2	7.2	8.7	9.0	9.2	9.7	9.3	8.6	9.0	8.1	6.8	5.0
		MCWBR	4.5	4.9	5.0	5.0	4.8	4.7	4.6	4.7	5.0	4.8	4.8	4.2
Clear-Sky Solar Irradiance	taub	0.330	0.343	0.373	0.391	0.397	0.410	0.401	0.399	0.376	0.369	0.344	0.326	
	taud	2.502	2.453	2.383	2.344	2.376	2.372	2.394	2.413	2.459	2.476	2.483	2.495	
	Ebn at Noon	791	844	861	872	874	861	864	854	848	803	763	755	
	Edh at Noon	70	86	105	118	118	119	115	109	97	84	71	64	
All-Sky Solar Radiation	RadAvg	1.35	2.31	3.57	4.81	5.70	6.31	6.19	5.49	4.38	2.77	1.62	1.24	
	RadStd	0.13	0.27	0.44	0.46	0.44	0.41	0.39	0.29	0.26	0.23	0.20	0.15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page