

BERGERAC DORDOGNE PERIGORD AP, France

WMO: 075300

Lat: 44.8231N

Lon: 0.5242E

Elev: 52

StdP: 100.70

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.3	-3.6	-7.9	1.9	-2.7	-6.0	2.3	-1.3	9.8	9.9	8.5	10.4	1.2	70	0.461

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	33.3	21.8	31.2	20.9	29.5	20.3	23.0	30.7	22.1	29.6	21.1	27.8	2.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.6	15.4	26.5	19.6	14.4	25.3	18.8	13.7	24.2	68.2	30.6	64.7	29.7	61.3	27.8	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	6.9	6.0	DB	-8.3	36.7	2.6	1.8	-10.1	38.0	-11.6	39.0	-13.1	40.0	-15.0	41.3	(4)
(5)			WB	-8.6	24.7	2.5	1.0	-10.4	25.5	-11.9	26.1	-13.3	26.6	-15.1	27.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	5.8	6.3	9.4	11.9	15.4	19.2	21.1	20.6	17.3	14.2	8.8	6.0	(6)	
	DBStd	6.49	3.78	3.75	3.18	3.00	3.23	3.38	2.85	3.09	3.09	3.74	3.69	4.04	(7)	
	HDD10.0	518	138	111	48	14	2	0	0	0	0	9	64	131	(8)	
	HDD18.3	2208	389	338	277	195	101	29	8	12	56	136	286	382	(9)	
	CDD10.0	1623	6	6	31	70	169	276	343	329	218	139	28	8	(10)	
	CDD18.3	271	0	0	0	1	10	56	92	83	24	6	0	0	(11)	
	CDH23.3	3267	0	0	3	34	189	671	1039	936	342	54	0	0	(12)	
	CDH26.7	1195	0	0	0	3	41	244	414	387	99	7	0	0	(13)	
(14) Wind	WSAvg	2.5	2.6	2.8	2.9	2.8	2.5	2.4	2.4	2.2	2.1	2.2	2.4	2.4	(14)	
(15) Precipitation	PrecAvg	821	74	59	55	82	76	65	56	62	65	71	82	74	(15)	
	PrecMax	1008	190	136	151	166	152	145	143	173	167	174	219	197	(16)	
	PrecMin	544	17	6	10	12	11	11	12	13	23	22	27	13	(17)	
	PrecStd	124	43	37	33	45	34	33	31	39	37	35	42	44	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.7	18.6	23.3	27.0	30.0	34.8	35.7	37.0	32.0	27.3	20.7	16.5	(19)	
		MCWB	12.2	12.3	13.6	16.9	20.0	22.7	22.0	22.8	20.3	19.2	15.5	12.7	(20)	
	2%	DB	14.0	15.9	20.4	24.0	27.8	31.4	32.8	33.6	29.4	24.7	18.1	14.6	(21)	
		MCWB	11.6	11.2	13.1	15.5	18.6	21.0	21.9	21.7	19.4	18.2	14.4	12.0	(22)	
	5%	DB	12.7	14.0	18.3	21.7	25.6	29.4	30.9	30.9	27.3	22.6	16.3	13.3	(23)	
		MCWB	10.8	10.3	12.1	14.4	17.7	20.3	21.1	21.0	18.8	17.3	13.6	11.4	(24)	
	10%	DB	11.5	12.3	16.2	19.2	23.1	27.4	29.0	28.5	25.0	20.7	14.7	12.2	(25)	
		MCWB	9.9	9.9	11.1	13.2	16.5	19.4	20.4	20.1	18.0	16.4	12.7	10.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	13.2	15.1	18.0	21.3	23.8	23.8	24.2	22.4	20.3	16.3	13.6	(27)	
		MCDB	14.5	16.9	20.8	25.0	27.9	31.3	31.5	32.1	29.0	25.1	19.1	14.9	(28)	
	2%	WB	12.1	11.9	13.8	16.5	19.5	22.3	22.9	22.9	20.7	18.9	15.0	12.6	(29)	
		MCDB	13.6	14.4	18.9	22.8	26.1	30.1	30.5	30.6	26.9	23.1	17.1	14.1	(30)	
	5%	WB	11.1	11.1	12.8	14.9	18.2	21.1	21.9	21.9	19.5	17.9	13.9	11.6	(31)	
		MCDB	12.4	13.2	16.9	20.2	23.9	27.7	29.4	29.3	25.2	21.5	15.8	13.1	(32)	
	10%	WB	10.0	10.2	11.8	13.7	17.1	19.9	21.0	20.8	18.5	16.9	12.9	10.7	(33)	
		MCDB	11.3	12.1	15.3	18.4	22.1	25.8	27.7	27.1	23.5	20.2	14.7	12.1	(34)	
(35) Mean Daily Temperature Range	MDBR		7.8	10.0	11.9	12.1	12.2	12.5	12.8	13.5	13.6	11.5	8.9	8.2	(35)	
	5% DB	MCDBR	9.1	13.3	17.0	17.4	16.6	16.7	17.3	18.7	17.8	13.9	11.0	9.4	(36)	
		MCWBR	6.8	8.9	10.0	9.7	8.5	7.6	7.4	8.0	8.6	7.9	7.6	7.0	(37)	
	5% WB	MCDBR	7.3	10.7	13.8	15.6	14.6	14.9	15.2	15.8	14.9	11.8	9.5	8.2	(38)	
		MCWBR	5.9	7.6	8.5	9.0	8.1	7.2	6.9	7.3	7.7	7.0	6.9	6.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.323	0.337	0.371	0.401	0.405	0.419	0.409	0.406	0.375	0.367	0.340	0.321	(40)	
	taud		2.481	2.422	2.333	2.248	2.291	2.289	2.313	2.335	2.402	2.437	2.461	2.479	(41)	
	Ebn at Noon		794	846	858	859	866	853	856	845	845	799	761	755	(42)	
	Edh at Noon		70	88	110	130	128	129	125	118	102	86	71	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.31	2.26	3.42	4.55	5.32	6.11	6.02	5.33	4.27	2.72	1.56	1.20	(44)	
	RadStd		0.15	0.26	0.40	0.54	0.43	0.52	0.44	0.37	0.27	0.23	0.18	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page