

GOURDON, France

WMO: 075350

Lat: 44.7450N

Lon: 1.3967E

Elev: 261

StdP: 98.23

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.5	-3.7	-9.1	1.8	-1.8	-7.1	2.1	-0.2	9.2	8.9	7.7	7.7	1.4	130	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	33.3	20.9	31.1	20.2	29.2	19.5	22.2	30.1	21.3	28.9	20.4	27.4	2.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	15.0	25.2	18.9	14.1	24.2	18.0	13.4	23.3	66.2	30.1	63.0	29.0	59.9	27.5	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.9	6.2	5.2	-8.5	37.2	2.1	2.0	-10.0	38.6	-11.3	39.8	-12.5	40.9	-14.0	42.4		
			-8.8	24.1	2.2	1.1	-10.4	24.8	-11.7	25.5	-12.9	26.1	-14.5	26.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	5.3	6.0	9.3	11.8	15.3	19.0	21.0	20.7	17.3	14.1	8.6	5.9
	DBStd	6.76	3.90	4.10	3.64	3.57	3.58	3.75	3.34	3.44	3.50	3.98	3.99	4.28
	HDD10.0	570	151	118	57	20	3	0	0	0	0	12	72	137
	HDD18.3	2270	405	344	281	197	107	36	12	13	60	137	292	386
	CDD10.0	1631	4	7	35	75	168	271	341	331	221	140	30	8
	CDD18.3	289	0	0	0	2	14	57	94	86	30	7	0	0
	CDH23.3	3008	0	0	2	33	164	614	989	881	289	36	0	0
	CDH26.7	1120	0	0	0	3	33	226	406	368	81	3	0	0
Wind	WSAvg	2.3	2.4	2.6	2.7	2.6	2.2	2.0	1.9	1.8	1.9	2.3	2.4	2.4
Precipitation	PrecAvg	868	75	61	61	84	82	73	58	65	77	73	85	74
	PrecMax	1123	178	128	149	201	143	172	169	147	179	163	186	167
	PrecMin	649	9	5	6	2	26	17	16	11	24	23	23	17
	PrecStd	129	44	36	36	50	34	43	32	36	43	34	39	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	19.0	23.1	26.6	29.7	35.3	36.2	36.1	31.6	26.6	20.2	16.1
		MCWB	10.7	10.5	12.8	15.8	18.6	21.6	20.8	21.0	18.9	18.0	14.5	11.8
	2%	DB	13.3	15.7	20.1	23.8	27.3	31.4	33.1	33.2	29.0	24.0	17.6	14.2
		MCWB	10.1	10.1	11.8	14.4	17.7	20.3	20.9	20.9	18.5	17.1	13.4	11.0
	5%	DB	12.0	13.6	18.0	21.5	25.1	29.2	30.8	30.7	26.8	22.1	15.8	12.8
		MCWB	9.8	9.2	11.0	13.1	16.7	19.7	20.3	20.2	18.1	16.4	12.6	10.4
	10%	DB	10.7	11.7	15.7	18.9	22.7	27.1	28.7	28.3	24.4	20.2	14.2	11.5
		MCWB	8.9	8.7	9.8	12.0	15.7	18.9	19.6	19.5	17.1	15.7	11.9	9.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	12.1	13.9	16.5	20.4	23.5	23.2	23.2	21.4	19.2	15.4	12.7
		MCDB	13.4	16.5	20.1	24.8	27.3	30.8	30.9	30.9	28.1	24.3	18.4	14.5
	2%	WB	11.1	11.0	12.6	15.1	18.7	21.7	22.1	22.1	19.9	18.0	14.1	11.7
		MCDB	12.6	14.0	18.1	22.6	25.7	29.3	30.2	30.2	26.5	22.2	16.5	13.3
	5%	WB	10.1	10.1	11.7	13.8	17.4	20.5	21.2	21.2	18.7	17.1	13.1	10.9
		MCDB	11.6	12.4	16.3	19.5	23.3	27.6	28.8	28.4	24.3	20.9	15.2	12.6
	10%	WB	9.1	9.1	10.7	12.7	16.2	19.4	20.2	20.2	17.7	16.2	12.1	9.9
		MCDB	10.4	11.4	14.6	17.6	21.4	25.7	27.4	26.6	22.9	19.4	14.0	11.3
Mean Daily Temperature Range	5% DB	MDBR	6.6	8.5	10.2	10.8	11.2	11.9	12.5	12.6	11.9	9.7	7.3	6.7
		MCDBR	8.0	11.2	14.4	15.2	14.8	15.3	16.3	16.4	15.1	11.6	8.9	7.3
		MCWBR	5.3	6.7	7.5	7.6	7.4	6.8	6.4	6.4	6.6	5.9	5.5	4.9
	5% WB	MCDBR	6.2	9.1	11.8	13.1	13.1	13.8	14.0	13.9	12.4	9.8	7.3	6.2
		MCWBR	4.6	5.9	6.6	6.8	7.1	6.5	6.1	5.9	6.0	5.4	5.0	4.5
Clear-Sky Solar Irradiance	taub	0.308	0.322	0.354	0.386	0.391	0.402	0.394	0.393	0.363	0.354	0.327	0.306	
	taud	2.502	2.453	2.378	2.286	2.322	2.325	2.342	2.359	2.421	2.460	2.489	2.503	
	Ebn at Noon	816	867	878	875	879	868	870	859	858	816	781	778	
	Edh at Noon	68	85	105	125	124	125	121	115	100	84	69	62	
All-Sky Solar Radiation	RadAvg	1.33	2.27	3.42	4.55	5.34	6.19	6.10	5.38	4.28	2.76	1.55	1.22	
	RadStd	0.17	0.28	0.39	0.57	0.43	0.53	0.45	0.36	0.28	0.23	0.19	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page