

MENDE, France

WMO: 075540

Lat: 44.5336N

Lon: 3.4544E

Elev: 716

StdP: 93.01

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.4	-7.2	-15.0	1.1	-5.5	-12.2	1.4	-3.5	11.1	-1.2	9.4	0.8	3.0	300	0.547

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	30.4	17.6	28.5	17.1	26.7	16.5	19.1	27.3	18.2	25.8	17.4	24.6	3.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	12.6	21.8	15.4	11.9	21.2	14.6	11.3	20.2	57.4	27.4	54.2	25.6	51.6	24.6	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.4	6.5	-11.7	33.0	2.7	2.2	-13.6	34.6	-15.2	35.9	-16.8	37.1	-18.7	38.7		
(5)			-11.5	20.5	3.1	0.7	-13.8	21.0	-15.6	21.5	-17.3	21.9	-19.6	22.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	1.4	1.8	5.6	8.4	11.4	16.1	18.8	18.5	14.8	10.9	6.1	3.2	(6)
(7)		DBStd	7.05	3.53	4.62	3.52	3.35	3.69	3.82	3.27	3.42	3.25	3.80	3.87	3.86	(7)
(8)		HDD10.0	1108	267	231	140	69	27	1	0	0	3	37	123	211	(8)
(9)		HDD18.3	3237	525	463	394	297	215	88	34	42	112	231	366	469	(9)
(10)		CDD10.0	1035	0	1	4	23	71	183	272	263	147	64	7	0	(10)
(11)		CDD18.3	123	0	0	0	0	1	21	49	47	6	0	0	0	(11)
(12)		CDH23.3	1422	0	0	0	2	19	244	533	521	94	7	0	0	(12)
(13)		CDH26.7	394	0	0	0	0	1	64	154	163	12	0	0	0	(13)
(14)	Wind	WSAvg	2.9	2.7	3.0	3.3	3.1	3.2	2.8	2.8	2.6	2.5	2.8	2.7	2.7	(14)
(15)	Precipitation	PrecAvg	886	58	52	46	84	89	73	60	70	92	97	98	66	(15)
(16)		PrecMax	1159	152	126	164	206	175	231	146	216	252	181	192	177	(16)
(17)		PrecMin	599	0	6	0	4	22	10	21	15	19	37	32	6	(17)
(18)		PrecStd	142	36	31	37	49	42	39	29	37	51	39	45	39	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	17.2	19.7	22.3	25.7	31.7	32.5	32.4	28.4	24.2	18.4	13.6	(19)
(20)			MCWB	6.6	8.3	8.8	12.3	14.6	19.1	18.9	17.5	15.5	13.2	11.9	7.1	(20)
(21)		2%	DB	9.4	13.6	17.0	19.7	23.0	28.2	30.1	30.6	25.9	21.2	14.6	10.9	(21)
(22)			MCWB	6.5	6.3	8.1	11.2	14.1	17.6	17.7	17.3	14.9	13.1	10.0	6.2	(22)
(23)		5%	DB	7.8	9.9	14.4	17.6	21.0	26.0	28.2	28.6	24.0	18.7	12.5	9.3	(23)
(24)			MCWB	5.7	5.3	7.0	10.1	13.5	16.6	17.2	17.1	14.5	12.5	9.8	6.9	(24)
(25)		10%	DB	6.5	7.2	11.6	15.3	18.6	24.0	26.5	26.5	21.9	16.5	11.2	8.1	(25)
(26)			MCWB	4.9	4.6	6.3	9.1	12.1	15.7	16.7	16.5	14.0	12.2	9.2	6.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.0	9.9	13.3	16.3	20.3	20.1	19.9	17.5	15.7	12.5	9.2	(27)
(28)			MCDWB	10.7	15.7	16.1	20.8	23.2	28.8	29.8	28.8	24.0	19.7	16.7	10.7	(28)
(29)		2%	WB	7.2	7.1	8.9	11.8	14.9	18.6	19.1	18.8	16.6	14.4	11.1	8.1	(29)
(30)			MCDWB	8.8	10.8	15.0	18.6	21.6	26.5	27.4	26.8	22.9	17.7	13.6	9.3	(30)
(31)		5%	WB	6.1	5.9	7.9	10.7	13.7	17.3	18.1	18.0	15.7	13.6	10.2	7.4	(31)
(32)			MCDWB	7.5	8.9	12.2	16.4	19.8	24.5	25.9	25.7	21.5	16.7	12.0	8.7	(32)
(33)		10%	WB	5.1	4.9	6.9	9.4	12.6	16.2	17.3	17.2	14.7	12.8	9.5	6.5	(33)
(34)			MCDWB	6.3	7.1	10.7	14.2	17.8	23.0	24.7	24.3	20.1	16.0	11.0	7.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.7	7.9	9.5	9.8	10.2	11.4	12.4	12.8	11.3	9.3	6.5	6.8	(35)
(36)			MCDBR	9.0	13.2	14.7	14.4	13.9	14.7	15.6	16.1	15.3	13.6	9.1	9.0	(36)
(37)			MCWBR	6.3	7.8	7.7	7.6	7.0	6.7	6.3	6.1	6.6	7.1	5.9	6.1	(37)
(38)		5% WB	MCDWB	7.5	10.5	11.6	12.9	12.6	13.8	13.6	13.5	12.3	9.6	7.4	6.4	(38)
(39)			MCWBR	5.8	6.8	6.7	6.9	6.8	6.9	6.2	6.1	6.0	5.6	5.2	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.283	0.302	0.338	0.372	0.380	0.382	0.376	0.374	0.350	0.341	0.308	0.282	(40)	
(41)		taud	2.507	2.464	2.394	2.304	2.328	2.351	2.364	2.381	2.429	2.462	2.507	2.521	(41)	
(42)		Ebn at Noon	851	893	898	889	890	887	887	878	873	832	810	816	(42)	
(43)		Edh at Noon	67	84	103	123	124	122	118	113	99	84	67	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.46	2.36	3.50	4.50	5.40	6.41	6.40	5.57	4.28	2.65	1.59	1.30	(44)	
(45)		RadStd	0.18	0.28	0.40	0.55	0.54	0.49	0.50	0.36	0.30	0.29	0.20	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page