

MILLAU, France

WMO: 075580

Lat: 44.1186N

Lon: 3.0194E

Elev: 720

StdP: 92.97

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.7	-4.8	-12.4	1.4	-2.8	-10.0	1.7	-1.7	16.4	3.6	14.7	2.5	5.1	310	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	30.7	18.3	28.9	18.0	27.1	17.4	20.0	27.0	19.1	26.0	18.4	24.9	4.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	13.9	22.4	16.9	13.2	21.6	16.1	12.5	20.8	60.3	26.9	57.3	26.0	54.7	24.9	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.7	10.3	DB	-8.2	33.5	2.7	1.8	-10.2	34.8	-11.7	35.8	-13.2	36.8	-15.1	38.1	(4)
(5)			WB	-9.2	21.6	2.4	0.9	-11.0	22.2	-12.4	22.8	-13.8	23.3	-15.5	24.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	3.3	3.8	7.1	9.5	13.3	17.7	19.9	19.7	15.8	12.3	6.8	4.2	(6)
(7)		DBStd	6.95	3.51	4.06	3.58	3.51	3.53	3.86	3.38	3.48	3.34	3.53	3.78	3.77	(7)
(8)		HDD10.0	857	209	176	103	50	11	1	0	0	2	19	106	181	(8)
(9)		HDD18.3	2814	467	407	349	264	159	58	24	26	88	187	345	439	(9)
(10)		CDD10.0	1284	0	2	12	36	113	232	307	302	177	92	11	1	(10)
(11)		CDD18.3	199	0	0	0	0	3	39	73	69	14	1	0	0	(11)
(12)		CDH23.3	1613	0	0	0	3	30	318	596	566	96	4	0	0	(12)
(13)		CDH26.7	465	0	0	0	0	2	82	178	188	15	0	0	0	(13)
(14)	Wind	WSAvg	4.8	4.7	5.1	5.3	5.4	5.0	4.7	4.7	4.3	4.3	4.5	4.9	4.5	(14)
(15)	Precipitation	PrecAvg	907	71	59	56	89	87	61	50	62	93	97	111	72	(15)
(16)		PrecMax	1355	243	122	140	203	203	211	123	127	241	192	207	156	(16)
(17)		PrecMin	669	0	2	0	13	31	17	9	12	16	45	31	8	(17)
(18)		PrecStd	157	50	35	37	51	44	39	27	31	59	37	51	42	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	16.7	20.3	22.9	26.4	31.7	32.5	33.7	28.6	23.2	16.5	12.5	(19)
(20)			MCWB	8.3	8.9	10.4	13.5	16.3	18.9	18.6	18.5	17.2	14.7	12.2	8.6	(20)
(21)		2%	DB	10.2	13.2	17.3	20.2	23.7	28.8	30.4	31.1	25.9	20.5	14.5	11.0	(21)
(22)			MCWB	8.0	7.7	9.8	12.0	15.1	18.3	18.1	18.5	16.1	14.4	11.8	8.8	(22)
(23)		5%	DB	9.0	10.6	14.7	17.9	21.7	26.8	28.7	28.8	23.9	18.7	13.1	10.1	(23)
(24)			MCWB	7.4	6.8	8.4	11.0	14.2	17.5	17.9	17.9	15.5	14.0	11.0	8.3	(24)
(25)		10%	DB	7.9	8.8	12.4	15.6	19.6	24.9	26.9	26.7	21.7	17.0	11.9	9.0	(25)
(26)			MCWB	6.6	6.4	7.6	9.9	13.2	16.8	17.4	17.4	15.1	13.7	10.2	7.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	10.2	11.9	14.2	17.7	21.2	21.0	20.8	19.1	16.9	13.6	10.4	(27)
(28)			MCDWB	10.8	14.7	17.2	21.0	24.2	27.8	28.1	28.0	25.1	19.8	15.4	11.2	(28)
(29)		2%	WB	8.6	8.5	10.4	12.8	16.0	19.5	19.8	19.7	17.8	15.8	12.4	9.5	(29)
(30)			MCDWB	9.6	11.3	15.5	18.9	21.9	26.3	27.2	26.6	22.6	18.2	13.9	10.4	(30)
(31)		5%	WB	7.6	7.6	9.4	11.6	14.8	18.4	19.0	19.0	16.9	15.1	11.4	8.7	(31)
(32)			MCDWB	8.7	9.6	13.3	16.6	20.1	24.9	26.2	25.7	21.1	17.3	12.8	9.6	(32)
(33)		10%	WB	6.7	6.7	8.4	10.4	13.8	17.4	18.1	18.2	15.9	14.2	10.5	7.7	(33)
(34)			MCDWB	7.8	8.5	11.4	14.5	18.4	23.6	24.7	24.7	19.9	16.5	11.7	8.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	6.8	8.1	8.6	8.9	10.0	10.6	10.5	9.3	7.2	5.7	5.4	(35)
(36)			MCDBR	6.8	10.0	12.2	12.3	11.9	12.7	13.5	13.6	12.4	9.6	7.3	6.5	(36)
(37)			MCWBR	4.8	6.2	6.5	6.2	6.1	5.5	5.2	5.1	5.3	5.1	4.9	4.7	(37)
(38)		5% WB	MCDWR	5.5	8.3	10.0	11.0	10.7	11.7	11.6	11.4	10.0	7.2	6.0	5.0	(38)
(39)			MCWBR	4.4	5.6	5.8	5.9	6.0	5.6	5.1	5.0	5.0	4.3	4.4	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.286	0.301	0.337	0.368	0.376	0.379	0.373	0.372	0.349	0.339	0.308	0.284	(40)	
(41)		taud	2.517	2.478	2.402	2.315	2.338	2.357	2.371	2.383	2.435	2.473	2.512	2.526	(41)	
(42)		Ebn at Noon	854	897	901	894	895	890	891	880	877	838	815	820	(42)	
(43)		Edh at Noon	67	83	103	122	123	121	118	112	99	83	68	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.50	2.41	3.57	4.65	5.52	6.52	6.51	5.66	4.37	2.75	1.67	1.33	(44)	
(45)		RadStd	0.17	0.28	0.36	0.53	0.49	0.47	0.45	0.36	0.29	0.28	0.21	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page