

MONT AIGOUAL, France

WMO: 075600

Lat: 44.1214N

Lon: 3.5814E

Elev: 1565

StdP: 83.88

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-11.6	-9.6	-23.8	0.5	1.9	-19.9	0.8	1.5	29.8	-5.8	28.0	-6.9	16.5	0	1.035

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	22.5	14.7	21.1	14.0	19.7	13.4	16.2	20.0	15.3	19.0	14.5	18.1	4.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	12.9	17.6	14.0	12.1	16.8	13.1	11.4	16.0	51.5	19.9	48.7	19.1	46.2	18.2	19.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	22.9	20.9	DB	-12.9	24.4	2.7	1.5	-14.8	25.6	-16.4	26.5	-17.9	27.3	-19.8	28.4	(4)
(5)			WB	-13.4	17.8	2.5	0.9	-15.2	18.4	-16.7	19.0	-18.1	19.5	-20.0	20.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.7	-1.3	-1.4	1.1	3.3	7.3	11.6	13.9	13.9	10.1	7.0	2.0	0.1
	DBStd	6.83	3.95	4.67	4.19	3.98	3.95	4.13	3.74	3.87	3.74	3.76	4.25	4.24
	HDD10.0	2001	349	321	277	204	103	31	11	9	44	104	241	307
	HDD18.3	4636	607	554	535	451	343	204	143	145	248	351	489	564
	CDD10.0	422	0	0	1	3	19	78	131	131	46	12	1	1
	CDD18.3	14	0	0	0	0	0	2	4	8	0	0	0	0
	CDH23.3	22	0	0	0	0	0	2	4	15	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	10.2	12.2	12.1	11.0	10.2	9.7	8.7	8.7	8.3	8.6	10.0	11.6	11.8
Precipitation	PrecAvg	1327	111	82	82	113	105	66	48	58	153	198	183	127
	PrecMax	2356	716	223	322	288	264	231	153	131	381	389	483	361
	PrecMin	863	1	0	0	14	15	12	4	19	2	33	26	7
	PrecStd	322	135	69	90	76	65	43	30	34	103	81	132	106
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	11.4	12.8	15.2	18.6	23.5	24.0	25.3	20.7	17.0	13.4	12.6
		MCWB	1.8	3.7	6.1	9.2	12.2	14.9	15.6	15.5	13.4	9.4	6.6	2.5
	2%	DB	8.0	9.1	10.6	13.0	16.6	20.9	22.0	23.0	18.4	15.0	10.9	9.4
		MCWB	1.5	2.5	4.2	7.5	11.2	14.7	14.7	14.6	12.3	8.7	5.1	1.9
	5%	DB	5.4	6.9	8.7	11.1	14.7	19.2	20.7	21.4	16.9	13.2	9.1	7.0
		MCWB	1.6	1.6	3.4	6.4	9.9	13.4	13.9	13.8	11.6	8.5	5.5	1.5
	10%	DB	3.7	4.5	6.9	9.1	13.0	17.7	19.4	19.7	15.2	11.7	7.5	5.4
		MCWB	1.5	1.0	2.8	5.3	8.8	12.6	13.5	13.3	10.8	9.0	5.7	2.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.4	5.7	7.4	10.1	13.8	17.2	17.4	17.2	15.3	12.4	9.3	6.2
		MCDB	6.5	8.6	10.3	13.9	17.4	21.2	21.5	21.3	18.4	13.3	10.2	6.9
	2%	WB	4.1	4.0	5.7	8.2	12.1	15.6	16.1	16.1	13.8	11.5	8.0	5.2
		MCDB	5.0	6.5	8.6	11.7	15.5	19.2	19.9	19.8	16.3	12.2	8.9	5.8
	5%	WB	3.1	2.9	4.6	7.1	10.7	14.4	15.2	15.2	12.9	10.7	7.2	4.3
		MCDB	3.8	4.7	7.1	10.1	13.7	17.8	19.1	18.8	15.0	11.5	7.9	4.9
	10%	WB	2.2	2.0	3.6	5.9	9.6	13.4	14.4	14.4	12.0	9.9	6.2	3.3
		MCDB	3.1	3.5	5.6	8.3	12.2	16.8	18.2	18.1	14.2	10.9	6.9	4.1
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.5	5.0	5.2	5.6	6.3	6.8	6.4	5.5	4.5	4.1	4.3
		MCDBR	6.1	6.7	7.0	7.5	7.3	7.3	7.8	7.6	6.8	6.2	5.7	5.9
		MCWBR	4.0	4.5	5.0	5.2	5.6	5.6	5.5	5.2	5.2	5.0	4.4	3.5
	5% WB	MCDBR	4.6	5.3	5.9	6.5	6.6	6.5	6.8	6.2	5.5	4.2	4.3	4.2
		MCWBR	4.1	4.3	4.6	4.9	5.3	5.6	5.4	5.1	4.8	4.0	4.0	3.8
Clear-Sky Solar Irradiance	taub	0.254	0.267	0.295	0.320	0.326	0.327	0.324	0.322	0.307	0.301	0.274	0.253	
	taud	2.576	2.553	2.502	2.438	2.455	2.469	2.473	2.484	2.520	2.550	2.581	2.586	
	Ebn at Noon	904	945	950	946	944	940	939	931	925	887	866	872	
	Edh at Noon	63	77	93	107	109	108	106	101	90	77	62	57	
All-Sky Solar Radiation	RadAvg	1.55	2.48	3.65	4.73	5.69	6.69	6.70	5.78	4.41	2.72	1.71	1.37	
	RadStd	0.18	0.27	0.37	0.49	0.49	0.43	0.42	0.33	0.29	0.30	0.22	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page