

AUBENAS AP, France

WMO: 075700

Lat: 44.5383N

Lon: 4.3672E

Elev: 919

StdP: 14.21

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.0	27.6	9.0	9.0	32.6	13.7	11.4	32.5	26.3	38.5	23.3	39.4	6.5	10	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.7	93.6	68.3	90.5	67.3	87.6	66.4	70.7	87.0	69.3	85.0	68.0	82.9	8.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	99.8	73.6	64.6	94.4	73.4	63.1	89.4	72.3	35.0	87.1	33.8	85.1	32.8	83.0	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	19.9	17.4	DB	20.9	98.3	4.1	3.2	17.9	100.6	15.5	102.5	13.2	104.3	10.2	106.7	(4)
(5)			WB	18.6	73.0	4.1	1.9	15.6	74.4	13.2	75.5	10.8	76.6	7.9	78.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	41.2	42.5	49.0	55.1	61.2	70.0	74.5	72.9	66.2	57.8	48.4	42.7		
	DBStd	12.99	5.85	6.31	6.09	5.69	5.65	5.79	4.98	5.17	5.03	5.91	5.97	5.62		
	HDD50	942	278	218	90	15	1	0	0	0	0	12	95	233		
	HDD65	3791	738	631	497	300	143	17	2	3	43	228	497	692		
	CDD50	3451	5	7	58	169	348	601	759	709	486	254	49	6		
	CDD65	823	0	0	0	3	25	168	296	247	79	5	0	0		
	CDH74	8406	0	0	1	68	298	1786	3059	2432	718	44	0	0		
	CDH80	3361	0	0	0	4	54	697	1359	1044	197	6	0	0		
(14) Wind	WSAvg	6.7	6.5	7.4	7.5	7.4	7.2	6.9	6.8	6.7	6.2	5.9	6.6	5.6		
(15) Precipitation	PrecAvg	49.1	3.9	2.5	2.4	3.7	3.9	2.7	2.3	2.7	6.2	7.5	7.0	4.2		
	PrecMax	80.1	13.2	8.9	7.9	9.0	10.6	9.8	7.8	8.3	14.0	14.7	21.5	11.3		
	PrecMin	28.7	0.1	0.0	0.1	0.5	0.5	0.7	0.3	0.8	1.2	0.6	0.6	0.2		
	PrecStd	11.8	3.3	2.4	2.2	2.3	2.6	1.8	1.7	1.6	3.6	3.5	5.0	3.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.4	65.4	72.6	80.1	85.0	95.7	96.8	99.0	89.8	79.1	67.6	59.6		
		MCWB	51.1	50.2	53.4	60.1	63.6	69.0	69.1	68.7	66.3	61.1	57.1	50.5		
	2%	DB	56.8	60.0	68.1	75.6	80.9	90.8	93.4	93.6	85.3	73.7	62.8	56.0		
		MCWB	47.7	48.3	52.1	57.5	62.2	67.9	68.4	67.8	64.5	60.8	54.4	49.2		
	5%	DB	53.1	55.7	64.5	71.8	77.2	87.5	90.6	89.8	81.6	70.6	59.8	53.6		
		MCWB	46.1	46.1	51.0	55.8	60.6	66.8	67.5	66.9	63.1	59.8	53.4	48.5		
	10%	DB	50.4	52.3	60.7	67.7	73.6	84.2	87.7	86.1	78.0	67.9	57.5	51.5		
		MCWB	44.8	44.7	49.0	53.9	58.9	65.6	66.7	65.9	61.9	58.8	52.5	47.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.1	52.0	55.6	60.9	66.3	72.5	72.3	71.6	69.2	65.5	59.1	54.0		
		MCDB	58.6	62.1	67.8	76.9	80.1	89.5	88.4	86.6	82.3	70.4	63.1	56.5		
	2%	WB	49.8	49.7	53.6	58.7	63.7	70.1	70.7	70.0	67.1	63.6	56.8	51.7		
		MCDB	53.6	56.9	64.9	72.8	76.9	86.2	87.5	85.5	77.3	69.0	60.6	53.9		
	5%	WB	47.8	47.9	51.9	56.7	61.9	68.2	69.3	68.7	65.6	61.9	55.2	50.0		
		MCDB	51.6	53.6	61.5	68.7	74.2	83.9	85.7	83.7	76.2	67.7	58.1	52.3		
	10%	WB	45.8	45.9	50.3	54.8	60.1	66.5	68.0	67.4	64.0	60.3	53.6	47.9		
		MCDB	49.4	50.8	58.5	65.1	71.0	81.5	83.7	81.9	74.4	65.9	56.4	50.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	15.7	18.6	19.3	19.7	22.2	22.7	22.5	19.9	16.3	14.0	13.7		
		MCDBR	17.9	22.4	25.1	26.7	26.3	27.4	27.6	29.0	26.4	21.0	17.7	16.7		
		MCWBR	11.6	13.0	12.9	12.3	11.6	10.2	9.2	9.6	10.2	10.6	10.8	11.3		
	5% WB	MCDBR	14.4	19.0	22.1	24.6	23.6	25.9	25.3	25.2	21.2	16.8	13.4	12.4		
		MCWBR	10.0	11.9	11.8	11.8	11.2	10.1	9.4	9.6	9.1	9.2	9.0	9.6		
(40) Clear-Sky Solar Irradiance	taub		0.308	0.328	0.364	0.390	0.398	0.398	0.393	0.390	0.374	0.371	0.334	0.306		
	taud		2.488	2.433	2.352	2.293	2.317	2.344	2.356	2.373	2.403	2.414	2.473	2.504		
	Ebn at Noon		259	273	275	276	277	277	273	269	252	246	246	248		
	Edh at Noon		22	28	34	39	40	39	38	36	32	28	23	20		
(44) All-Sky Solar Radiation	RadAvg		482	775	1170	1517	1817	2136	2127	1831	1403	862	530	420		
	RadStd		56	81	122	158	155	122	136	90	93	94	73	53		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page