

MONTELMAR-ANCONE AP, France

WMO: 075770

Lat: 44.5811N

Lon: 4.7331E

Elev: 74

StdP: 100.44

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.7	-1.3	-9.1	1.8	-0.1	-6.9	2.1	1.7	12.3	3.9	11.3	4.0	4.4	20	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	34.0	20.8	32.3	20.4	30.7	20.0	22.2	30.4	21.4	29.4	20.8	28.5	3.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.6	24.8	18.9	13.9	24.4	18.2	13.2	23.7	65.1	30.1	62.4	29.7	60.1	28.5	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.4	9.4	8.5	-4.7	36.4	1.8	1.9	-6.0	37.8	-7.1	38.9	-8.1	40.0	-9.4	41.4		
			(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-5.6	23.5	1.9	0.8	-7.0	24.1	-8.1	24.6	-9.1	25.1	-10.5	25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	5.5	6.5	10.2	13.0	17.0	21.3	23.8	23.3	19.0	15.1	9.4	6.1
	DBStd	7.18	3.24	3.39	3.14	3.08	2.94	3.17	2.78	2.83	2.92	3.20	3.55	3.44
	HDD10.0	473	143	102	37	8	0	0	0	0	0	3	52	128
	HDD18.3	1996	399	330	254	161	60	9	1	1	26	108	268	380
	CDD10.0	2014	2	6	41	98	217	339	427	412	271	160	34	7
	CDD18.3	496	0	0	0	1	19	98	170	155	47	6	0	0
	CDH23.3	4572	0	0	1	28	200	926	1627	1419	348	24	0	0
	CDH26.7	1762	0	0	0	2	36	340	693	599	92	1	0	0
Wind	WSAvg	3.7	3.9	4.1	3.9	3.7	3.5	3.7	3.7	3.6	3.5	3.3	3.8	3.8
Precipitation	PrecAvg	930	65	73	75	60	89	60	36	71	126	114	97	74
	PrecMax	1362	140	224	186	161	227	143	103	182	312	417	365	241
	PrecMin	630	4	2	1	5	14	5	1	2	0	7	3	10
	PrecStd	196	37	59	50	34	52	33	29	49	100	93	82	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	17.4	21.9	26.4	29.8	35.1	36.0	37.3	31.7	25.7	19.7	15.8
		MCWB	11.1	10.9	12.9	16.0	18.7	21.6	21.1	21.3	19.5	17.9	14.7	11.9
	2%	DB	13.1	15.4	19.7	23.6	27.4	32.2	34.0	34.0	29.4	23.6	17.8	14.1
		MCWB	9.8	10.1	12.2	14.7	17.5	20.6	20.8	20.8	19.0	17.4	13.9	11.2
	5%	DB	11.6	13.6	18.0	21.5	25.6	30.4	32.3	32.1	27.1	21.9	16.2	12.7
		MCWB	9.0	9.3	11.4	13.6	16.8	20.0	20.4	20.5	18.2	16.7	13.1	10.2
	10%	DB	10.3	11.9	16.2	19.5	23.7	28.4	30.7	30.1	25.2	20.3	14.7	11.4
		MCWB	8.2	8.5	10.5	12.7	16.0	19.1	20.0	20.1	17.7	16.1	12.3	9.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.5	11.7	14.1	16.6	19.9	23.2	23.1	23.1	21.3	19.3	15.8	12.8
		MCDB	14.0	15.6	19.8	24.6	27.6	32.1	31.7	30.8	27.0	22.7	18.2	14.6
	2%	WB	10.3	10.7	12.8	15.3	18.5	21.7	22.1	22.1	20.3	18.4	14.4	11.6
		MCDB	12.3	14.3	18.2	22.3	25.5	29.5	31.0	29.9	26.0	22.0	16.7	13.5
	5%	WB	9.4	9.8	12.0	14.2	17.5	20.6	21.3	21.4	19.4	17.5	13.6	10.6
		MCDB	11.2	12.9	16.6	20.1	23.9	28.3	29.8	29.2	25.1	20.9	15.8	12.3
	10%	WB	8.5	8.8	11.1	13.3	16.5	19.7	20.7	20.7	18.5	16.5	12.5	9.5
		MCDB	10.1	11.5	15.3	18.2	22.3	27.1	28.7	28.2	23.7	19.6	14.6	11.1
Mean Daily Temperature Range	5% DB	MDBR	6.0	7.6	9.6	10.1	10.5	11.1	11.7	11.6	10.1	8.2	6.4	5.6
		MCDBR	8.4	11.5	13.2	14.3	14.5	14.8	15.1	15.4	14.0	10.6	8.6	7.5
	5% WB	MCWBR	5.9	7.0	7.0	6.9	6.4	5.5	4.8	4.9	5.6	5.5	5.6	5.2
		MCWBR	7.5	10.0	11.6	12.5	12.5	13.5	13.5	13.5	11.4	9.1	7.7	6.3
Clear-Sky Solar Irradiance	taub	taub	0.317	0.337	0.374	0.396	0.404	0.404	0.398	0.395	0.382	0.381	0.342	0.314
		taud	2.470	2.410	2.328	2.286	2.312	2.340	2.355	2.372	2.395	2.395	2.452	2.487
	Ebn at Noon	Ebn at Noon	803	847	856	865	867	866	866	857	839	783	760	768
		Edh at Noon	71	89	111	125	126	123	120	114	103	90	72	64
All-Sky Solar Radiation	RadAvg	RadAvg	1.54	2.46	3.71	4.81	5.74	6.76	6.76	5.81	4.44	2.76	1.69	1.33
	RadStd	RadStd	0.17	0.26	0.38	0.48	0.49	0.38	0.43	0.27	0.30	0.29	0.23	0.17

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page