

POINTE DE SOCOA, France

WMO: 076000

Lat: 43.3944N

Lon: 1.6864W

Elev: 82

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.9	33.6	23.0	17.4	38.3	26.6	20.6	40.4	44.9	49.7	38.6	51.1	6.2	190	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.0	85.7	70.1	81.4	69.7	78.5	68.8	74.1	80.7	72.3	78.5	70.7	76.5	10.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	118.2	78.1	70.1	111.1	76.3	68.5	105.2	74.6	37.6	81.2	36.0	78.5	34.6	76.7	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.6	28.2	24.0	DB	26.9	96.9	3.5	4.3	24.4	100.0	22.4	102.5	20.4	104.9	17.9	108.1	(4)
(5)			WB	25.8	77.7	3.5	1.9	23.3	79.1	21.2	80.2	19.3	81.2	16.7	82.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.9	49.1	49.2	52.8	55.5	60.4	65.9	69.4	70.1	66.6	62.6	54.4	50.7	(6)	
	DBStd	9.43	6.44	6.67	6.22	5.07	5.02	4.85	3.99	3.89	4.71	6.25	6.51	7.08	(7)	
	HDD50	332	93	84	38	7	0	0	0	0	0	2	30	78	(8)	
	HDD65	2741	494	442	382	289	162	43	6	3	34	120	323	443	(9)	
	CDD50	3597	64	62	124	173	321	476	601	624	497	393	161	101	(10)	
	CDD65	531	0	1	3	5	18	69	141	162	81	46	5	0	(11)	
	CDH74	2242	0	2	8	40	138	339	517	646	363	183	6	0	(12)	
	CDH80	528	0	0	0	8	35	124	123	145	73	20	0	0	(13)	
(14) Wind	WSAvg	9.9	11.1	10.9	10.7	10.3	10.1	9.3	8.9	8.6	8.4	9.1	10.8	11.3	(14)	
(15) Precipitation	PrecAvg	67.8	6.9	6.0	5.3	6.2	5.2	3.9	3.4	3.7	5.0	6.1	9.2	6.9	(15)	
	PrecMax	90.7	17.4	13.9	12.0	13.6	12.8	8.5	8.3	10.4	9.7	17.3	15.4	11.4	(16)	
	PrecMin	50.6	0.5	1.4	1.3	2.5	2.0	0.9	1.0	1.2	1.8	0.8	2.0	0.4	(17)	
	PrecStd	8.9	4.0	3.5	2.8	3.2	2.2	2.0	1.9	2.2	2.3	3.9	3.9	3.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.3	71.2	74.6	79.3	84.4	91.1	91.7	90.0	86.7	83.0	73.9	69.1	(19)	
		MCWB	53.9	53.5	56.7	59.5	65.8	72.0	73.0	72.8	68.8	66.3	59.8	54.1	(20)	
	2%	DB	63.7	65.9	70.3	72.1	77.4	82.9	82.3	83.6	81.5	78.6	70.5	65.7	(21)	
		MCWB	53.3	52.3	55.5	57.5	63.6	68.6	72.7	72.6	68.1	64.2	58.4	53.8	(22)	
	5%	DB	60.9	62.5	66.3	67.5	72.5	76.7	78.5	79.6	77.8	75.7	67.1	63.1	(23)	
		MCWB	52.3	51.2	54.2	56.3	62.5	68.5	71.3	71.7	68.2	63.3	56.7	53.0	(24)	
	10%	DB	58.2	59.2	62.9	64.1	68.8	73.2	76.2	77.0	75.1	72.9	64.1	60.6	(25)	
		MCWB	51.1	50.8	53.0	56.1	61.7	66.6	69.7	70.1	67.2	62.2	55.8	52.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.0	57.0	59.3	62.8	69.3	74.7	76.4	76.9	73.3	68.9	62.6	57.9	(27)	
		MCDB	62.3	64.1	69.8	71.1	79.4	84.5	83.4	83.2	80.4	76.2	68.4	62.2	(28)	
	2%	WB	55.4	55.0	57.4	60.2	66.1	70.7	73.8	74.3	71.1	66.9	60.2	56.3	(29)	
		MCDB	60.1	60.6	65.7	67.7	73.2	78.4	79.9	80.8	77.3	73.9	66.1	61.6	(30)	
	5%	WB	54.0	53.6	55.9	58.5	64.0	68.9	71.9	72.5	69.4	65.4	58.6	54.9	(31)	
		MCDB	58.2	58.4	63.3	64.8	70.3	75.1	77.7	78.5	75.5	72.3	64.5	60.3	(32)	
	10%	WB	52.5	52.3	54.4	57.0	62.3	67.3	70.3	70.8	67.9	63.9	57.1	53.5	(33)	
		MCDB	56.9	57.0	60.8	62.5	67.4	72.6	75.6	76.2	73.8	70.4	62.2	58.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.5	12.6	13.3	13.2	12.9	12.4	12.0	13.0	14.4	14.0	12.0	11.8	(35)	
		MCDBR	14.0	17.6	18.7	20.3	21.7	21.2	17.2	18.5	19.4	17.6	15.0	13.7	(36)	
	5% WB	MCWBR	8.1	9.1	9.4	10.3	10.9	10.8	9.6	10.1	10.2	8.2	7.8	7.7	(37)	
		MCWBR	11.7	14.2	16.3	16.7	18.1	17.5	15.9	16.5	16.8	15.5	12.7	11.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.331	0.347	0.381	0.406	0.416	0.428	0.418	0.417	0.394	0.372	0.347	0.327	(40)	
		taud	2.489	2.431	2.342	2.284	2.300	2.302	2.335	2.346	2.398	2.458	2.474	2.495	(41)	
	Ebn at Noon		253	268	271	272	272	269	270	266	264	256	244	244	(42)	
		Edh at Noon	23	29	35	40	41	41	39	37	33	28	23	21	(43)	
(44) All-Sky Solar Radiation	RadAvg		446	720	1110	1433	1701	1884	1879	1674	1354	878	525	418	(44)	
	RadStd		55	94	137	151	138	118	105	104	69	72	64	51	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page