

BIARRITZ AP, France

WMO: 076020

Lat: 43.4694N

Lon: 1.5344W

Elev: 245

StdP: 14.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.5	31.3	22.0	16.7	33.6	25.5	19.7	35.9	28.1	49.7	25.0	50.2	5.5	100	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.8	87.9	71.4	83.3	69.1	79.2	67.7	73.4	82.4	71.5	79.4	70.0	76.5	8.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.7	114.3	77.4	69.1	108.1	75.0	67.8	103.0	73.6	37.1	82.6	35.4	79.6	34.1	76.6	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	18.4	15.7	DB	23.7	97.0	3.2	3.5	21.4	99.6	19.6	101.6	17.8	103.6	15.5	106.2	(4)
(5)			WB	22.7	77.7	3.3	1.8	20.4	79.0	18.4	80.0	16.5	81.0	14.1	82.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	47.2	47.7	51.8	54.6	59.7	65.3	68.5	69.4	65.2	61.2	52.1	48.4	(6)	
	DBStd	10.00	6.91	6.88	6.22	5.50	5.60	5.76	4.61	4.66	5.39	6.48	6.64	7.54	(7)	
	HDD50	489	133	112	51	15	2	0	0	0	0	5	53	118	(8)	
	HDD65	3145	551	486	409	316	182	63	15	9	60	152	388	514	(9)	
	CDD50	3287	47	46	108	153	303	459	574	602	457	351	117	70	(10)	
	CDD65	466	0	0	1	4	18	71	125	146	67	33	1	0	(11)	
	CDH74	2484	0	2	9	47	192	471	531	665	392	172	3	0	(12)	
	CDH80	777	0	0	0	9	50	193	176	219	106	24	0	0	(13)	
(14) Wind	WSAvg	7.1	7.3	7.3	7.6	7.8	7.7	7.4	7.1	6.6	6.3	6.2	7.0	7.2	(14)	
(15) Precipitation	PrecAvg	67.8	6.9	6.0	5.3	6.2	5.2	3.9	3.4	3.7	5.0	6.1	9.2	6.9	(15)	
	PrecMax	90.7	17.4	13.9	12.0	13.6	12.8	8.5	8.3	10.4	9.7	17.3	15.4	11.4	(16)	
	PrecMin	50.6	0.5	1.4	1.3	2.5	2.0	0.9	1.0	1.2	1.8	0.8	2.0	0.4	(17)	
	PrecStd	8.9	4.0	3.5	2.8	3.2	2.2	2.0	1.9	2.2	2.3	3.9	3.9	3.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	71.3	75.0	80.3	86.2	93.0	92.9	93.9	88.0	83.3	73.2	68.0	(19)	
		MCWB	53.9	54.7	57.2	62.4	66.9	71.9	73.9	73.2	69.8	66.5	60.2	54.9	(20)	
	2%	DB	62.8	65.2	70.4	73.4	79.5	85.7	84.6	86.2	83.1	78.4	69.4	64.6	(21)	
		MCWB	53.0	52.5	56.0	58.7	64.5	70.0	71.3	71.8	68.4	64.6	58.1	54.1	(22)	
	5%	DB	60.0	61.5	66.2	68.2	74.4	78.8	78.9	80.5	78.6	75.2	65.6	61.7	(23)	
		MCWB	51.4	51.1	54.3	56.2	62.4	67.1	69.4	70.6	67.1	63.1	56.1	52.6	(24)	
	10%	DB	57.2	57.8	62.5	63.9	69.6	73.5	75.5	76.7	74.5	71.8	62.4	59.0	(25)	
		MCWB	50.5	50.1	52.7	54.9	60.6	65.7	68.6	69.2	66.2	61.8	55.3	51.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.4	56.6	59.3	63.5	69.6	74.7	75.6	76.2	72.9	68.4	62.3	57.5	(27)	
		MCDB	61.8	65.1	70.9	76.6	82.9	88.0	86.8	86.2	82.3	77.3	68.8	62.6	(28)	
	2%	WB	54.7	54.4	57.1	60.0	65.9	70.9	72.9	73.5	70.6	66.4	59.8	55.9	(29)	
		MCDB	59.3	60.6	66.9	70.1	76.0	82.3	81.2	81.7	78.2	74.0	65.6	60.7	(30)	
	5%	WB	53.3	53.0	55.4	58.0	63.6	68.5	70.9	71.7	68.9	64.8	58.1	54.5	(31)	
		MCDB	57.5	58.2	63.3	65.4	71.5	76.5	77.4	78.8	75.5	71.8	63.3	59.2	(32)	
	10%	WB	51.8	51.6	53.9	56.4	61.7	66.6	69.3	70.1	67.2	63.2	56.4	52.9	(33)	
		MCDB	55.8	56.1	60.3	61.9	67.9	72.7	74.5	75.7	73.2	69.5	61.1	57.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.6	13.8	14.4	14.2	14.4	13.9	12.9	13.8	16.1	15.3	13.6	12.9	(35)	
		MCDBR	15.9	20.3	22.1	23.3	25.3	25.2	22.1	22.6	23.8	20.6	18.2	15.2	(36)	
	5% WB	MCWBR	9.5	10.9	11.0	11.6	12.4	12.0	10.7	10.8	11.5	9.9	9.8	8.6	(37)	
		MCWBR	13.1	15.5	17.8	19.1	20.5	20.9	18.1	18.7	19.0	17.9	15.2	12.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.327	0.343	0.376	0.401	0.410	0.422	0.413	0.412	0.389	0.367	0.343	0.324	(40)	
		taud	2.495	2.438	2.354	2.295	2.313	2.314	2.345	2.356	2.408	2.466	2.482	2.500	(41)	
	Ebn at Noon	Ebn at Noon	255	270	273	274	274	270	271	268	266	257	246	245	(42)	
		Edh at Noon	23	28	35	40	40	40	39	37	33	27	23	21	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	441	716	1106	1421	1682	1861	1849	1656	1346	873	521	414	(44)	
	RadStd	RadStd	55	93	137	151	141	119	108	105	69	71	65	52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page