

DAX SEYRESSE AP, FranceWMO: **076030**Lat: **43.6897N**Lon: **1.0700W**Elev: **108**StdP: **14.64**Time Zone: **1.00 (EUC)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.7	29.2	20.8	15.7	31.3	24.7	18.8	34.1	19.2	52.9	16.7	52.6	2.4	70	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	91.2	72.3	87.3	70.5	83.9	69.3	74.4	86.8	72.6	83.7	70.9	80.7	7.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.7	113.4	80.0	69.0	106.9	77.2	67.6	101.7	75.4	37.9	86.9	36.2	84.2	34.7	80.8	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	13.1	11.4	DB	22.2	99.1	3.6	2.6	19.6	100.9	17.5	102.4	15.5	103.8	12.8	105.7	(4)
(5)			WB	21.4	77.7	3.9	1.5	18.5	78.7	16.2	79.6	14.1	80.4	11.2	81.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.8	45.3	46.3	51.4	55.9	61.2	67.9	70.6	70.8	66.7	60.0	50.8	46.4	(6)	
	DBStd	11.12	6.80	6.67	6.23	5.63	5.92	5.82	5.09	5.07	5.54	6.31	6.42	6.94	(7)	
	HDD50	600	173	135	57	9	1	0	0	0	0	8	66	151	(8)	
	HDD65	3252	612	525	421	280	148	34	9	5	43	174	425	576	(9)	
	CDD50	3463	26	30	102	185	349	537	638	645	502	319	91	39	(10)	
	CDD65	640	0	0	0	6	31	121	182	185	95	20	0	0	(11)	
	CDH74	5139	0	1	17	115	359	986	1361	1383	763	150	4	0	(12)	
	CDH80	1746	0	0	0	22	109	362	476	515	238	24	0	0	(13)	
(14) Wind	WSAvg	4.8	4.9	5.0	5.5	5.3	5.1	5.0	4.8	4.4	4.1	4.0	4.5	4.7	(14)	
(15) Precipitation	PrecAvg	50.7	5.1	4.2	3.4	4.6	3.9	3.0	2.6	2.9	4.1	4.9	7.2	4.8	(15)	
	PrecMax	67.8	13.0	8.8	7.6	11.1	10.5	7.9	5.9	9.2	9.0	10.6	15.9	8.0	(16)	
	PrecMin	34.6	0.4	0.7	0.5	1.3	1.2	0.6	0.5	0.6	1.1	0.9	1.2	0.5	(17)	
	PrecStd	8.1	3.1	2.3	2.0	2.5	1.9	1.8	1.6	1.9	2.0	2.8	4.0	2.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.8	69.2	76.5	83.3	88.9	94.4	95.2	98.4	90.8	83.5	72.2	67.1	(19)	
		MCWB	54.7	54.8	57.5	63.0	68.0	73.9	73.9	72.7	70.7	66.6	60.8	55.6	(20)	
	2%	DB	60.7	64.5	71.4	77.1	82.7	88.6	89.8	90.7	86.2	77.8	67.6	62.7	(21)	
		MCWB	53.3	53.1	56.4	60.2	65.5	70.9	73.1	72.8	68.9	64.9	58.2	54.0	(22)	
	5%	DB	57.6	60.6	67.1	72.2	77.3	84.0	85.2	85.5	82.3	74.1	63.4	59.3	(23)	
		MCWB	52.3	51.7	55.0	58.3	63.8	69.3	70.9	71.0	67.9	63.5	57.0	52.9	(24)	
	10%	DB	55.3	56.8	63.0	67.3	72.9	79.6	81.4	81.5	78.3	70.4	60.2	56.3	(25)	
		MCWB	51.7	50.1	53.0	56.3	61.8	67.2	69.6	69.3	66.5	62.1	55.6	51.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.8	57.2	60.0	64.1	70.0	75.9	76.6	76.7	73.7	69.0	63.5	57.4	(27)	
		MCDB	60.4	65.9	71.0	78.0	83.2	89.4	88.7	89.8	86.1	77.5	68.5	62.5	(28)	
	2%	WB	55.3	54.6	57.8	61.6	67.2	72.8	74.3	74.1	71.2	66.6	60.5	55.5	(29)	
		MCDB	58.6	61.0	68.2	73.9	79.7	86.0	86.3	85.7	81.0	74.7	65.3	60.5	(30)	
	5%	WB	53.6	53.0	55.8	59.3	65.0	70.3	72.4	72.0	69.4	64.9	58.2	53.9	(31)	
		MCDB	56.6	58.1	64.3	69.6	75.3	80.9	82.8	83.0	78.7	71.4	62.1	57.8	(32)	
	10%	WB	51.8	51.5	54.1	57.5	62.9	68.3	70.6	70.3	67.6	63.3	56.2	52.4	(33)	
		MCDB	54.7	56.1	61.1	65.1	70.7	77.2	79.2	79.4	75.7	68.8	59.5	55.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	16.9	18.2	18.5	17.8	18.1	18.3	19.2	20.4	18.5	14.6	14.4	(35)	
		MCDBR	16.8	24.4	26.3	28.2	27.7	27.0	26.1	26.9	26.7	24.1	19.9	18.6	(36)	
	5% WB	MCWBR	11.2	14.1	12.9	12.9	12.8	11.8	11.3	11.1	11.3	12.2	12.0	11.5	(37)	
		MCWBR	13.9	19.6	21.8	24.0	23.5	23.3	22.8	23.4	22.8	20.3	17.1	15.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.328	0.343	0.376	0.402	0.410	0.423	0.414	0.412	0.387	0.368	0.343	0.324	(40)	
		taud	2.488	2.429	2.346	2.283	2.306	2.305	2.335	2.347	2.403	2.459	2.474	2.490	(41)	
	Ebn at Noon		254	269	272	274	274	270	271	267	266	256	245	243	(42)	
		Edh at Noon	23	28	35	40	40	41	39	37	33	27	23	21	(43)	
(44) All-Sky Solar Radiation	RadAvg		446	729	1115	1433	1681	1866	1854	1658	1350	877	527	416	(44)	
	RadStd		48	91	132	150	141	125	119	107	71	72	64	50	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page