

PAU PYRENEES AP, France

WMO: 076100

Lat: 43.3850N

Lon: 0.4164W

Elev: 616

StdP: 14.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.4	28.3	21.2	16.2	29.4	24.1	18.7	31.8	24.2	50.4	20.5	50.6	3.3	120	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.3	89.7	71.6	86.3	70.2	83.0	68.7	74.2	86.1	72.1	83.2	70.3	80.0	5.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.2	113.9	80.9	68.4	106.6	77.3	66.9	101.1	74.9	38.0	86.2	36.2	83.3	34.5	80.2	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	19.1	16.1	13.5	DB	21.0	96.5	3.4	3.1	18.6	98.8	16.6	100.6	14.7	102.4	12.2	104.7
(5)				WB	20.2	78.2	3.4	1.6	17.8	79.4	15.8	80.3	13.9	81.2	11.5	82.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.5	44.0	45.1	50.4	54.1	60.2	66.2	69.0	69.3	64.5	59.3	49.4	45.2	(6)
(7)		DBStd	11.03	6.38	6.90	6.25	5.80	6.38	6.25	5.35	5.52	5.48	6.29	6.32	6.89	(7)
(8)		HDD50	725	199	160	71	23	4	0	0	0	8	85	175		(8)
(9)		HDD65	3617	650	558	453	329	174	61	22	19	75	194	469	613	(9)
(10)		CDD50	3083	14	22	84	147	321	485	590	597	435	296	66	26	(10)
(11)		CDD65	499	0	0	0	2	27	95	147	151	60	17	0	0	(11)
(12)		CDH74	4432	0	2	9	61	319	911	1184	1223	549	171	3	0	(12)
(13)		CDH80	1444	0	0	0	8	79	324	400	457	147	29	0	0	(13)
(14)	Wind	WSAvg	5.5	5.6	5.9	6.2	6.3	6.1	5.8	5.4	4.9	4.5	4.5	5.1	5.2	(14)
(15)	Precipitation	PrecAvg	45.4	4.2	3.7	3.5	4.5	4.4	3.4	2.9	2.8	3.2	3.8	5.3	3.8	(15)
(16)		PrecMax	64.0	9.9	7.8	8.2	9.2	10.0	11.0	5.4	7.3	6.0	9.8	9.8	6.8	(16)
(17)		PrecMin	36.1	0.3	0.7	0.5	1.7	1.6	0.7	0.7	0.8	1.0	1.6	0.8	0.3	(17)
(18)		PrecStd	6.9	2.5	2.2	2.0	2.0	1.7	2.0	1.3	1.5	1.5	1.8	2.4	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.6	70.2	75.2	80.5	87.3	93.3	93.1	95.9	88.8	83.8	72.2	66.6	(19)
(20)		0.4%	MCWB	54.3	53.9	56.5	62.3	67.0	72.8	74.0	72.6	69.2	65.0	58.8	54.7	(20)
(21)		2%	DB	60.7	64.4	70.7	75.0	81.7	87.8	88.3	89.6	84.2	78.8	67.7	62.5	(21)
(22)		2%	MCWB	51.8	52.3	55.8	59.3	65.1	69.9	72.4	72.9	68.1	64.2	57.4	52.7	(22)
(23)		5%	DB	56.9	60.4	66.6	70.6	77.2	83.4	84.4	84.8	80.6	74.6	62.9	58.8	(23)
(24)		5%	MCWB	50.4	50.7	54.3	57.5	63.5	68.7	70.6	71.0	66.7	62.6	54.9	51.3	(24)
(25)		10%	DB	53.8	56.0	62.5	66.1	73.1	79.1	80.7	80.8	76.5	70.5	58.9	55.3	(25)
(26)		10%	MCWB	49.5	49.1	52.4	55.6	61.6	67.1	68.9	69.3	65.1	61.2	53.8	50.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.9	56.1	59.4	63.8	69.8	75.4	76.5	76.5	72.6	67.8	61.8	56.5	(27)
(28)		0.4%	MCDWB	61.4	65.2	70.3	76.2	82.9	87.7	88.8	88.3	84.6	77.7	68.0	62.5	(28)
(29)		2%	WB	53.7	53.7	56.8	60.9	66.9	72.2	73.9	74.1	70.0	65.6	58.4	54.4	(29)
(30)		2%	MCDWB	57.9	61.3	67.2	71.9	78.6	84.3	85.6	85.8	80.6	74.8	64.6	59.6	(30)
(31)		5%	WB	51.7	51.8	54.9	58.6	64.6	69.7	71.7	72.2	68.0	63.9	56.4	52.5	(31)
(32)		5%	MCDWB	55.5	57.6	64.1	68.1	74.8	80.7	82.2	82.9	76.8	71.8	61.3	57.0	(32)
(33)		10%	WB	49.8	50.1	53.3	56.5	62.4	67.7	69.8	70.1	66.2	62.2	54.4	50.8	(33)
(34)		10%	MCDWB	53.0	55.3	61.0	64.3	71.0	77.5	78.6	78.8	73.9	68.8	58.3	54.6	(34)
(35)	Mean Daily Temperature Range		MDBR	15.3	17.0	18.5	18.1	18.0	18.6	18.6	19.3	20.0	19.0	15.8	16.2	(35)
(36)		5% DB	MCDBR	20.9	25.5	26.5	26.7	26.2	27.5	26.8	27.2	26.6	25.6	22.7	21.5	(36)
(37)			MCWBR	13.5	15.0	13.9	13.5	12.2	12.3	12.5	12.3	12.1	12.8	13.5	13.5	(37)
(38)			MCDBR	17.3	20.6	22.7	23.6	23.3	23.5	23.6	24.0	22.5	21.5	18.8	17.9	(38)
(39)		5% WB	MCWBR	12.3	13.3	12.5	12.6	11.6	11.7	12.0	11.7	11.1	11.5	12.3	12.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.310	0.325	0.361	0.386	0.397	0.409	0.400	0.400	0.373	0.352	0.326	0.307	(40)	
(41)		taud	2.499	2.441	2.359	2.296	2.310	2.309	2.337	2.347	2.412	2.475	2.498	2.505	(41)	
(42)		Ebn at Noon	262	276	278	279	278	274	275	271	271	263	253	252	(42)	
(43)		Edh at Noon	23	28	34	40	40	40	39	37	32	27	23	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	482	763	1138	1430	1661	1863	1873	1669	1365	904	558	445	(44)	
(45)		RadStd	45	92	125	151	141	126	123	110	65	75	64	51	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page