

ST GIRONS ANTICHAN AP, France

WMO: 076270

Lat: 43.0053N

Lon: 1.1069E

Elev: 417

StdP: 96.41

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.0	-3.1	-7.9	2.0	-2.7	-6.2	2.3	-1.0	9.4	8.9	8.4	8.3	1.5	300	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	31.5	21.4	29.5	20.8	27.7	19.9	22.7	29.2	21.6	27.7	20.6	26.4	2.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	16.0	26.5	19.5	15.0	25.0	18.6	14.2	23.7	69.1	29.2	64.8	27.7	61.3	26.3	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.6	6.4	5.4	-8.0	35.0	2.2	1.8	-9.5	36.3	-10.8	37.4	-12.0	38.4	-13.6	39.8		
			-8.4	25.1	2.1	0.7	-10.0	25.6	-11.2	26.1	-12.4	26.5	-14.0	27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.5	5.4	6.1	9.0	11.0	14.5	18.2	20.1	20.1	17.0	13.9	8.4	6.1	(6)
(7)		DBStd	6.26	3.46	3.86	3.41	3.27	3.36	3.38	2.89	2.93	2.97	3.40	3.47	3.51	(7)
(8)		HDD10.0	551	145	114	58	26	4	0	0	0	8	68	127		(8)
(9)		HDD18.3	2328	400	342	289	220	127	43	16	14	60	140	297	380	(9)
(10)		CDD10.0	1477	4	6	28	57	142	247	312	314	210	130	22	5	(10)
(11)		CDD18.3	211	0	0	0	0	7	40	70	70	20	4	0	0	(11)
(12)		CDH23.3	2049	0	0	2	18	96	405	616	647	217	48	1	0	(12)
(13)		CDH26.7	633	0	0	0	1	16	118	201	242	50	5	0	0	(13)
(14)	Wind	WSAvg	2.1	2.2	2.4	2.4	2.1	1.9	2.0	1.8	1.8	1.8	2.0	2.0	(14)	
(15)	Precipitation	PrecAvg	907	77	64	67	98	100	74	57	62	68	75	92	71	(15)
(16)		PrecMax	1249	185	145	132	208	180	224	114	122	160	292	236	138	(16)
(17)		PrecMin	715	9	11	12	37	50	20	16	12	20	23	11	6	(17)
(18)		PrecStd	118	48	37	29	41	36	41	26	24	37	50	43	38	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.3	20.2	22.8	25.9	28.7	32.6	33.7	35.0	30.5	27.1	21.5	17.9	(19)
(20)			MCWB	11.1	10.9	12.6	16.3	19.4	22.2	21.8	21.2	20.0	17.4	14.1	11.3	(20)
(21)		2%	DB	14.6	17.3	20.2	22.8	25.9	29.7	30.9	31.7	28.0	24.5	18.9	15.3	(21)
(22)			MCWB	9.8	10.3	12.2	14.5	18.3	21.1	21.5	21.2	19.0	17.0	12.6	9.9	(22)
(23)		5%	DB	12.9	14.8	18.1	20.5	23.7	27.7	28.9	29.4	25.9	22.4	16.4	13.4	(23)
(24)			MCWB	9.0	9.1	11.3	13.4	16.9	20.1	20.8	20.9	18.1	16.2	11.6	9.4	(24)
(25)		10%	DB	11.1	12.5	15.8	18.2	21.6	25.7	26.8	27.0	23.7	20.3	14.1	11.6	(25)
(26)			MCWB	8.0	8.4	10.2	12.3	15.8	19.1	20.0	20.0	17.5	15.3	10.6	8.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	12.2	14.2	16.7	20.6	23.9	23.9	23.9	21.6	19.2	15.0	12.2	(27)
(28)			MCD B	15.6	17.8	20.1	24.0	26.6	30.5	30.6	30.6	27.9	24.5	19.7	15.9	(28)
(29)		2%	WB	10.7	10.9	12.8	15.2	18.8	22.0	22.5	22.5	20.1	17.8	13.4	10.9	(29)
(30)			MCD B	13.5	15.5	18.4	21.7	24.8	28.2	29.0	29.0	26.4	22.6	17.3	14.0	(30)
(31)		5%	WB	9.5	9.8	11.7	14.0	17.5	20.6	21.4	21.4	18.9	16.7	12.2	9.9	(31)
(32)			MCD B	12.1	13.6	17.1	19.5	22.6	26.3	27.3	27.5	24.2	21.2	15.3	12.7	(32)
(33)		10%	WB	8.2	8.7	10.7	12.7	16.2	19.5	20.5	20.4	17.8	15.7	11.1	8.7	(33)
(34)			MCD B	10.6	12.1	15.3	17.3	20.6	24.7	25.7	26.1	22.4	19.5	13.8	11.2	(34)
(35)	Mean Daily Temperature Range	MDBR	9.3	9.8	10.9	10.6	10.3	10.4	10.5	10.9	11.4	10.9	9.6	9.7	(35)	
(36)		5% DB	MCD BR	12.5	14.6	15.2	15.3	14.6	14.8	15.2	16.1	15.4	14.5	13.6	12.7	(36)
(37)			MCWBR	8.0	8.8	8.6	8.4	8.0	7.7	7.4	7.5	7.4	8.0	8.4	8.3	(37)
(38)		5% WB	MCD BR	10.7	12.6	13.3	14.0	13.0	13.2	13.2	13.8	13.3	12.8	11.7	10.9	(38)
(39)			MCWBR	7.3	8.0	7.9	8.0	7.5	7.3	7.0	7.2	6.9	7.4	7.6	7.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.303	0.320	0.366	0.386	0.401	0.414	0.406	0.406	0.371	0.354	0.323	0.302	(40)	
(41)		taud	2.499	2.437	2.327	2.286	2.289	2.286	2.316	2.321	2.412	2.459	2.494	2.508	(41)	
(42)		Ebn at Noon	841	879	872	879	873	860	862	850	858	828	805	806	(42)	
(43)		Edh at Noon	71	89	112	126	130	130	125	121	102	86	71	65	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.71	2.61	3.81	4.75	5.44	6.24	6.31	5.61	4.48	3.05	1.93	1.56	(44)	
(45)		RadStd	0.16	0.30	0.36	0.47	0.43	0.39	0.37	0.32	0.22	0.26	0.20	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page