

ALBI LE SEQUESTRE AP, France

WMO: 076320

Lat: 43.9147N

Lon: 2.1164E

Elev: 172

StdP: 99.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.7	-3.0	-8.1	1.9	-1.6	-6.1	2.3	-0.2	9.4	10.1	8.2	10.3	1.1	90	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	34.3	20.7	32.3	20.3	30.5	19.6	22.1	30.6	21.3	29.5	20.6	28.3	3.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.5	25.5	18.7	13.8	24.4	18.0	13.2	23.6	65.5	30.8	62.6	29.5	59.9	28.5	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.1	6.9	5.9	DB	-6.7	37.2	2.2	2.1	-8.3	38.7	-9.6	39.9	-10.8	41.1	-12.4	42.6	(4)
			WB	-7.2	23.5	2.2	0.6	-8.8	23.9	-10.1	24.3	-11.3	24.6	-12.9	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	5.6	6.3	9.6	12.3	16.1	20.4	22.5	22.3	18.5	14.9	9.0	6.0
	DBStd	7.03	3.55	3.83	3.27	3.16	3.35	3.64	3.08	3.36	3.31	3.73	3.86	3.90
	HDD10.0	509	139	110	47	13	1	0	0	0	0	7	62	131
	HDD18.3	2109	393	337	270	181	84	21	4	38	115	279	382	
	CDD10.0	1853	4	6	35	83	192	311	387	381	256	159	33	7
	CDD18.3	411	0	0	0	1	17	81	132	127	43	9	0	0
	CDH23.3	4207	0	0	3	34	199	845	1354	1291	413	68	0	0
	CDH26.7	1681	0	0	0	4	44	329	591	585	123	6	0	0
Wind	WSAvg	2.4	2.3	2.4	2.7	2.7	2.6	2.5	2.6	2.3	2.1	2.2	2.2	2.1
Precipitation	PrecAvg	847	72	61	60	94	88	73	51	56	67	72	82	72
	PrecMax	1128	158	129	128	194	164	276	109	109	165	204	166	144
	PrecMin	645	7	8	12	21	33	15	10	16	18	21	11	8
	PrecStd	129	36	37	30	48	36	50	27	25	37	39	37	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.7	19.2	23.2	27.0	30.3	35.6	36.2	37.9	32.1	27.5	21.1	17.1
		MCWB	11.2	11.6	13.0	15.9	18.6	21.3	20.7	20.6	19.3	18.1	15.0	12.2
	2%	DB	14.2	16.4	20.3	23.8	27.7	32.2	34.0	34.7	29.9	25.2	18.9	15.1
		MCWB	10.6	10.5	12.3	14.8	17.7	20.3	20.8	20.6	18.5	17.4	13.9	11.4
	5%	DB	12.7	14.2	18.1	21.5	25.6	30.2	32.0	32.3	27.9	23.3	17.0	13.3
		MCWB	9.8	9.6	11.4	13.5	16.8	19.5	20.3	20.3	18.1	16.7	13.1	10.4
	10%	DB	11.1	12.3	16.0	19.2	23.3	28.3	30.1	30.0	25.7	21.5	15.0	11.8
		MCWB	9.0	8.9	10.4	12.5	15.8	18.8	19.7	19.8	17.4	16.1	12.2	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.5	12.6	14.6	17.0	20.4	22.9	23.1	23.1	21.4	19.3	15.8	13.0
		MCDB	14.2	17.2	20.7	25.0	28.2	32.1	31.8	31.7	29.0	25.1	20.0	15.7
	2%	WB	11.2	11.2	13.1	15.4	18.7	21.6	22.1	22.0	20.1	18.4	14.6	12.0
		MCDB	13.4	14.8	18.4	22.3	25.9	29.8	30.4	30.7	27.0	23.2	17.8	14.3
	5%	WB	10.2	10.3	12.1	14.2	17.5	20.5	21.3	21.1	19.1	17.5	13.5	11.0
		MCDB	12.1	13.2	16.6	19.8	23.7	28.2	29.3	29.6	25.3	21.9	16.1	12.9
	10%	WB	9.1	9.2	11.1	13.1	16.4	19.6	20.5	20.3	18.1	16.6	12.5	9.9
		MCDB	10.8	11.9	15.2	17.9	21.9	26.5	28.1	28.2	23.7	20.6	14.7	11.6
Mean Daily Temperature Range	5% DB	MDBR	7.4	9.3	10.8	11.1	10.9	11.6	12.1	12.4	11.9	10.4	8.0	7.8
		MCDBR	10.3	13.3	15.2	15.7	15.0	15.3	15.9	16.4	15.3	13.1	11.3	10.4
		MCWBR	7.0	8.1	8.4	7.9	7.0	6.1	5.5	5.7	6.1	6.3	6.9	7.0
	5% WB	MCDBR	8.3	11.4	12.6	13.5	13.0	13.5	13.5	13.7	12.4	10.9	9.4	8.8
	MCWBR	6.0	7.3	7.3	7.1	6.6	5.9	5.2	5.3	5.5	5.6	6.1	6.3	
Clear-Sky Solar Irradiance	taub	0.313	0.329	0.365	0.396	0.403	0.412	0.404	0.405	0.376	0.362	0.333	0.311	
	taud	2.484	2.431	2.340	2.253	2.286	2.299	2.319	2.330	2.393	2.439	2.472	2.490	
	Ebn at Noon	816	863	870	867	869	860	862	849	848	811	781	781	
	Edh at Noon	71	88	110	130	129	128	124	119	103	87	72	65	
All-Sky Solar Radiation	RadAvg	1.43	2.35	3.53	4.63	5.38	6.31	6.28	5.53	4.35	2.82	1.65	1.31	
	RadStd	0.15	0.28	0.34	0.54	0.43	0.48	0.46	0.36	0.26	0.25	0.19	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page