

CARCASSONNE AP, France

WMO: 076350

Lat: 43.2153N

Lon: 2.2956E

Elev: 433

StdP: 14.47

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.2	30.0	20.0	15.2	32.3	23.2	17.8	34.2	29.3	46.6	26.9	46.5	9.5	290	0.574

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	91.8	69.4	88.5	68.5	85.6	67.7	72.7	84.4	71.4	82.2	70.1	80.7	10.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	110.1	76.6	68.0	104.5	76.1	66.5	99.3	75.1	36.6	84.6	35.4	82.3	34.3	80.6	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.7	23.3	21.2	DB	23.7	96.8	3.5	3.1	21.2	99.1	19.1	100.9	17.1	102.6	14.6	104.9
			WB	22.6	74.8	3.6	1.2	20.0	75.7	17.9	76.4	15.8	77.0	13.2	77.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	43.9	44.8	50.4	54.8	61.1	68.9	73.3	72.8	66.4	60.1	50.2	45.0
	DBStd	12.00	6.05	6.25	5.42	5.37	5.59	5.97	5.35	5.11	5.21	5.97	6.36	6.39
	HDD50	696	201	159	61	17	2	0	0	0	0	5	74	177
	HDD65	3443	653	565	452	307	145	29	7	5	44	170	445	621
	CDD50	3519	13	14	75	162	346	567	723	708	493	318	79	21
	CDD65	789	0	0	0	2	24	146	265	247	87	18	0	0
	CDH74	6589	0	0	2	34	218	1242	2354	2077	599	63	0	0
	CDH80	2351	0	0	0	3	45	416	934	800	146	7	0	0
	WSAvg	10.7	10.9	11.6	11.8	11.7	11.2	10.5	10.5	9.9	9.6	10.1	10.2	10.1
	PrecAvg	28.7	2.6	2.8	2.6	2.8	2.7	1.9	1.0	1.7	2.0	3.1	2.4	3.0
(15) Precipitation	PrecMax	41.7	5.9	5.3	7.4	5.3	8.1	4.6	2.6	4.7	7.1	12.5	9.1	7.5
	PrecMin	15.7	0.6	0.9	0.0	1.0	0.5	0.2	0.0	0.1	0.0	0.2	0.4	0.5
	PrecStd	5.6	1.3	1.1	1.7	1.3	1.7	1.2	0.7	1.1	1.8	3.1	2.2	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	65.2	72.8	78.1	85.1	93.1	95.7	97.3	89.4	79.8	68.5	60.9
		MCWB	54.1	53.7	55.4	60.2	65.4	70.4	69.9	70.3	67.6	64.0	59.5	55.1
	2%	DB	57.3	59.8	67.2	72.9	79.5	88.2	91.6	92.0	84.0	75.1	64.8	58.3
		MCWB	52.2	51.5	54.1	57.9	63.2	68.0	69.2	69.8	65.7	63.2	58.2	53.9
	5%	DB	54.8	56.5	63.0	68.6	75.6	84.8	88.5	88.0	80.4	71.7	62.0	56.2
		MCWB	51.1	50.3	52.5	56.1	61.7	67.5	68.7	68.7	64.9	62.5	57.2	52.7
	10%	DB	52.8	53.9	59.7	65.1	72.1	81.2	85.5	84.5	77.1	68.9	59.6	54.2
		MCWB	49.7	49.3	51.3	54.7	60.3	66.4	67.7	68.2	63.8	62.0	55.8	51.2
	0.4%	WB	55.5	55.4	58.1	62.1	67.9	73.4	73.9	74.6	71.2	68.0	61.7	56.6
		MCDB	59.5	61.6	67.5	74.6	82.1	87.3	87.0	86.2	79.7	72.6	65.6	59.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	53.2	53.0	55.6	59.6	65.1	71.2	72.4	72.9	69.4	66.3	59.8	54.8
		MCDB	56.0	57.7	63.5	69.9	75.7	83.4	84.4	83.8	76.9	70.3	63.4	57.4
	5%	WB	51.7	51.4	54.0	57.5	63.1	69.3	71.1	71.6	68.0	64.9	58.1	53.3
		MCDB	54.4	55.1	60.4	65.6	72.2	80.5	82.6	81.7	74.9	68.9	61.3	55.8
	10%	WB	49.9	49.9	52.6	55.9	61.5	67.6	69.7	70.3	66.3	63.4	56.2	51.5
		MCDB	52.4	53.6	58.0	62.7	69.5	78.2	81.2	80.2	74.1	67.7	59.2	54.0
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	13.5	16.0	16.9	17.3	19.2	20.3	20.4	18.9	15.0	12.6	11.7
		MCDBR	14.2	18.9	23.4	24.4	24.7	25.7	26.3	27.5	25.1	19.0	15.8	13.6
		MCWBR	9.9	11.9	12.4	12.0	11.3	9.8	9.1	9.3	10.4	9.4	9.9	9.7
	5% WB	MCDBR	11.9	16.4	18.3	19.9	20.4	21.5	20.8	20.9	17.7	13.0	12.7	11.6
		MCWBR	9.1	11.3	10.5	10.6	10.4	9.1	8.2	9.0	8.9	7.3	8.8	8.8
(40) Clear-Sky Solar Irradiance	taub		0.313	0.328	0.367	0.392	0.402	0.411	0.406	0.406	0.378	0.364	0.334	0.311
	taud		2.509	2.457	2.362	2.300	2.321	2.328	2.347	2.355	2.418	2.464	2.500	2.516
	Ebn at Noon		262	276	276	277	277	273	273	270	270	259	251	252
	Edh at Noon		23	28	34	39	40	40	38	37	32	27	23	21
(44) All-Sky Solar Radiation	RadAvg		502	790	1161	1495	1728	2016	2025	1789	1402	924	571	454
	RadStd		48	86	102	154	133	137	130	108	76	86	59	55

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page