

BEZIERS CAP D'AGDE AP, France

WMO: 076380

Lat: 43.3222N

Lon: 3.3527E

Elev: 52

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.1	30.0	13.7	11.0	38.2	19.1	14.4	38.7	31.4	51.3	27.6	52.5	5.9	270	0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	90.7	68.5	88.1	67.9	85.5	67.3	74.0	82.1	72.6	80.5	71.3	79.3	11.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.6	117.1	78.0	70.2	111.1	76.5	68.6	105.4	75.5	37.6	81.8	36.2	80.7	35.1	79.2	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	23.1	20.6	23.7	96.2	3.3	3.6	21.3	98.8	19.4	100.9	17.6	102.9	15.2	105.5
			21.7	75.8	3.9	1.7	18.9	77.0	16.6	78.0	14.4	79.0	11.6	80.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.5	45.8	46.0	51.5	56.9	62.9	70.6	75.5	74.1	68.2	61.8	53.1	46.7	(6)
(7)		DBStd	11.76	5.87	6.17	5.18	4.53	4.50	5.00	3.88	3.94	4.68	5.62	6.48	6.15	(7)
(8)		HDD50	520	156	135	44	3	0	0	0	0	0	3	42	137	(8)
(9)		HDD65	2966	596	532	419	245	92	9	0	0	21	127	358	567	(9)
(10)		CDD50	3988	25	22	89	210	401	617	790	748	547	368	135	36	(10)
(11)		CDD65	959	0	0	0	2	29	175	325	283	118	27	0	0	(11)
(12)		CDH74	7780	0	0	3	32	229	1396	2913	2367	748	91	1	0	(12)
(13)		CDH80	2422	0	0	0	4	42	425	1024	751	161	15	0	0	(13)
(14)	Wind	WSAvg	9.4	9.6	10.2	10.5	9.9	10.0	9.2	9.4	8.9	8.2	8.9	9.5	8.6	(14)
(15)	Precipitation	PrecAvg	25.3	2.1	2.0	1.9	2.2	1.8	1.1	0.7	1.3	2.9	3.7	3.2	2.3	(15)
(16)		PrecMax	49.6	9.5	9.3	7.6	6.6	6.3	3.9	2.3	3.5	7.8	9.4	10.1	9.0	(16)
(17)		PrecMin	12.2	0.0	0.1	0.0	0.2	0.2	0.1	0.1	0.0	0.6	0.7	0.1	0.2	(17)
(18)		PrecStd	7.8	2.5	2.1	1.9	1.7	1.3	0.9	0.6	0.9	1.9	2.4	2.9	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.6	66.8	71.9	77.4	85.2	92.9	94.2	94.4	88.7	81.4	70.8	63.7	(19)
(20)		0.4%	MCWB	55.9	53.5	55.5	60.0	66.2	70.2	68.9	70.0	65.8	63.5	60.8	55.6	(20)
(21)		2%	DB	60.7	61.1	66.8	73.1	79.2	88.8	90.8	89.6	84.5	76.2	66.8	60.8	(21)
(22)		2%	MCWB	53.1	51.5	53.8	58.7	62.3	68.7	68.3	68.5	65.1	63.4	59.9	54.6	(22)
(23)		5%	DB	57.7	58.1	63.8	69.8	76.1	84.6	88.3	86.7	81.1	73.2	64.8	58.9	(23)
(24)		5%	MCWB	51.5	50.2	52.7	56.7	61.0	66.6	68.4	67.4	65.0	63.1	59.4	53.8	(24)
(25)		10%	DB	55.1	55.7	60.8	66.6	73.0	81.4	85.7	84.1	78.3	70.8	63.0	56.9	(25)
(26)		10%	MCWB	49.9	49.7	51.1	55.5	59.9	65.7	67.9	67.3	64.2	62.8	58.0	51.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.7	55.3	57.6	63.9	67.3	73.3	76.3	75.7	72.5	70.0	63.6	58.2	(27)
(28)		0.4%	MCDWB	63.1	61.0	66.9	73.3	79.6	86.0	84.7	82.6	77.1	72.9	67.1	61.3	(28)
(29)		2%	WB	54.5	53.4	55.7	61.0	65.2	71.0	74.3	74.1	71.0	67.6	62.0	56.3	(29)
(30)		2%	MCDWB	58.9	57.5	62.5	69.1	74.9	82.2	82.8	81.2	75.5	71.2	65.4	59.5	(30)
(31)		5%	WB	52.7	52.2	54.5	58.9	63.6	69.5	72.6	72.7	69.5	66.2	60.6	54.6	(31)
(32)		5%	MCDWB	56.7	56.7	60.3	66.8	71.7	79.7	81.2	80.1	74.6	69.7	64.0	57.9	(32)
(33)		10%	WB	50.7	50.6	53.4	57.3	62.1	68.1	71.3	71.4	67.8	64.8	58.9	52.7	(33)
(34)		10%	MCDWB	54.5	55.3	58.6	63.3	69.6	77.8	79.8	79.1	74.5	68.6	62.3	56.3	(34)
(35)	Mean Daily Temperature Range		MDBR	14.8	16.5	17.0	16.8	17.6	18.6	19.1	19.3	18.7	15.6	14.7	15.3	(35)
(36)		5% DB	MCDBR	16.9	19.7	21.7	22.3	22.9	23.4	22.7	23.2	23.0	19.2	15.5	16.0	(36)
(37)		5% DB	MCWBR	11.2	12.4	12.0	10.8	10.3	8.8	8.1	8.7	9.3	10.0	10.0	10.8	(37)
(38)		5% WB	MCDBR	14.5	17.1	17.4	18.4	18.3	19.5	17.1	17.0	14.5	12.0	11.4	12.8	(38)
(39)		5% WB	MCWBR	10.5	11.8	10.7	10.0	9.3	8.6	8.1	9.4	8.1	7.8	8.2	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.320	0.334	0.374	0.403	0.412	0.416	0.411	0.411	0.392	0.380	0.343	0.317	(40)	
(41)		taud	2.498	2.456	2.362	2.289	2.317	2.339	2.356	2.364	2.399	2.437	2.486	2.512	(41)	
(42)		Ebn at Noon	259	273	274	273	274	272	272	268	265	252	246	249	(42)	
(43)		Edh at Noon	23	28	34	40	40	39	38	37	33	28	23	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	531	832	1214	1583	1895	2194	2202	1891	1443	905	594	468	(44)	
(45)		RadStd	58	83	101	134	130	114	102	98	85	95	73	52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page