

BEZIERS CAP D'AGDE AP, France

WMO: 076380

Lat: 43.3222N

Lon: 3.3527E

Elev: 16

StdP: 101.13

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.7	(c) -1.1	(d) -10.2	(e) 1.6	(f) 3.5	(g) -7.1	(h) 2.1	(i) 3.7	(j) 14.0	(k) 10.7	(l) 12.3	(m) 11.4	(n) 2.7	(o) 270	(p) 0.506

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	32.6	20.3	31.1	19.9	29.7	19.6	23.4	27.8	22.5	27.0	21.8	26.3	5.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.0	16.7	25.5	21.2	15.9	24.7	20.4	15.1	24.2	69.5	27.7	66.3	27.0	63.7	26.2	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.5	(b) 10.3	(c) 9.2	(e) -4.6	(f) 35.7	(g) 1.8	(h) 2.0	(i) -5.9	(j) 37.1	(k) -7.0	(l) 38.3	(m) -8.0	(n) 39.4	(o) -9.3	(p) 40.8		
(a) 11.5	(b) 10.3	(c) 9.2	(e) -5.7	(f) 24.3	(g) 2.2	(h) 1.0	(i) -7.3	(j) 25.0	(k) -8.6	(l) 25.6	(m) -9.8	(n) 26.1	(o) -11.4	(p) 26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	7.7	7.8	10.8	13.8	17.2	21.4	24.2	23.4	20.1	16.6	11.7	8.2		
	DBStd	6.53	3.26	3.43	2.88	2.52	2.50	2.78	2.16	2.19	2.60	3.12	3.60	3.42		
	HDD10.0	289	87	75	24	2	0	0	0	0	0	2	23	76		
	HDD18.3	1648	331	296	233	136	51	5	0	0	12	71	199	315		
	CDD10.0	2216	14	12	49	117	223	343	439	416	304	204	75	20		
	CDD18.3	533	0	0	0	1	16	97	181	157	66	15	0	0		
	CDH23.3	4322	0	0	2	18	127	776	1618	1315	416	51	1	0		
	CDH26.7	1346	0	0	0	2	23	236	569	417	89	8	0	0		
(14) Wind	WSAvg	4.2	4.3	4.5	4.7	4.4	4.5	4.1	4.2	4.0	3.6	4.0	4.3	3.9		
(15) Precipitation	PrecAvg	642	54	50	47	56	46	29	19	34	74	93	82	58		
	PrecMax	1261	241	235	192	168	161	98	59	90	197	240	257	229		
	PrecMin	310	0	2	0	4	4	2	3	0	15	17	2	4		
	PrecStd	197	64	53	48	43	34	24	15	24	49	61	74	61		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	19.3	22.2	25.2	29.6	33.9	34.5	34.7	31.5	27.5	21.6	17.6		
		MCWB	13.3	11.9	13.1	15.6	19.0	21.2	20.5	21.1	18.8	17.5	16.0	13.1		
	2%	DB	16.0	16.2	19.3	22.8	26.2	31.5	32.7	32.0	29.2	24.5	19.3	16.0		
		MCWB	11.7	10.8	12.1	14.8	16.8	20.4	20.2	20.3	18.4	17.5	15.5	12.6		
	5%	DB	14.3	14.5	17.7	21.0	24.5	29.2	31.3	30.4	27.3	22.9	18.2	14.9		
		MCWB	10.8	10.1	11.5	13.7	16.1	19.2	20.2	19.7	18.3	17.3	15.2	12.1		
	10%	DB	12.9	13.2	16.0	19.2	22.8	27.5	29.8	29.0	25.7	21.5	17.2	13.8		
		MCWB	10.0	9.8	10.6	13.1	15.5	18.7	20.0	19.6	17.9	17.1	14.4	11.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	12.9	14.2	17.7	19.6	22.9	24.6	24.3	22.5	21.1	17.6	14.5		
		MCDB	17.3	16.1	19.4	22.9	26.4	30.0	29.3	28.1	25.0	22.7	19.5	16.3		
	2%	WB	12.5	11.9	13.2	16.1	18.4	21.7	23.5	23.4	21.6	19.8	16.7	13.5		
		MCDB	14.9	14.2	17.0	20.6	23.8	27.9	28.2	27.3	24.1	21.8	18.6	15.3		
	5%	WB	11.5	11.2	12.5	14.9	17.5	20.8	22.6	22.6	20.8	19.0	15.9	12.6		
		MCDB	13.7	13.7	15.7	19.3	22.1	26.5	27.3	26.7	23.7	20.9	17.8	14.4		
	10%	WB	10.4	10.4	11.9	14.0	16.7	20.1	21.8	21.9	19.9	18.2	15.0	11.5		
		MCDB	12.5	12.9	14.8	17.4	20.9	25.4	26.6	26.2	23.6	20.3	16.8	13.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	9.2	9.5	9.3	9.8	10.3	10.6	10.7	10.4	8.7	8.2	8.5		
		MCDBR	9.4	10.9	12.0	12.4	12.7	13.0	12.6	12.9	12.8	10.7	8.6	8.9		
		MCWBR	6.2	6.9	6.6	6.0	5.7	4.9	4.5	4.8	5.2	5.6	5.5	6.0		
	5% WB	MCDBR	8.0	9.5	9.7	10.2	10.2	10.8	9.5	9.4	8.0	6.7	6.3	7.1		
		MCWBR	5.9	6.5	5.9	5.5	5.2	4.8	4.5	5.2	4.5	4.3	4.5	5.3		
(40) Clear-Sky Solar Irradiance	taub		0.320	0.334	0.374	0.403	0.412	0.416	0.411	0.411	0.392	0.380	0.343	0.317		
	taud		2.498	2.456	2.362	2.289	2.317	2.339	2.356	2.364	2.399	2.437	2.486	2.512		
	Ebn at Noon		815	862	863	862	863	858	857	846	834	796	776	784		
	Edh at Noon		71	87	108	126	126	124	120	116	104	89	72	65		
(44) All-Sky Solar Radiation	RadAvg		1.68	2.62	3.83	4.99	5.97	6.92	6.94	5.96	4.55	2.85	1.87	1.48		
	RadStd		0.18	0.26	0.32	0.42	0.41	0.36	0.32	0.31	0.27	0.30	0.23	0.16		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page