

SETE, France

WMO: 076410

Lat: 43.3972N

Lon: 3.6922E

Elev: 81

StdP: 100.36

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.3	1.3	-11.1	1.5	3.2	-8.3	1.9	3.6	13.7	9.4	11.7	9.3	5.3	320	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	31.2	20.3	29.8	19.9	28.5	19.6	23.6	27.0	22.8	26.3	22.0	25.3	4.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.7	17.6	25.4	21.7	16.5	24.6	20.9	15.7	24.0	70.9	26.8	67.7	26.2	64.7	25.3	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	9.6	8.2	-0.7	34.5	2.0	1.9	-2.1	35.9	-3.3	37.1	-4.5	38.1	-5.9	39.5		
(5)			-3.7	24.4	2.0	1.0	-5.2	25.1	-6.4	25.7	-7.5	26.3	-8.9	27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	8.2	8.6	11.5	14.5	17.7	22.1	24.4	23.8	20.7	17.1	12.3	9.2
	DBStd	6.39	3.07	3.33	2.85	2.64	2.72	2.94	2.30	2.14	2.40	2.93	3.14	3.20
	HDD10.0	217	72	58	16	1	0	0	0	0	0	1	15	53
	HDD18.3	1492	314	274	211	119	44	3	0	0	6	56	182	284
	CDD10.0	2364	16	18	64	136	238	364	448	429	321	221	83	28
	CDD18.3	600	0	0	0	4	24	117	189	171	77	18	1	0
	CDH23.3	3337	0	0	2	8	76	654	1310	1024	238	26	0	0
	CDH26.7	805	0	0	0	1	12	168	351	239	31	4	0	0
Wind	WSAvg	4.3	4.5	4.5	4.4	4.4	4.2	3.9	3.9	3.8	3.8	4.4	4.8	4.4
Precipitation	PrecAvg	610	49	45	44	54	45	29	17	31	76	92	73	54
	PrecMax	1105	208	192	193	142	147	135	59	102	195	199	233	198
	PrecMin	299	0	0	0	4	4	2	1	1	18	14	6	3
	PrecStd	174	58	45	46	36	34	30	14	24	48	52	65	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	17.6	20.8	24.5	28.2	32.7	33.7	32.8	29.4	26.0	20.2	16.7
		MCWB	11.9	10.9	12.4	15.1	18.5	20.9	20.2	21.3	19.1	17.1	15.2	12.7
	2%	DB	14.9	15.3	18.4	21.9	25.3	30.3	31.3	30.6	27.4	23.4	18.5	15.4
		MCWB	10.7	10.0	11.7	14.2	16.5	20.2	20.4	20.0	18.3	16.9	15.2	12.3
	5%	DB	13.5	13.7	16.9	20.2	23.5	28.5	30.0	29.1	25.8	21.9	17.4	14.5
		MCWB	10.3	9.6	10.9	13.4	15.9	19.7	20.1	19.4	17.8	17.1	14.8	11.8
	10%	DB	12.3	12.6	15.5	18.7	22.1	26.8	28.6	27.8	24.5	20.7	16.6	13.6
		MCWB	9.6	9.6	10.4	12.8	15.4	19.1	19.9	19.5	17.7	16.9	14.1	11.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	12.2	13.7	17.0	19.5	23.6	24.9	24.6	22.5	20.6	17.3	14.1
		MCDB	15.5	13.9	18.2	21.5	24.8	28.7	28.2	27.2	24.1	21.8	18.5	15.5
	2%	WB	11.8	11.6	12.7	15.6	18.4	22.5	23.9	23.5	21.5	19.7	16.3	13.2
		MCDB	13.7	13.2	15.9	19.5	22.7	26.6	27.0	26.7	23.5	21.0	17.6	14.7
	5%	WB	11.0	11.0	12.1	14.6	17.5	21.5	23.0	22.7	20.7	18.7	15.6	12.3
		MCDB	12.8	12.9	14.6	18.0	21.3	25.9	26.7	25.9	23.0	20.1	17.0	14.0
	10%	WB	10.1	10.2	11.6	13.9	16.6	20.6	22.1	21.9	19.9	18.1	14.6	11.4
		MCDB	12.2	12.4	14.0	17.1	20.2	25.1	25.7	24.9	22.4	19.6	16.3	13.3
Mean Daily Temperature Range	5% DB	MDBR	5.0	5.7	6.2	6.3	6.8	7.1	7.3	7.2	6.5	5.3	5.0	4.9
		MCDBR	5.7	6.6	7.5	8.0	8.7	8.9	8.9	8.9	7.9	6.7	5.1	5.1
		MCWBR	4.2	4.3	4.4	4.3	4.3	4.2	4.0	4.1	4.3	4.0	4.0	3.8
	5% WB	MCDBR	5.0	5.2	5.9	6.5	6.8	7.0	6.3	6.3	5.4	4.1	4.0	4.5
		MCWBR	4.3	4.1	4.0	4.0	4.0	3.9	3.8	4.3	4.1	3.4	3.7	3.9
Clear-Sky Solar Irradiance	taub		0.319	0.333	0.373	0.399	0.407	0.409	0.405	0.404	0.388	0.380	0.343	0.315
	taud		2.495	2.454	2.363	2.302	2.331	2.356	2.370	2.378	2.408	2.432	2.482	2.511
	Ebn at Noon		816	863	864	867	867	863	863	852	839	796	776	785
	Edh at Noon		71	87	108	124	124	122	119	114	103	89	72	65
All-Sky Solar Radiation	RadAvg		1.71	2.67	3.90	5.10	6.15	7.11	7.12	6.08	4.62	2.88	1.90	1.49
	RadStd		0.19	0.26	0.31	0.41	0.41	0.34	0.29	0.29	0.27	0.30	0.24	0.16

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page