

NIMES COURBESSAC AP, France

WMO: 076450

Lat: 43.8569N

Lon: 4.4064E

Elev: 62

StdP: 100.58

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.9	-0.6	-11.2	1.4	3.0	-8.7	1.8	3.1	10.6	8.5	9.5	7.5	2.6	0	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	34.6	21.0	33.0	20.5	31.5	20.1	23.0	30.1	22.2	29.1	21.5	28.3	3.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	15.9	25.1	20.2	15.0	24.6	19.3	14.2	24.3	68.2	30.0	65.2	29.1	62.5	28.3	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
9.3	8.2	7.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-3.8	37.5	1.8	2.0	-5.1	38.9	-6.1	40.1	-7.1	41.2	-8.5	42.7		
			-5.1	24.3	1.9	0.7	-6.5	24.8	-7.6	25.2	-8.7	25.5	-10.0	26.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	7.2	7.9	11.3	14.1	17.9	22.4	25.1	24.7	20.3	16.4	10.9	7.7
	DBStd	7.03	3.18	3.30	3.04	2.86	2.84	3.09	2.57	2.55	2.85	3.11	3.46	3.28
	HDD10.0	308	97	70	21	3	0	0	0	0	0	2	31	84
	HDD18.3	1673	346	291	219	131	42	3	0	0	12	74	224	329
	CDD10.0	2330	9	12	61	125	244	373	469	456	311	200	56	14
	CDD18.3	651	0	0	0	3	28	126	211	197	73	14	0	0
	CDH23.3	5994	0	0	3	37	246	1184	2112	1834	520	57	1	0
	CDH26.7	2416	0	0	0	3	49	457	956	801	143	7	0	0
Wind	WSAvg	3.2	3.1	3.3	3.4	3.4	3.3	3.3	3.3	3.1	3.0	3.0	3.1	2.8
Precipitation	PrecAvg	775	70	63	53	61	58	43	28	50	77	125	74	63
	PrecMax	1192	223	202	214	147	175	149	119	150	229	415	227	153
	PrecMin	390	0	1	0	2	1	0	1	3	0	12	0	1
	PrecStd	191	53	53	46	41	43	32	26	34	59	105	54	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	19.5	23.6	26.6	30.6	35.5	36.2	37.3	32.7	27.3	21.1	17.2
		MCWB	11.9	11.7	13.2	16.3	19.0	21.8	21.5	21.9	19.9	17.7	15.2	12.3
	2%	DB	15.3	16.9	20.7	24.2	28.0	33.1	34.5	34.6	30.0	24.7	18.8	15.3
		MCWB	10.4	10.6	12.4	14.9	17.7	20.7	20.9	21.0	19.1	17.6	14.6	11.7
	5%	DB	13.5	15.0	18.8	22.1	26.0	31.1	33.1	32.7	28.2	23.2	17.3	14.0
		MCWB	9.7	9.7	11.6	13.9	16.7	20.0	20.4	20.5	18.3	17.1	13.6	10.9
	10%	DB	12.1	13.4	17.2	20.2	24.2	29.3	31.6	31.0	26.4	21.7	16.1	12.8
		MCWB	9.0	8.9	10.8	12.8	15.9	19.1	20.1	20.1	17.7	16.5	13.2	10.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	12.5	14.5	17.4	20.5	23.5	23.8	24.0	22.0	20.2	16.8	14.0
		MCDB	15.9	16.9	20.4	25.0	28.1	32.8	31.4	29.9	26.7	23.1	19.0	15.6
	2%	WB	11.6	11.5	13.2	15.7	18.7	22.0	22.7	23.1	21.1	19.3	15.6	12.7
		MCDB	14.0	15.2	18.6	22.1	25.5	29.8	30.3	29.6	25.9	22.4	17.6	14.4
	5%	WB	10.5	10.7	12.4	14.6	17.7	20.9	22.0	22.4	20.2	18.3	14.7	11.7
		MCDB	12.7	14.0	17.3	20.4	24.0	28.8	29.3	28.8	25.1	21.7	16.7	13.4
	10%	WB	9.6	9.6	11.6	13.7	16.8	20.0	21.2	21.6	19.2	17.3	13.6	10.5
		MCDB	11.7	12.8	15.9	18.6	22.3	27.2	28.5	28.1	24.2	20.5	15.6	12.4
Mean Daily Temperature Range	5% DB	MDBR	7.9	9.0	10.2	10.4	10.7	11.6	12.1	11.9	10.7	9.0	8.1	7.7
		MCDBR	9.7	11.6	12.7	13.3	13.6	13.8	13.8	14.3	13.3	10.8	9.1	9.0
		MCWBR	6.3	6.8	6.5	6.4	6.0	5.3	4.7	4.9	5.3	5.4	5.8	6.0
	5% WB	MCDBR	8.1	10.3	11.2	12.1	12.0	13.2	12.4	12.3	11.0	8.8	7.6	7.4
		MCWBR	5.8	6.6	6.3	6.4	6.0	5.6	5.0	5.1	5.2	5.0	5.5	5.5
Clear-Sky Solar Irradiance	taub	0.323	0.342	0.380	0.398	0.407	0.407	0.401	0.400	0.386	0.387	0.349	0.320	
	taud	2.462	2.408	2.315	2.286	2.311	2.338	2.353	2.364	2.390	2.385	2.443	2.480	
	Ebn at Noon	802	847	853	866	866	865	865	854	838	782	760	769	
	Edh at Noon	73	91	113	126	126	123	120	115	104	92	74	66	
All-Sky Solar Radiation	RadAvg	1.68	2.64	3.94	5.16	6.21	7.20	7.16	6.13	4.67	2.90	1.86	1.46	
	RadStd	0.19	0.26	0.32	0.42	0.43	0.33	0.32	0.24	0.28	0.28	0.22	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page