

CAP POMEgues, France

WMO: 076520

Lat: 43.2651N

Lon: 5.2897E

Elev: 70

StdP: 100.49

Time Zone: 1.00 (EUC)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.4	1.8	-5.2	2.5	1.9	-3.4	2.9	3.3	26.4	4.8	25.8	6.2	9.4	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	28.6	22.0	27.3	21.9	26.3	21.5	24.2	26.5	23.4	25.7	22.7	25.1	5.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.4	25.6	22.7	17.5	25.0	21.9	16.7	24.3	73.1	26.7	70.1	25.8	67.4	25.2	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	20.7	17.9	-2.5	31.2	4.5	2.0	-5.7	32.6	-8.3	33.8	-10.8	35.0	-14.1	36.4
			-3.8	25.4	4.1	1.0	-6.8	26.1	-9.2	26.6	-11.5	27.2	-14.5	27.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	9.0	8.4	10.5	13.0	16.4	19.7	23.5	22.7	20.7	17.4	12.7	10.3	(6)
	DBStd	5.82	3.36	3.56	2.57	2.05	2.59	2.21	2.04	2.15	2.11	2.49	3.17	2.53	(7)
	HDD10.0	185	51	66	24	3	0	0	0	0	0	0	13	28	(8)
	HDD18.3	1523	290	279	242	159	70	12	0	1	6	47	168	250	(9)
	CDD10.0	2159	19	20	41	94	199	292	420	394	320	229	95	36	(10)
	CDD18.3	457	0	0	0	0	11	53	162	137	76	18	1	0	(11)
	CDH23.3	1558	0	0	0	0	9	83	788	551	120	6	0	0	(12)
	CDH26.7	184	0	0	0	0	0	4	119	57	3	0	0	0	(13)
(14) Wind	WSAvg	7.0	7.3	7.8	8.2	8.2	6.3	6.7	6.1	6.2	6.2	6.8	7.6	7.0	(14)
(15) Precipitation	PrecAvg	560	49	48	40	50	40	28	12	28	65	79	67	49	(15)
	PrecMax	863	136	226	103	157	121	97	85	132	231	307	194	137	(16)
	PrecMin	278	0	0	0	0	0	0	0	0	0	0	0	1	(17)
	PrecStd	153	36	41	27	35	32	24	19	27	60	67	47	36	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.9	16.4	18.6	19.6	24.5	27.4	31.9	29.5	27.8	24.1	20.3	17.0	(19)
		MCWB	12.1	12.9	13.7	13.8	17.6	21.9	23.3	22.3	20.4	18.9	14.5	14.6	(20)
	2%	DB	14.1	15.0	16.5	18.2	22.7	25.7	29.7	28.2	26.0	22.7	18.2	15.4	(21)
		MCWB	11.7	12.1	12.5	13.1	17.4	20.7	22.2	22.4	20.9	18.8	14.8	13.2	(22)
	5%	DB	13.4	13.7	15.2	17.0	21.5	24.1	27.8	27.1	24.9	21.9	17.5	14.6	(23)
		MCWB	11.3	11.2	12.0	12.5	17.2	19.6	21.8	22.5	20.2	18.6	14.5	12.6	(24)
	10%	DB	12.7	12.7	14.1	16.0	20.4	23.0	26.6	26.0	23.8	20.9	16.6	13.9	(25)
		MCWB	10.8	10.7	11.5	12.1	16.7	18.5	21.6	21.7	20.0	18.0	14.1	11.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.4	13.7	14.6	15.4	20.8	23.9	25.7	25.4	23.1	21.2	16.7	15.2	(27)
		MCDB	14.2	16.2	17.3	17.6	22.1	25.7	27.2	27.3	24.6	22.6	18.0	16.7	(28)
	2%	WB	12.5	12.7	13.2	14.3	19.1	22.0	24.3	24.2	22.4	20.1	15.9	14.0	(29)
		MCDB	13.6	14.5	15.3	16.4	21.2	24.7	26.6	26.5	23.9	21.6	17.4	15.1	(30)
	5%	WB	11.7	11.8	12.5	13.8	18.1	20.7	23.6	23.5	21.8	19.3	15.0	12.9	(31)
		MCDB	13.0	13.1	14.5	15.7	20.4	22.9	26.1	25.7	23.4	21.1	16.8	14.2	(32)
	10%	WB	11.0	11.1	11.9	13.2	17.1	19.7	22.8	22.7	21.1	18.5	14.3	12.2	(33)
		MCDB	12.4	12.5	13.8	15.0	19.7	22.1	25.5	24.9	23.0	20.5	16.4	13.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.4	4.6	4.9	5.0	5.0	5.2	5.0	4.9	4.5	3.8	3.8	(35)
		MCDBR	4.7	5.0	5.9	6.1	6.6	6.1	6.5	6.2	5.9	4.8	3.9	4.2	(36)
	5% WB	MCWBR	4.0	3.8	3.9	4.1	4.1	3.8	3.9	4.2	3.9	3.2	3.1	3.5	(37)
		MCWBR	4.2	4.8	5.0	4.9	5.5	5.0	4.7	4.9	4.5	3.9	3.4	3.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.321	0.337	0.370	0.395	0.405	0.404	0.399	0.397	0.386	0.378	0.345	0.317	(40)
		taud	2.499	2.455	2.382	2.325	2.344	2.374	2.392	2.402	2.418	2.445	2.484	2.513	(41)
	Ebn at Noon		815	859	868	871	870	868	869	859	841	799	775	784	(42)
		Edh at Noon	72	88	106	121	123	119	116	111	102	88	73	65	(43)
(44) All-Sky Solar Radiation	RadAvg		1.82	2.78	4.14	5.41	6.52	7.50	7.46	6.44	4.89	3.13	2.01	1.58	(44)
	RadStd		0.18	0.27	0.31	0.34	0.45	0.28	0.26	0.20	0.26	0.26	0.21	0.15	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.30	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	N/A	+50

Nomenclature: See separate page