

CAP COURONNE, France

WMO: 076530

Lat: 43.332N

Lon: 5.053E

Elev: 27

StdP: 101.00

Time Zone: 1.00 (EUC)

Period: 82-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.6	0.4	-7.7	2.0	-1.3	-5.0	2.5	1.8	20.6	3.0	18.7	4.9	7.9	340	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	30.7	22.6	29.5	22.3	28.3	21.8	24.8	28.7	24.0	27.8	23.2	26.8	5.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.6	18.5	27.4	22.8	17.6	26.6	22.0	16.7	25.6	75.5	28.8	72.2	27.8	69.0	26.9	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	15.0	13.3	-3.7	34.0	3.7	1.5	-6.4	35.1	-8.6	36.0	-10.7	36.9	-13.4	38.0
			-5.5	26.7	4.1	0.7	-8.4	27.2	-10.9	27.7	-13.2	28.1	-16.2	28.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	8.0	8.2	11.0	13.4	17.3	20.9	24.7	23.4	21.3	17.4	11.9	9.1
	DBStd	6.47	3.87	3.63	2.75	2.21	2.72	2.47	2.03	2.24	2.25	2.52	3.73	3.23
	HDD10.0	253	79	69	22	3	0	0	0	0	0	24	56	
	HDD18.3	1568	320	284	227	148	52	6	0	4	47	193	286	
	CDD10.0	2294	17	19	53	105	227	326	455	416	338	229	82	28
	CDD18.3	567	0	0	0	1	21	82	197	157	92	17	1	0
	CDH23.3	3169	0	0	0	2	58	346	1462	958	330	13	0	0
	CDH26.7	723	0	0	0	0	6	53	395	226	43	0	0	0
Wind	WSAvg	6.0	6.3	6.2	6.6	6.8	5.2	5.4	5.2	5.7	5.3	6.1	6.7	6.3
Precipitation	PrecAvg	501	46	32	26	49	37	25	11	22	77	72	66	40
	PrecMax	734	136	117	72	136	88	110	66	73	210	142	163	150
	PrecMin	236	0	0	0	0	0	0	0	0	0	23	5	0
	PrecStd	138	39	30	21	33	27	28	14	21	56	32	43	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.2	17.3	19.8	22.2	27.2	30.2	33.9	33.0	30.1	24.6	19.8	17.2
		MCWB	11.4	13.3	15.1	16.0	19.5	21.7	22.9	23.9	20.6	20.0	15.5	14.3
	2%	DB	14.4	15.1	17.9	19.9	24.8	28.4	31.2	30.5	27.7	23.3	18.7	15.7
		MCWB	12.2	12.0	13.1	14.3	19.0	20.4	22.8	22.8	20.6	19.1	15.4	13.7
	5%	DB	13.6	13.9	16.3	18.6	23.3	26.7	29.7	29.1	26.3	22.2	17.9	14.7
		MCWB	11.6	11.5	12.3	13.8	18.0	19.6	22.7	22.3	20.5	18.6	15.0	13.0
	10%	DB	12.9	13.0	15.2	17.4	22.0	25.3	28.7	27.7	25.2	21.1	17.0	13.9
		MCWB	10.9	11.0	11.7	13.4	17.4	19.3	22.4	21.8	20.2	18.1	14.7	12.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.3	14.4	15.7	16.7	20.8	23.5	25.7	26.5	23.6	21.2	17.2	15.3
		MCDB	14.1	17.1	19.9	21.3	24.4	28.2	30.0	30.3	26.7	23.6	18.4	16.1
	2%	WB	12.6	12.9	14.1	15.4	19.7	22.1	24.8	25.1	22.6	20.2	16.2	14.1
		MCDB	13.6	14.3	17.0	18.6	23.5	25.7	28.7	29.0	25.6	22.0	17.4	14.8
	5%	WB	11.8	12.1	13.2	14.7	18.8	21.1	24.2	24.2	22.0	19.6	15.2	13.0
		MCDB	13.1	13.6	15.4	17.5	22.4	24.7	28.1	27.8	25.2	21.3	17.1	14.3
	10%	WB	10.7	11.2	12.4	13.9	17.9	20.2	23.5	23.2	21.3	18.8	14.4	12.2
		MCDB	12.4	12.9	14.5	16.5	21.3	23.7	27.3	26.6	24.2	20.7	16.6	13.6
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.8	6.6	7.1	7.3	7.5	7.9	7.7	7.3	5.9	5.1	5.1
		MCDBR	5.1	6.1	8.0	8.9	9.1	9.3	9.3	9.7	9.0	7.0	4.8	4.8
		MCWBR	4.2	4.5	5.6	6.0	5.6	5.0	5.2	5.6	5.2	4.7	4.0	4.1
	5% WB	MCDBR	4.6	5.7	7.2	7.9	8.5	7.9	8.2	8.1	7.5	5.8	4.7	4.7
		MCWBR	4.3	4.5	5.4	5.7	5.4	4.8	5.4	5.8	4.9	4.4	4.3	4.4
Clear-Sky Solar Irradiance	taub	0.326	0.343	0.378	0.400	0.409	0.409	0.403	0.401	0.390	0.386	0.351	0.322	
	taud	2.485	2.437	2.354	2.313	2.333	2.363	2.382	2.392	2.410	2.419	2.464	2.499	
	Ebn at Noon	806	851	859	866	865	864	865	855	837	789	765	775	
	Edh at Noon	73	89	109	123	124	121	117	112	103	90	74	66	
All-Sky Solar Radiation	RadAvg	1.81	2.78	4.13	5.40	6.51	7.49	7.45	6.41	4.87	3.10	2.00	1.57	
	RadStd	0.18	0.27	0.30	0.35	0.43	0.28	0.26	0.21	0.26	0.26	0.21	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.29	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	N/A	+49

Nomenclature: See separate page