

CAP CEPET, France

WMO: 076610

Lat: 43.079N

Lon: 5.941E

Elev: 440

StdP: 14.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.4	38.0	16.9	13.1	40.8	20.9	15.9	42.6	49.0	51.1	44.5	50.4	14.6	330	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.4	86.8	70.3	84.5	70.1	82.5	69.5	75.6	81.6	74.1	80.3	72.6	79.1	12.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.8	128.0	79.5	72.0	120.3	78.3	70.3	113.5	77.0	39.4	81.4	37.9	80.3	36.5	79.2	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.0	36.1	31.9	DB	33.3	91.2	3.2	2.3	31.0	92.9	29.1	94.3	27.3	95.6	24.9	97.3	(4)
(5)			WB	28.5	77.0	3.2	2.4	26.1	78.7	24.3	80.2	22.5	81.5	20.1	83.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.7	48.4	48.5	52.7	57.0	63.2	70.6	75.1	75.5	68.6	62.8	54.8	50.1
	DBStd	10.59	4.49	4.63	4.14	4.19	4.25	4.39	3.85	3.69	4.12	4.32	4.92	4.82
	HDD50	254	83	72	21	3	0	0	0	0	0	1	16	58
	HDD65	2563	515	463	383	242	83	5	0	0	14	91	306	461
	CDD50	4149	33	29	103	212	410	617	777	789	559	398	160	62
	CDD65	984	0	0	0	2	28	172	312	324	122	24	0	0
	CDH74	5428	0	0	0	2	64	791	2051	2146	365	9	0	0
	CDH80	1114	0	0	0	0	4	127	454	503	26	0	0	0
Wind	WSAvg	13.7	14.5	14.2	15.1	14.4	13.6	12.1	13.4	12.1	12.7	13.4	14.6	14.6
Precipitation	PrecAvg	26.4	2.8	1.9	1.5	2.4	1.7	1.2	0.4	0.6	3.1	4.0	4.0	2.7
	PrecMax	42.4	7.7	5.7	4.7	6.1	4.0	4.3	1.8	2.6	7.2	9.8	10.6	7.8
	PrecMin	13.1	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.1	1.2	1.1	0.1
	PrecStd	6.7	2.3	1.6	1.3	1.6	1.3	1.3	0.4	0.7	2.0	2.1	2.5	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.3	61.2	67.6	72.5	79.8	87.5	89.8	90.4	82.7	75.4	67.4	62.1
		MCWB	52.4	51.3	53.9	58.2	63.6	69.4	70.0	71.1	68.1	64.3	60.0	54.4
	2%	DB	58.3	58.4	63.4	69.1	75.4	83.2	86.8	87.0	80.1	73.0	64.8	59.7
		MCWB	51.4	50.5	52.8	57.3	62.0	68.3	70.4	70.5	67.6	64.3	59.4	54.2
	5%	DB	56.3	56.6	61.1	66.5	72.7	80.7	84.5	84.7	78.1	71.1	63.1	58.1
		MCWB	51.3	50.1	52.5	56.0	61.0	67.6	70.3	70.4	66.7	63.4	58.4	53.5
	10%	DB	54.8	54.9	59.2	64.1	70.5	78.4	82.5	82.8	75.9	69.2	61.6	56.7
		MCWB	50.5	49.5	51.7	55.1	60.3	66.7	69.7	70.0	65.5	62.7	57.2	52.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.5	54.9	56.8	61.7	67.2	74.5	77.7	78.4	73.2	68.9	63.1	58.2
		MCDB	57.6	57.0	62.0	68.0	73.3	82.1	83.5	83.6	78.0	71.9	64.8	59.6
	2%	WB	54.2	53.3	55.6	59.4	65.3	71.9	75.6	76.1	71.4	67.1	61.2	56.3
		MCDB	56.4	55.6	60.3	65.5	71.4	78.7	82.0	81.6	76.4	70.1	63.4	58.0
	5%	WB	52.8	52.1	54.3	58.1	63.7	70.4	74.1	74.4	69.7	65.7	59.8	54.9
		MCDB	55.3	54.9	58.6	63.6	69.6	77.1	80.6	80.2	75.2	69.0	62.1	57.0
	10%	WB	51.3	50.7	53.2	56.7	62.2	68.9	72.6	73.0	68.2	64.3	58.3	53.4
		MCDB	54.1	54.1	57.3	61.7	67.9	75.7	79.2	79.5	73.2	67.7	60.9	56.0
Mean Daily Temperature Range	5% DB	MDBR	8.6	9.9	11.1	11.5	12.1	13.0	13.4	13.4	12.2	10.2	9.0	8.4
		MCDBR	9.2	11.1	13.1	14.3	14.7	15.5	15.6	15.3	14.0	11.7	9.9	9.2
		MCWBR	7.4	8.5	8.5	8.5	8.5	8.3	8.6	9.3	8.7	7.5	7.6	7.2
	5% WB	MCDBR	7.6	9.6	11.3	12.5	12.4	13.4	13.4	13.0	12.3	9.9	8.0	7.6
		MCWBR	7.2	8.2	8.1	8.5	8.4	8.6	9.4	9.8	8.9	7.2	7.3	7.2
Clear-Sky Solar Irradiance	taub	0.323	0.340	0.374	0.398	0.408	0.406	0.401	0.398	0.389	0.382	0.348	0.320	
	taud	2.493	2.447	2.369	2.317	2.333	2.370	2.387	2.403	2.413	2.427	2.467	2.506	
	Ebn at Noon	258	272	274	275	275	275	275	272	266	252	245	248	
	Edh at Noon	23	28	34	39	39	38	37	35	33	29	23	21	
All-Sky Solar Radiation	RadAvg	586	876	1315	1709	2052	2365	2358	2049	1550	1000	641	508	
	RadStd	56	86	105	108	148	88	88	68	80	79	65	51	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+90

Nomenclature: See separate page