

CAP LEUCATE, France

WMO: 076660

Lat: 42.917N

Lon: 3.060E

Elev: 164

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 32.0	(c) 35.1	(d) 17.2	(e) 13.2	(f) 38.9	(g) 21.1	(h) 15.9	(i) 39.6	(j) 55.9	(k) 51.4	(l) 46.6	(m) 50.9	(n) 24.0	(o) 320	(p) 0.630

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	88.1	68.4	85.1	68.1	82.5	67.6	74.7	78.9	73.4	78.2	72.1	76.9	15.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.6	125.8	77.3	71.9	118.8	75.7	70.7	113.6	74.6	38.4	78.7	37.0	78.4	35.9	77.1	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 43.5	(b) 37.0	(c) 32.3	(e) 30.7	(f) 93.8	(g) 4.1	(h) 4.1	(i) 27.7	(j) 96.8	(k) 25.3	(l) 99.2	(m) 23.1	(n) 101.5	(o) 20.1	(p) 104.5		
(4) 43.5	(5) 37.0	(6) 32.3	(7) 30.7	(8) 93.8	(9) 4.1	(10) 4.1	(11) 27.7	(12) 96.8	(13) 25.3	(14) 99.2	(15) 23.1	(16) 101.5	(17) 20.1	(18) 104.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.7	47.8	48.5	53.1	57.5	62.9	70.7	75.2	74.7	69.2	63.3	54.7	49.5	
	DBStd	10.99	5.90	6.06	5.07	4.53	4.79	5.19	4.22	4.17	4.35	5.20	5.85	5.60	
	HDD50	327	111	85	26	2	0	0	0	0	0	1	26	76	
	HDD65	2589	533	463	370	228	98	9	0	0	11	89	308	480	
	CDD50	4222	43	42	121	228	399	620	783	766	577	414	168	61	
	CDD65	1010	0	0	1	4	31	179	318	301	138	37	1	0	
	CDH74	5109	0	0	2	12	89	840	2004	1704	407	51	0	0	
	CDH80	1190	0	0	0	2	15	201	501	399	66	6	0	0	
Wind	WSAvg	15.1	16.6	16.9	16.4	15.7	15.7	13.9	13.8	12.7	13.1	15.3	16.3	15.2	
Precipitation	PrecAvg	21.5	2.2	1.6	1.5	1.9	1.8	0.9	0.6	1.0	2.0	3.1	2.9	2.1	
	PrecMax	37.2	7.8	4.5	6.2	5.6	4.8	3.8	2.0	3.6	8.1	9.0	8.9	8.6	
	PrecMin	12.8	0.0	0.0	0.0	0.1	0.3	0.1	0.1	0.0	0.4	0.1	0.3	0.1	
	PrecStd	6.4	2.0	1.3	1.3	1.5	1.2	0.9	0.4	0.8	1.7	2.2	2.6	2.3	
	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.8	64.8	71.2	76.0	81.2	90.0	92.2	91.8	86.2	79.1	69.2	64.0
MCWB			55.3	53.0	55.5	59.1	64.2	69.1	68.2	70.1	65.0	64.3	59.6	54.9	
2%		DB	61.0	60.2	65.6	70.5	76.2	85.3	88.2	87.6	81.5	74.5	65.8	60.7	
		MCWB	53.4	51.5	53.9	57.4	62.2	68.2	68.0	69.6	64.9	64.2	59.9	53.9	
5%		DB	58.2	57.5	62.4	67.2	72.9	81.7	85.0	84.2	78.3	71.8	64.2	58.7	
		MCWB	51.7	50.4	52.7	56.4	60.7	67.4	68.2	68.8	64.5	63.5	59.6	53.9	
10%		DB	55.8	55.5	59.9	64.4	70.1	78.6	82.5	81.4	75.8	69.5	62.7	57.1	
		MCWB	50.4	50.3	51.6	56.0	59.9	66.2	67.8	68.3	64.6	63.2	58.3	52.5	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures		0.4%	WB	56.7	55.3	57.5	62.7	67.0	73.5	76.8	76.8	72.6	69.7	63.4	57.6
			MCDB	62.7	60.9	65.6	68.7	75.3	80.3	80.9	80.7	75.2	71.9	65.8	60.6
	2%	WB	54.6	53.6	55.8	60.7	65.1	71.8	74.7	75.2	71.1	67.5	62.0	56.2	
		MCDB	59.3	56.9	61.5	66.9	71.2	78.4	78.6	79.3	73.7	70.0	64.6	59.1	
	5%	WB	53.0	52.5	54.6	58.9	63.9	70.5	73.4	73.8	69.9	66.4	60.7	54.7	
		MCDB	57.0	55.9	59.2	64.1	69.2	76.8	78.0	78.4	72.7	68.8	63.4	57.9	
	10%	WB	51.3	51.2	53.7	57.5	62.5	69.1	72.0	72.4	68.7	65.4	59.2	53.1	
		MCDB	55.0	54.8	57.4	61.8	67.4	75.4	77.1	77.1	72.1	68.0	62.0	56.7	
	Mean Daily Temperature Range	5% DB	MDBR	9.3	9.7	10.4	10.4	10.8	11.8	12.4	11.9	11.2	9.4	8.9	9.0
			MCDBR	11.2	12.3	13.9	14.0	14.9	16.0	15.8	15.7	14.3	11.9	9.6	10.1
MCWBR			7.3	8.0	7.6	7.0	7.4	6.7	6.9	7.0	6.5	6.9	7.1	7.0	
5% WB		MCDBR	9.7	10.2	10.9	11.0	10.7	11.6	10.3	10.6	8.6	8.0	7.6	8.7	
		MCWBR	7.4	7.6	7.0	6.9	6.7	6.1	6.8	7.3	6.2	5.8	6.6	7.1	
Clear-Sky Solar Irradiance	taub	0.316	0.330	0.371	0.398	0.409	0.415	0.413	0.412	0.391	0.375	0.339	0.314		
	taud	2.513	2.473	2.379	2.310	2.333	2.348	2.361	2.370	2.411	2.459	2.503	2.523		
	Ebn at Noon	262	276	276	276	275	272	272	268	266	256	250	252		
	Edh at Noon	23	27	34	39	39	39	38	36	33	28	23	21		
All-Sky Solar Radiation	RadAvg	549	843	1223	1566	1842	2123	2126	1855	1432	941	615	488		
	RadStd	58	85	102	135	129	114	107	98	82	88	67	51		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page