

CANNES-MANDELIEU AP, France

WMO: 076840

Lat: 43.5564N

Lon: 6.9506E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.7	32.8	15.5	12.0	43.4	19.5	14.6	43.1	22.9	55.3	20.6	53.7	4.2	0	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	88.3	69.3	85.5	70.5	83.6	70.4	75.4	82.9	74.2	81.7	72.9	80.7	9.0	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.9	122.1	81.3	71.5	116.3	80.1	70.1	110.7	79.0	38.9	83.1	37.6	81.7	36.5	80.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.4	15.7	13.0	DB	28.0	94.9	2.1	2.7	26.5	96.8	25.3	98.3	24.1	99.8	22.6	101.8	
			WB	25.0	77.1	2.3	1.4	23.3	78.1	21.9	79.0	20.6	79.8	19.0	80.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.8	47.0	47.4	51.5	56.7	62.7	69.5	74.1	73.9	68.6	62.1	54.1	48.7
	DBStd	10.66	4.25	4.44	4.11	3.96	4.38	4.58	4.12	3.90	4.12	4.31	5.22	4.58
	HDD50	339	111	92	30	2	1	0	0	0	0	1	23	79
	HDD65	2788	557	493	418	249	97	12	3	3	14	108	328	506
	CDD50	3899	19	19	77	204	394	584	746	740	559	375	145	37
	CDD65	873	0	0	0	0	25	146	284	278	123	17	0	0
	CDH74	6965	0	0	2	6	141	1004	2559	2415	780	57	1	0
	CDH80	1631	0	0	0	0	11	195	693	628	103	1	0	0
Wind	WSAvg	5.3	5.2	5.2	5.8	5.5	5.4	5.3	5.6	5.4	5.2	4.8	5.0	5.1
Precipitation	PrecAvg	39.5	3.8	2.6	2.4	3.5	2.6	1.9	0.9	1.3	4.0	5.9	6.4	4.1
	PrecMax	58.8	15.3	8.0	9.9	9.3	7.4	4.2	3.5	3.8	9.3	13.6	22.1	11.1
	PrecMin	18.8	0.0	0.0	0.0	0.6	0.2	0.1	0.0	0.0	0.4	0.7	0.2	0.2
	PrecStd	10.6	3.7	2.3	2.2	2.4	1.8	1.3	0.8	0.9	2.7	3.5	5.0	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.5	64.5	69.9	74.7	81.6	89.5	92.7	92.4	86.2	78.4	70.4	64.7
		MCWB	51.0	50.9	54.3	58.3	64.0	71.2	66.6	68.7	66.9	64.7	58.1	53.5
	2%	DB	60.8	60.7	65.5	71.1	77.7	84.6	88.0	88.4	82.6	75.5	67.8	62.1
		MCWB	51.4	50.6	52.3	57.2	63.0	68.4	69.2	69.6	67.8	64.7	58.1	53.2
	5%	DB	58.3	58.8	63.0	68.5	75.0	81.7	85.6	85.3	80.6	73.4	65.9	60.0
		MCWB	50.1	50.3	52.1	56.4	62.5	68.7	71.3	70.6	68.0	63.7	57.8	52.1
	10%	DB	56.2	57.0	61.0	66.1	72.3	79.5	83.8	83.2	78.5	71.4	63.7	57.9
		MCWB	48.7	49.3	52.2	56.0	61.4	68.3	71.1	71.0	67.3	62.7	56.3	50.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.2	54.8	57.5	62.0	68.7	75.1	77.4	76.7	73.6	69.1	62.5	57.4
		MCDB	59.9	59.6	64.4	68.4	75.7	83.1	84.7	83.7	80.0	75.1	66.9	61.4
	2%	WB	53.3	53.1	56.0	60.3	65.9	73.1	75.7	75.4	71.7	67.3	60.8	55.4
		MCDB	58.8	58.1	61.7	67.2	73.7	80.2	83.6	82.2	79.1	73.0	65.4	59.8
	5%	WB	51.6	51.8	54.7	59.0	64.4	71.3	74.4	74.2	70.2	65.6	59.3	53.8
		MCDB	56.7	56.9	60.4	66.1	71.7	78.8	82.3	81.5	77.8	71.1	64.0	58.1
	10%	WB	49.9	50.3	53.4	57.5	63.1	69.7	73.1	72.9	68.6	63.9	57.7	52.0
		MCDB	54.9	55.9	59.5	63.9	70.1	77.5	81.0	80.8	76.3	69.6	62.3	56.5
Mean Daily Temperature Range	5% DB	MDBR	17.3	17.6	17.6	16.9	16.8	16.8	17.5	18.0	18.1	16.8	17.3	17.5
		MCDBR	19.8	19.8	21.1	20.3	20.3	20.3	20.1	21.3	20.3	18.9	18.2	19.3
		MCWBR	12.9	13.0	12.8	10.9	10.6	10.5	11.1	11.3	11.2	11.3	11.4	12.8
	5% WB	MCDBR	17.3	17.6	17.5	17.4	16.4	17.0	16.7	16.7	17.2	16.4	15.1	16.2
		MCWBR	12.4	12.6	12.2	11.1	10.3	10.8	11.2	11.1	11.2	11.1	10.6	11.7
Clear-Sky Solar Irradiance	taub	0.329	0.352	0.393	0.430	0.439	0.444	0.436	0.427	0.416	0.400	0.359	0.325	
	taud	2.461	2.393	2.295	2.210	2.237	2.266	2.298	2.328	2.336	2.360	2.424	2.480	
	Ebn at Noon	253	265	267	265	266	264	265	263	256	244	238	243	
	Edh at Noon	23	30	37	43	43	42	40	38	35	30	24	21	
All-Sky Solar Radiation	RadAvg	572	851	1274	1626	1948	2249	2280	1987	1489	967	609	495	
	RadStd	57	94	120	118	148	108	108	72	86	80	66	54	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (27 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page