

CANNES-MANDELIEU AP, France

WMO: 076840

Lat: 43.5564N

Lon: 6.9506E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.5	-9.2	1.7	6.3	-7.0	2.1	6.2	10.2	13.0	9.2	12.0	1.9	0	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	31.3	20.7	29.7	21.4	28.7	21.3	24.1	28.3	23.4	27.6	22.7	27.0	4.0	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	17.4	27.4	21.9	16.6	26.7	21.2	15.8	26.1	72.6	28.4	69.7	27.6	67.1	27.0	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	7.0	5.8	-2.2	34.9	1.2	1.5	-3.1	36.0	-3.7	36.9	-4.4	37.7	-5.2	38.8		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-3.9	25.1	1.3	0.8	-4.8	25.6	-5.6	26.1	-6.3	26.6	-7.2	27.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	8.3	8.6	10.8	13.7	17.0	20.8	23.4	23.3	20.3	16.7	12.3	9.3
	DBStd	5.92	2.36	2.47	2.28	2.20	2.44	2.54	2.29	2.17	2.29	2.39	2.90	2.54
	HDD10.0	188	62	51	17	1	1	0	0	0	0	1	13	44
	HDD18.3	1549	309	274	232	138	54	7	2	2	8	60	182	281
	CDD10.0	2166	11	11	43	113	219	324	414	411	311	208	81	21
	CDD18.3	485	0	0	0	0	14	81	158	154	68	9	0	0
	CDH23.3	3869	0	0	1	3	78	558	1422	1342	433	32	1	0
	CDH26.7	906	0	0	0	0	6	108	385	349	57	1	0	0
Wind	WSAvg	2.4	2.3	2.3	2.6	2.5	2.4	2.4	2.5	2.4	2.3	2.1	2.2	2.3
Precipitation	PrecAvg	1004	96	65	61	90	67	49	24	34	101	149	163	105
	PrecMax	1494	389	202	252	237	187	107	88	97	235	345	562	282
	PrecMin	477	0	1	0	16	6	2	1	0	10	19	6	6
	PrecStd	268	94	58	56	61	45	34	21	22	68	89	127	78
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.0	18.1	21.1	23.7	27.6	31.9	33.7	33.6	30.1	25.8	21.3	18.1
		MCWB	10.6	10.5	12.4	14.6	17.8	21.8	19.2	20.4	19.4	18.2	14.5	12.0
	2%	DB	16.0	16.0	18.6	21.7	25.4	29.2	31.1	31.3	28.1	24.2	19.9	16.7
		MCWB	10.8	10.3	11.3	14.0	17.2	20.2	20.7	20.9	19.9	18.2	14.5	11.8
	5%	DB	14.6	14.9	17.2	20.3	23.9	27.6	29.8	29.6	27.0	23.0	18.8	15.6
		MCWB	10.1	10.2	11.2	13.6	17.0	20.4	21.9	21.4	20.0	17.6	14.3	11.2
	10%	DB	13.4	13.9	16.1	19.0	22.4	26.4	28.8	28.5	25.8	21.9	17.6	14.4
		MCWB	9.3	9.6	11.2	13.4	16.3	20.2	21.7	21.7	19.6	17.0	13.5	10.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.9	12.7	14.2	16.7	20.4	23.9	25.2	24.9	23.1	20.6	17.0	14.1
		MCDB	15.5	15.4	18.0	20.2	24.3	28.4	29.3	28.7	26.7	23.9	19.4	16.3
	2%	WB	11.9	11.7	13.3	15.7	18.9	22.8	24.3	24.1	22.1	19.6	16.0	13.0
		MCDB	14.9	14.5	16.5	19.6	23.2	26.8	28.7	27.9	26.1	22.8	18.5	15.5
	5%	WB	10.9	11.0	12.6	15.0	18.0	21.8	23.5	23.5	21.2	18.6	15.2	12.1
		MCDB	13.7	13.9	15.8	18.9	22.1	26.0	28.0	27.5	25.5	21.7	17.8	14.5
	10%	WB	9.9	10.2	11.9	14.2	17.3	20.9	22.8	22.7	20.3	17.7	14.3	11.1
		MCDB	12.7	13.3	15.3	17.7	21.1	25.3	27.2	27.1	24.6	20.9	16.8	13.6
Mean Daily Temperature Range	5% DB	MDBR	9.6	9.8	9.8	9.4	9.3	9.3	9.7	10.0	10.1	9.4	9.6	9.7
		MCDBR	11.0	11.0	11.7	11.3	11.3	11.3	11.2	11.8	11.3	10.5	10.1	10.7
		MCWBR	7.2	7.2	7.1	6.0	5.9	5.8	6.1	6.3	6.2	6.3	6.3	7.1
	5% WB	MCDBR	9.6	9.8	9.7	9.7	9.1	9.4	9.3	9.3	9.5	9.1	8.4	9.0
		MCWBR	6.9	7.0	6.8	6.2	5.7	6.0	6.2	6.2	6.2	6.2	5.9	6.5
Clear-Sky Solar Irradiance	taub	0.329	0.352	0.393	0.430	0.439	0.444	0.436	0.427	0.416	0.400	0.359	0.325	
	taud	2.461	2.393	2.295	2.210	2.237	2.266	2.298	2.328	2.336	2.360	2.424	2.480	
	Ebn at Noon	798	836	841	835	837	832	834	830	808	769	749	766	
	Edh at Noon	74	93	116	136	136	133	127	120	110	95	77	67	
All-Sky Solar Radiation	RadAvg	1.80	2.68	4.02	5.12	6.14	7.09	7.19	6.26	4.70	3.05	1.92	1.56	
	RadStd	0.18	0.30	0.38	0.37	0.47	0.34	0.34	0.23	0.27	0.25	0.21	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page